

Regulatory Commission, Washington, DC 20555-0001, and it is requested that copies be transmitted either by means of facsimile transmission to 301-415-3725 or by e-mail to OGCMailCenter@nrc.gov. A copy of the request for hearing and petition for leave to intervene should also be sent to the licensee. The licensee's contact for this is Mr. P. Michael Whaley, Nuclear Reactor Manager, Kansas State University, 112 Ward Hall, Manhattan, KS 66506-2506.

Non-timely requests and/or petitions and contentions will not be entertained absent a determination by the Commission, the presiding officer, or the Atomic Safety and Licensing Board that the petition, request and/or contentions should be granted based on a balancing of the factors specified in 10 CFR 2.309(c)(1)(i)-(viii).

Detailed guidance which the NRC uses to review applications for the renewal of non-power reactor licenses can be found in the document NUREG-1537, entitled "Guidelines for Preparing and Reviewing Applications for the Licensing of Non-Power Reactors," can be obtained from the Commission's PDR. The NRC maintains an Agencywide Documents Access and Management System (ADAMS), which provides text and image files of NRC's public documents. The detailed review guidance (NUREG-1537) may be accessed through the NRC's Public Electronic Reading Room on the Internet at <http://www.nrc.gov/reading-rm/adams.html> under ADAMS accession number ML042430055 for part one and ML042430048 for part two. Copies of the application to renew the facility license for the KSU Research Reactor are available for public inspection at the Commission's PDR, located at One White Flint North, 11555 Rockville Pike (first floor), Rockville, Maryland, 20855-2738. The initial application also may be accessed through the NRC's Public Electronic Reading Room, at the address mentioned above, under ADAMS accession number ML022630083. The revised application may be accessed under ADAMS accession number ML052620181. Persons who do not have access to ADAMS, or if there are problems in accessing the documents located in ADAMS, may contact the NRC Public Document Room Reference staff at 1-800-397-4209, 301-415-4737, or by e-mail to pdr@nrc.gov.

Dated at Rockville, Maryland, this 28th day of September 2005.

For the Nuclear Regulatory Commission.

Brian E. Thomas,

Section Chief, Research and Test Reactors Section, New, Research and Test Reactors Program, Division of Regulatory Improvement Programs, Office of Nuclear Reactor Regulation.

[FR Doc. E5-5474 Filed 10-5-05; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

[Docket Nos. 50-272 and 50-311]

PSEG Nuclear, LLC; Exelon Generation Company, LLC; Salem Nuclear Generating Station, Unit Nos. 1 and 2; Notice of Partial Withdrawal of Application for Amendment to Facility Operating License

The U.S. Nuclear Regulatory Commission (NRC or the Commission) has granted the request of PSEG Nuclear LLC (PSEG), on behalf of PSEG and Exelon Generation Company, LLC (the licensees) to withdraw a portion of its April 15, 2004, application and the August 11, 2004, and August 11, 2005, supplements for proposed amendments to Facility Operating License Nos. DPR-70 and DPR-75 for the Salem Nuclear Generating Station, Unit Nos. 1 and 2, located in Salem County, New Jersey.

One of the proposed changes would have permitted a modification to the Salem, Unit No. 1, containment cooling system. Specifically, PSEG proposed to install a new closed-loop chilled water system to supply cooling water to the containment fan cooling units during normal operation. The emergency containment cooling water system would remain the safety-related source of cooling water for postulated accidents. The request involved changes to the system configuration, revisions to the analysis of containment temperature and pressure following a design-basis event, and associated changes to the Technical Specifications. The Commission had previously issued a Notice of Consideration of Issuance of Amendment published in the **Federal Register** on October 12, 2004 (69 FR 60684). However, by letter dated August 11, 2005, PSEG withdrew the above-referenced proposed change.

For further details with respect to this action, see the application for amendment dated April 15, 2004, as supplemented by letters dated August 11, 2004, and August 11, 2005. Documents may be examined, and/or copied for a fee, at the NRC's Public Document Room (PDR), located at One White Flint North, Public File Area 01 F21, 11555 Rockville Pike (first floor),

Rockville, Maryland. Publicly-available records will be accessible electronically from the Agencywide Documents Access and Management Systems (ADAMS) Public Electronic Reading Room on the internet at the NRC Web site, <http://www.nrc.gov/reading-rm/adams/html>. Persons who do not have access to ADAMS or who encounter problems in accessing the documents located in ADAMS, should contact the NRC PDR reference staff by telephone at 1-800-397-4209, or 301-415-4737, or by e-mail to pdr@nrc.gov.

Dated at Rockville, Maryland, this 30th day of September 2005.

For the Nuclear Regulatory Commission.

Stewart N. Bailey,

Sr. Project Manager, Section 2, Project Directorate I, Division of Licensing Project Management, Office of Nuclear Reactor Regulation.

[FR Doc. E5-5473 Filed 10-5-05; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

[Docket Nos. 50-220 and 50-410]

Nine Mile Point Nuclear Station, LLC; Nine Mile Point Nuclear Station, Units 1 and 2; Notice of Availability of the Draft Supplement 24 to the Generic Environmental Impact Statement for License Renewal of Nuclear Plants, and Public Meeting for the License Renewal of Nine Mile Point Nuclear Station, Units 1 and 2

Notice is hereby given that the U.S. Nuclear Regulatory Commission (NRC, Commission) has published a draft plant-specific supplement to the Generic Environmental Impact Statement for License Renewal of Nuclear Plants (GEIS), NUREG-1437, regarding the renewal of operating licenses DPR-63 and NPF-69 for an additional 20 years of operation for the Nine Mile Point Nuclear Station, Units 1 and 2 (Nine Mile Point). Nine Mile Point is located in northern New York on the shore of Lake Ontario, approximately 5 miles northeast of Oswego, New York, 36 miles north-northeast of Syracuse, New York, and 65 miles east of Rochester, New York. Possible alternatives to the proposed action (license renewal) include no action and reasonable alternative energy sources.

The draft Supplement 24 to the GEIS is publicly available at the NRC Public Document Room (PDR), located at One White Flint North, 11555 Rockville Pike, Rockville, Maryland, 20852, or from the NRC's Agencywide Documents