

submissions by uploading document files electronically. If you wish to mail additional materials in reference to an electronic or facsimile submission, you must submit them to the OSHA Docket Office (see the section of this notice titled "Addresses"). The additional materials must clearly identify your electronic comments by your name, date, and the docket number so the Agency can attach them to your comments.

Because of security procedures, the use of regular mail may cause a significant delay in the receipt of comments. For information about security procedures concerning the delivery of materials by hand, express delivery, messenger, or courier service, please contact the OSHA Docket Office at (202) 693-2350 (TTY (877) 889-5627).

Comments and submissions are posted without change at <http://www.regulations.gov>. Therefore, OSHA cautions commenters about submitting personal information such as social security numbers and date of birth. Although all submissions are listed in the <http://www.regulations.gov> index, some information (e.g., copyrighted material) is not publicly available to read or download through this Web site. All submissions, including copyrighted material, are available for inspection and copying at the OSHA Docket Office. Information on using the <http://www.regulations.gov> Web site to submit comments and access the docket is available at the Web site's "User Tips" link. Contact the OSHA Docket Office for information about materials not available through the Web site, and for assistance in using the Internet to locate docket submissions.

V. Authority and Signature

Edwin G. Foulke, Jr., Assistant Secretary of Labor for Occupational Safety and Health, directed the preparation of this notice. The authority for this notice is the Paperwork Reduction Act of 1995 (44 U.S.C. 3506 *et seq.*) and Secretary of Labor's Order No. 5-2002 (67 FR 65008).

Signed at Washington, DC, on August 21, 2007.

Edwin G. Foulke, Jr.,

Assistant Secretary of Labor for Occupational Safety and Health.

[FR Doc. E7-17569 Filed 9-5-07; 8:45 am]

BILLING CODE 4510-26-P

NUCLEAR REGULATORY COMMISSION

[Docket No. 50-461]

Amergen Energy Company, LLC; Notice of Withdrawal of Application for Amendment to Facility Operating License

The U.S. Nuclear Regulatory Commission (the Commission) has granted the request of AmerGen Energy Company, LLC (the licensee) to withdraw its November 16, 2006, application for proposed amendment to Facility Operating License No. NPF-62 for the Clinton Power Station, Unit No. 1, located in DeWitt County, Illinois.

The proposed amendment would have revised the facility technical specifications (TSs) pertaining to TS 3.6.5.1, "Drywell," surveillance requirement, 3.6.5.1.3, to delay the performance of the next drywell bypass leakage rate test from the current requirement of November 23, 2008, to prior to startup from the Clinton Unit 1, refueling outage 12 (C1R12), projected for January 2010; and TS 5.5.13, "Primary Containment Leakage Rate Testing Program," to delay the performance of the next primary containment Type A integrated leak rate test from the current requirement of no later than November 23, 2008, to prior to startup from the C1R12 refueling outage.

The Commission had previously issued a Notice of Consideration of Issuance of Amendment published in the **Federal Register** on January 30, 2007 (72 FR 4306). However, by letter dated April 30, 2007, the licensee withdrew the proposed change.

For further details with respect to this action, see the application for amendment dated November 16, 2006, and the licensee's letter dated April 30, 2007, which withdrew the application for license amendment. Documents may be examined, and/or copied for a fee, at the NRC's Public Document Room (PDR), located at One White Flint North, Public File Area O1 F21, 11555 Rockville Pike (first floor), Rockville, Maryland. Publicly available records will be accessible electronically from the Agencywide Documents Access and Management Systems (ADAMS) Public Electronic Reading Room on the Internet at the NRC Web site, <http://www.nrc.gov/reading-rm.html>. Persons who do not have access to ADAMS or who encounter problems in accessing the documents located in ADAMS should contact the NRC PDR Reference staff by telephone at 1-800-397-4209, or 301-415-4737 or by e-mail to pdr@nrc.gov.

Dated at Rockville, Maryland, this 28th day of August, 2007.

For the Nuclear Regulatory Commission.

Stephen P. Sands,

Project Manager, Plant Licensing Branch III-2, Division of Operating Reactor Licensing, Office of Nuclear Reactor Regulation.

[FR Doc. E7-17600 Filed 9-5-07; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

[DOCKET NOS. 50-272 AND 50-311]

PSEG Nuclear LLC; Notice of Withdrawal of Application for Amendment to Facility Operating License

The U.S. Nuclear Regulatory Commission (the Commission) has granted the request of PSEG Nuclear LLC (the licensee) to withdraw its application dated August 4, 2006, as supplemented by letter dated March 8, 2007, for proposed amendment to Facility Operating License Nos. 50-272 and 50-311 for the Salem Nuclear Generating Station, Unit Nos. 1 and 2, located in Salem County, New Jersey.

The proposed amendment would have revised Technical Specification 3/4.9.3, "Decay Time," to allow the movement of irradiated fuel in the reactor pressure vessel to commence at 24 hours after shutdown or at the decay time calculated using the licensee's spent fuel pool integrated decay heat management program, whichever is later. The Commission had previously issued a Notice of Consideration of Issuance of Amendment published in the **Federal Register** on December 19, 2006 (71 FR 75999). However, by letter dated August 13, 2007, the licensee withdrew the proposed change.

For further details with respect to this action, see the application for amendment dated August 4, 2006, as supplemented by letter dated March 8, 2007, and the licensee's letter dated August 13, 2007, which withdrew the application for license amendment. Documents may be examined, and/or copied for a fee, at the NRC's Public Document Room (PDR), located at One White Flint North, Public File Area O1 F21, 11555 Rockville Pike (first floor), Rockville, Maryland. Publicly available records will be accessible electronically from the Agencywide Documents Access and Management Systems (ADAMS) Public Electronic Reading Room on the internet at the NRC Web site, <http://www.nrc.gov/reading-rm.html>. Persons who do not have access to ADAMS or who encounter problems in accessing the documents

located in ADAMS should contact the NRC PDR Reference staff by telephone at 1-800-397-4209, or 301-415-4737 or by e-mail to pdr@nrc.gov.

Dated at Rockville, Maryland, this 29th day of August 2007.

For the Nuclear Regulatory Commission.

Richard B. Ennis,

Senior Project Manager, Plant Licensing Branch I-2, Division of Operating Reactor Licensing, Office of Nuclear Reactor Regulation.

[FR Doc. E7-17606 Filed 9-5-07; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

Proposed License Renewal Interim Staff Guidance LR-ISG-2007-02: Changes to Generic Aging Lesson Learned (GALL) Report Aging Management Program (AMP) XI.E6, "Electrical Cable Connections Not Subject to 10 CFR 50.49 Environmental Qualification Requirements" Solicitation of Public Comment

AGENCY: U.S. Nuclear Regulatory Commission.

ACTION: Solicitation of public comment.

SUMMARY: The U.S. Nuclear Regulatory Commission (NRC) is soliciting public comment on its Proposed License Renewal Interim Staff Guidance LR-ISG-2007-02 (LR-ISG) for changes to its Generic Aging Lesson Learned (GALL) Report Aging Management Program (AMP) XI.E6, "Electrical Cable Connections Not Subject to 10 CFR 50.49 Environmental Qualification Requirements." This LR-ISG clarifies and recommends a one-time inspection to ensure that either aging of metallic cable connections is not occurring or an existing preventive maintenance program is effective, such that a periodic inspection is not needed. The NRC staff issues LR-ISGs to facilitate timely implementation of the license renewal rule and to review activities associated with an LRA. Upon receiving public comments, the NRC staff will evaluate the comments and make a determination to incorporate the comments, as appropriate. Once the NRC staff completes the LR-ISG, it will issue the LR-ISG for NRC and industry use. The NRC staff will also incorporate the approved LR-ISG into the next revision of the license renewal guidance documents.

DATES: Comments may be submitted by October 22, 2007. Comments received after this date will be considered, if it is practical to do so, but the Commission is able to ensure

consideration only for comments received on or before this date.

ADDRESSES: Comments may be submitted to: Chief, Rulemaking, Directives, and Editing Branch, Office of Administration, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001. Comments should be delivered to: 11545 Rockville Pike, Rockville, Maryland, Room T-6D59, between 7:30 a.m. and 4:15 p.m. on Federal workdays. Persons may also provide comments via e-mail at NRCREP@NRC.GOV. The NRC maintains an Agencywide Documents Access and Management System (ADAMS), which provides text and image files of NRC's public documents. These documents may be accessed through the NRC's Public Electronic Reading Room on the Internet at <http://www.nrc.gov/reading-rm/adams.html>. Persons who do not have access to ADAMS or who encounter problems in accessing the documents located in ADAMS should contact the NRC Public Document Room (PDR) reference staff at 1-800-397-4209, 301-415-4737, or by e-mail at pdr@nrc.gov.

FOR FURTHER INFORMATION CONTACT: Ms. Linh Tran, Project Manager, Office of Nuclear Reactor Regulation, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001; telephone 301-415-4103 or by e-mail at Int@nrc.gov.

SUPPLEMENTARY INFORMATION: Attachment 1 to this **Federal Register** notice, entitled *Staff Position and Rationale for the Proposed License Renewal Interim Staff Guidance LR-ISG-2007-02: Changes to Generic Aging Lesson Learned (GALL) Report Aging Management Program (AMP) XI.E6, "Electrical Cable Connections Not Subject to 10 CFR 50.49 Environmental Qualification Requirements,"* contains the NRC staff's rationale for publishing the proposed LR-ISG-2007-02. Attachment 2 to this **Federal Register** notice, entitled *Proposed License Renewal Interim Staff Guidance LR-ISG-2007-02: Changes to Generic Aging Lesson Learned (GALL) Report Aging Management Program (AMP) XI.E6, "Electrical Cable Connections Not Subject to 10 CFR 50.49 Environmental Qualification Requirements,"* contains the proposed revisions to GALL AMP XI.E6.

The NRC staff is issuing this notice to solicit public comments on the proposed LR-ISG-2007-02. After the NRC staff considers any public comments, it will make a determination regarding issuance of the proposed LR-ISG.

Dated at Rockville, Maryland this 29th day of August, 2007.

For the Nuclear Regulatory Commission.

Pao-Tsin Kuo,

Director, Division of License Renewal, Office of Nuclear Reactor Regulation.

Attachment 1—Staff Position and Rationale for the Proposed License Renewal Interim Staff Guidance LR-ISG-2007-02: Changes to Generic Aging Lesson Learned (GALL) Report Aging Management Program (AMP) XI.E6, "Electrical Cable Connections Not Subject to 10 CFR 50.49 Environmental Qualification Requirements"

Staff Position

The staff is proposing to revise GALL AMP XI.E6 to recommend a one-time inspection for electrical cable connections not subject to 10 CFR 50.49 environmental qualification requirement instead of the period inspection as currently stated in GALL AMP XI.E6. The staff determined that this one-time inspection, on representative sample basis, is adequate to ensure that either aging of metallic cable connections is not occurring and/or existing preventive maintenance program is effective such that a periodic inspection program is not needed.

Rationale

In reviewing the industry's documents and comments, the staff determined that although the current GALL AMP XI.E6 was based on technical bases of Electric Power Research Institute documents, Sandia National Laboratories Report, SAND 96-0344, and thermography data, few operating experiences related to failed connection due to aging had been identified. Most of the operating experience related to failed connection are due to human errors or maintenance practices. The operating experience cannot support a periodic inspection as currently recommended in GALL AMP XI.E6. However, because there have been a limited number of age related failures of cable connections, a one-time inspection of the metallic portion of electrical cable connections is warranted. On this basis, the staff is revising GALL AMP XI.E6 to clarify and recommend a one-time inspection, on a representative sampling basis, to ensure that either aging of metallic cable connections is not occurring or an existing preventive maintenance program is effective, such that a periodic inspection is not needed.