

*No significant hazards consideration comments received:* No.

*Indiana Michigan Power Company, Docket Nos. 50-315 and 50-316, Donald C. Cook Nuclear Plant, Units 1 and 2 (DCCNP-1 and DCCNP-2), Berrien County, Michigan*

*Date of application for amendments:* June 13, 2007, as supplemented by letter dated February 13, 2008.

*Brief description of amendments:* The amendments revised Section 5.5.9, "Ventilation Filter Testing Program (VFTP)," changing the specified pressure drop values for the combined high efficient particulate air filters and charcoal adsorbers for three engineered safety feature ventilation systems from less than 6 inches water gauge to less than 4 inches water gauge at the specified flow rates.

*Date of issuance:* April 28, 2008.

*Effective date:* As of the date of issuance, and shall be implemented within 45 days.

*Amendment No.:* 305 (for DCCNP-1) and 288 (for DCCNP-2).

*Facility Operating License Nos. DPR-58 and DPR-74:* Amendments revised the Renewed Operating Licenses and Technical Specifications.

*Date of initial notice in Federal Register:* August 14, 2007 (72 FR 45458). The supplemental letter contained clarifying information, did not change the initial no significant hazards consideration determination, and did not expand the scope of the original **Federal Register** notice. The Commission's related evaluation of the amendment is contained in a safety evaluation dated April 28, 2008.

*No significant hazards consideration comments received:* No.

*Omaha Public Power District, Docket No. 50-285, Fort Calhoun Station, Unit No. 1, Washington County, Nebraska*

*Date of amendment requests:* July 30 and October 19, 2007, as supplemented by letters dated August 31 and December 12, 2007, and February 21, March 28, and April 4 and 10, 2008.

*Brief description of amendment:* The amendment revised Technical Specification (TS) Limiting Condition for Operation (LCO) 2.4, "Containment Cooling," LCO 2.14, "Engineered Safety Features System Initiation Instrumentation Settings," and LCO 2.15, "Instrumentation and Control Systems"; TS Surveillance Requirement (SR) 3.1, "Instrumentation and Control," SR 3.5(4), "Containment Isolation Valves Leak Rate Tests (Type C Tests)," and SR 3.6(3), "Containment Recirculating Air Cooling and Filtering System"; and associated TS Basis

documents and Updated Safety Analysis Report sections to modify the containment spray system actuation logic to preclude automatic start of the containment spray pumps for a loss-of-coolant accident. The amendment also revised TS SR 3.6(3)a. to delete SRs for testing of the containment air cooling and filtering system emergency mode dampers and replace it with a surveillance to verify that the dampers are in the accident positions in all operating plant modes and deletes the requirement in TS SR 3.6(3)b. to remotely operate dampers. The amendment added license conditions related to the replacement and testing of containment air cleaning and filtering (CACF) unit HEPA (high-efficiency particulate air) filters and surveillance testing of the CACF unit relief ports. The license conditions require administrative controls pending the completion of detailed analysis and confirm commitments for the licensee to submit TS amendments by October 31, 2008.

*Date of issuance:* May 2, 2008.

*Effective date:* The license amendment is effective as of its date of issuance and shall be implemented prior to startup from the 2008 refueling outage.

*Amendment No.:* 255.

*Renewed Facility Operating License No. DPR-40:* The amendment revised the Technical Specifications and added additional conditions to the Renewed Facility Operating License.

*Date of initial notice in Federal Register:* August 28, 2007 (72 FR 49581), and January 29, 2008 (73 FR 5227). The supplemental letters dated August 31 and December 12, 2007, and February 21, March 28, and April 4 and 10, 2008, provided additional information that clarified the applications, did not expand the scope of the applications as originally noticed, and did not change the staff's original proposed no significant hazards consideration determination as published in the **Federal Register**. The Commission's related evaluation of the amendment is contained in a safety evaluation dated May 2, 2008.

*No significant hazards consideration comments received:* No.

Dated at Rockville, Maryland, this 9th day of May 2008.

For the Nuclear Regulatory Commission.

**Catherine Haney,**

*Director, Division of Operating Reactor Licensing, Office of Nuclear Reactor Regulation.*

[FR Doc. E8-11246 Filed 5-19-08; 8:45 am]

BILLING CODE 7590-01-P

## NUCLEAR REGULATORY COMMISSION

### Advisory Committee on Reactor Safeguards (ACRS); Meeting of the Subcommittee on Economic Simplified Boiling Water Reactor (ESBWR); Notice of Meeting

The ACRS Subcommittee on ESBWR will hold a meeting on June 3, 2008, Room T2 B3, 11545 Rockville Pike, Rockville, Maryland.

The entire meeting will be open to public attendance, with the exception of a portion that may be closed to protect information that is proprietary to General Electric-Hitachi (GEH) Nuclear Energy and its contractors pursuant to 5 U.S.C. 552b(c)(4).

The agenda for the subject meeting shall be as follows:

#### Tuesday June 3, 2008—9 a.m. Until 5:30 p.m.

The Subcommittee will review several chapters of the Safety Evaluation Report with Open Items associated with the Economic Simplified Boiling Water Reactor (ESBWR) Design Certification Application. The Subcommittee will hear presentations by and hold discussions with representatives of the NRC staff, GEH, and other interested persons regarding this matter. The Subcommittee will gather information, analyze relevant issues and facts, and formulate proposed positions and actions, as appropriate, for deliberation by the full Committee.

Members of the public desiring to provide oral statements and/or written comments should notify the Designated Federal Official, Mr. David Bessette (telephone 301/415-8065) five days prior to the meeting, if possible, so that appropriate arrangements can be made. Electronic recordings will be permitted only during those portions of the meeting that are open to the public. Detailed procedures for the conduct of and participation in ACRS meetings were published in the **Federal Register** on September 26, 2007 (72 FR 54695).

Further information regarding this meeting can be obtained by contacting the Designated Federal Official between 7:45 a.m. and 4:30 p.m. (ET). Persons planning to attend this meeting are urged to contact the above named individual at least two working days prior to the meeting to be advised of any potential changes to the agenda.

Dated: May 9, 2008.

**Cayetano Santos,**  
*Branch Chief, ACRS.*

[FR Doc. E8-11228 Filed 5-19-08; 8:45 am]

BILLING CODE 7590-01-P