

requirements pertaining to qualification of certain electrical equipment important to safety. In addition, Criterion III, "Design Control," of Appendix B, "Quality Assurance Criteria for Nuclear Power Plants," to 10 CFR Part 50 requires that where a test program is used to verify the adequacy of a specific design feature, it should include suitable qualification testing of a prototype unit under the most severe DBE.

This regulatory guide describes a method that the NRC staff considers acceptable for complying with the regulations for qualification of safety-related battery chargers and inverters for nuclear power plants.

In July 2007, the NRC published a draft of this guide as DG-1148. The public comment period closed on October 2, 2007. The staff's responses to the public comments are located in the NRC's Agencywide Documents Access and Management System (ADAMS) under Accession No. ML080640181.

Electronic copies of Regulatory Guide 1.210 are available through the NRC's public Web site under "Regulatory Guides" at <http://www.nrc.gov/reading-rm/doc-collections/>.

In addition, regulatory guides are available for inspection at the NRC's Public Document Room (PDR), which is located at 11555 Rockville Pike, Rockville, MD. The PDR mailing address is USNRC PDR, Washington, DC 20555-0001. The PDR can also be reached by telephone at (301) 415-4737 or (800) 397-4209, by fax at (301) 415-3548, and by e-mail to PDR@nrc.gov.

Regulatory guides are not copyrighted, and NRC approval is not required to reproduce them.

Dated at Rockville, Maryland, this 2nd day of June, 2008.

For the Nuclear Regulatory Commission.

Stephen C. O'Connor,

Acting Chief, Regulatory Guide Development Branch, Division of Engineering, Office of Nuclear Regulatory Research.

[FR Doc. E8-12695 Filed 6-5-08; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

Notice of Public Meeting for the Partial Site Release of the Off-Shore Piping for San Onofre Generation Station, Unit 1

AGENCY: U.S. Nuclear Regulatory Commission.

ACTION: Notice of meeting.

SUMMARY: The NRC staff will hold a public meeting to discuss the proposed

release for unrestricted use of the off-shore portion of the circulating water system from SONGS Unit 1, and to accept public comments on the proposed action. The proposed release is requested in accordance with NRC regulations at 10 CFR 50.83, Release of Part of a Power Reactor Facility or Site for Unrestricted Use. The public meeting will be held on June 11, 2008, at the Dana Point Marina Inn, 24800 Dana Point Harbor Drive, Dana Point, CA 92629. The meeting will convene at 6 p.m. and will continue until 8 p.m., as necessary. The meeting will include: (1) An overview of the NRC review and inspection processes; (2) a presentation of the proposed action; and (3) the opportunity for interested government agencies, organizations, and individuals to provide comments on the SONGS plan. To be considered, comments must be provided either at the transcribed public meeting or in writing. Persons may pre-register to attend or present oral comments at the meeting by contacting Mr. James Shepherd, the NRC Project Manager at 1-800-368-5642, extension 6712, or by e-mail at James.Shepherd@nrc.gov no later than June 9, 2008. Members of the public may also register to provide oral comments within 15 minutes of the start of the meeting. Individual, oral comments may be limited by the time available, depending on the number of persons who register. If special equipment or accommodations are needed to attend or present information at the public meeting, the need should be brought to Mr. Shepherd's attention no later than June 9, 2008, to provide the NRC staff adequate notice to determine whether the request can be accommodated.

FOR FURTHER INFORMATION CONTACT: Mr. James Shepherd, Reactor Decommissioning Branch, Division of Waste Management and Environmental Protection, Office of Federal and State Materials and Environmental Management Programs, U.S. Nuclear Regulatory Commission, Mail Stop T8 F05, Washington, DC 20555-0001. Mr. Shepherd may be contacted at the aforementioned telephone number or e-mail address.

Dated at Rockville, Maryland, this 29th day of May, 2008.

For the Nuclear Regulatory Commission.

Keith McConnell,

Deputy Director, Decommissioning and Uranium Recovery Licensing Directorate, Division of Waste Management and Environmental Protection, Office of Federal and State Materials and Environmental Management Programs.

[FR Doc. E8-12821 Filed 6-5-08; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

[Docket Nos.: 50-295 and 50-304]

Exelon Generation Company, LLC; Zion Nuclear Power Station, Units 1 and 2; Notice of Public Meeting on the Proposed License Transfer and Draft Post Shutdown Decommissioning Activities Report

AGENCY: U.S. Nuclear Regulatory Commission (NRC).

ACTION: Notice of meeting.

FOR FURTHER INFORMATION, CONTACT: Mr. John B. Hickman, Mail Stop T-8F5, Decommissioning and Uranium Recovery Licensing Directorate, Division of Waste Management and Environmental Protection, Office of Federal and State Materials and Environmental Management Programs, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, telephone: (301) 415-3017 or via e-mail: john.hickman@nrc.gov.

SUMMARY: The NRC is providing notice that the NRC staff will conduct a meeting to discuss and accept public comments on the Zion Nuclear Power Station, Units 1 and 2 (Zion) proposed license transfer and Zion Solutions (ZS) draft Post Shutdown Decommissioning Activities Report (PSDAR) on Wednesday, June 18, 2008, at 7 p.m. in a meeting room at the Illinois Beach Resort and Conference Center, 1 Lake Front Drive, Zion, Illinois (<http://www.ilresorts.com/>).

Zion began commercial operation in December 1973 for Unit 1, and September 1974 for Unit 2. Unit 1 permanently shut down on February 21, 1997, and Unit 2 permanently shut down on September 19, 1996. All fuel was removed from the reactor and placed in the spent fuel pool on April 27, 1997, for Unit 1 and February 25, 1998, for Unit 2. In accordance with 10 CFR 50.82(a)(1)(i), the licensee certified in a letter dated February 13, 1998, that operations have ceased at Zion. In accordance with 10 CFR 50.82(a)(1)(ii), the licensee certified in a letter dated March 9, 1998, that all fuel had been removed from the Zion reactor vessels