

*Effective date:* As of the date of issuance and shall be implemented within 60 days from the date of issuance.

*Amendment Nos.:* 163/145.

*Facility Operating License Nos. NPF-68 and NPF-81:* Amendments revised the licenses and the technical specifications.

*Date of initial notice in Federal Register:* May 17, 2011 (76 FR 28476).

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated November 9, 2011.

No significant hazards consideration comments received: No.

*Southern Nuclear Operating Company, Inc., Docket Nos. 50-424 and 50-425, Vogtle Electric Generating Plant, Units 1 and 2, Burke County, Georgia;*

*Date of application for amendments:* April 29, 2011

*Brief description of amendments:* The amendments revised the Technical Specifications (TSs) "RCS [reactor coolant system] Leakage Detection Instrumentation," to define a new time limit for restoring inoperable RCS leakage detection instrument to operable status and establish alternate methods of monitoring RCS leakage when one or more required monitors are inoperable. This revision is consistent with the Industry/Technical Specification Task Force (TSTF) standard technical specification traveler TSTF-513-A, "Revise PWR [pressurized water reactor] Operability Requirements and Actions for RCS Leakage [Detection] Instrumentation."

*Date of issuance:* November 10, 2011.

*Effective date:* As of the date of issuance and shall be implemented within 60 days from the date of issuance.

*Amendment Nos.:* 164/146.

*Facility Operating License Nos. NPF-68 and NPF-81:* Amendments revised the licenses and the technical specifications.

*Date of initial notice in Federal Register:* June 14, 2011 (76 FR 34768).

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated November 10, 2011.

No significant hazards consideration comments received: No.

For the Nuclear Regulatory Commission.

Dated at Rockville, Maryland, this 17th day of November 2011.

**Michele G. Evans,**

*Director, Division of Operating Reactor Licensing, Office of Nuclear Reactor Regulation.*

[FR Doc. 2011-30525 Filed 11-28-11; 8:45 am]

**BILLING CODE 7590-01-P**

## NUCLEAR REGULATORY COMMISSION

[Docket No. 50-483; NRC-2011-0276]

### Union Electric Company; Callaway Plant, Unit 1; Notice of Consideration of Issuance of Amendment to Facility Operating License, Proposed No Significant Hazards Consideration Determination, and Opportunity for a Hearing

**AGENCY:** Nuclear Regulatory Commission.

**ACTION:** Notice of license amendment request, opportunity to comment, opportunity to request a hearing.

**DATES:** Comments must be filed by December 29, 2011. A request for a hearing must be filed January 30, 2012.

**ADDRESSES:** Please include Docket ID NRC-2011-0276 in the subject line of your comments. For additional instructions on submitting comments and instructions on accessing documents related to this action, see "Submitting Comments and Accessing Information" in the **SUPPLEMENTARY INFORMATION** section of this document. You may submit comments by any one of the following methods:

- *Federal Rulemaking Web Site:* Go to <http://www.regulations.gov> and search for documents filed under Docket ID NRC-2011-0276. Address questions about NRC dockets to Carol Gallagher, telephone: (301) 492-3668; email: [Carol.Gallagher@nrc.gov](mailto:Carol.Gallagher@nrc.gov).

- *Mail comments to:* Cindy Bladey, Chief, Rules, Announcements, and Directives Branch (RADB), Office of Administration, Mail Stop: TWB-05-B01M, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001.

- *Fax comments to:* RADB at (301) 492-3446.

#### SUPPLEMENTARY INFORMATION:

#### Submitting Comments and Accessing Information

Comments submitted in writing or in electronic form will be posted on the NRC Web site and on the Federal rulemaking Web site, <http://www.regulations.gov>. Because your comments will not be edited to remove any identifying or contact information, the NRC cautions you against including any information in your submission that you do not want to be publicly disclosed.

The NRC requests that any party soliciting or aggregating comments received from other persons for submission to the NRC inform those persons that the NRC will not edit their

comments to remove any identifying or contact information, and therefore, they should not include any information in their comments that they do not want publicly disclosed.

You can access publicly available documents related to this document using the following methods:

- *NRC's Public Document Room (PDR):* The public may examine and have copied, for a fee, publicly available documents at the NRC's PDR, O1-F21, One White Flint North, 11555 Rockville Pike, Rockville, Maryland 20852.

- *NRC's Agencywide Documents Access and Management System (ADAMS):* Publicly available documents created or received at the NRC are available online in the NRC Library at <http://www.nrc.gov/reading-rm/adams.html>. From this page, the public can gain entry into ADAMS, which provides text and image files of the NRC's public documents. If you do not have access to ADAMS or if there are problems in accessing the documents located in ADAMS, contact the NRC's PDR reference staff at 1-(800) 397-4209, (301) 415-4737, or by email to [pdr.resource@nrc.gov](mailto:pdr.resource@nrc.gov). The application for amendment, dated December 10, 2010, as supplemented by letters dated June 16, 2011, and October 27, 2011, are available electronically under ADAMS Accession Nos. ML103470204, ML111680233 and ML113010383, respectively.

- *Federal Rulemaking Web Site:* Public comments and supporting materials related to this notice can be found at <http://www.regulations.gov> by searching on Docket ID NRC-2011-0276.

#### FOR FURTHER INFORMATION CONTACT:

Mohan C. Thadani, Senior Project Manager, Plant Licensing Branch IV, Division of Operating Reactor Licensing, Office of Nuclear Reactor Regulation, U.S. Nuclear Regulatory Commission, Washington, DC 20555. Telephone: (301) 415-1476; fax number: (301) 415-2102 email: [mohan.thadani@nrc.gov](mailto:mohan.thadani@nrc.gov).

The U.S. Nuclear Regulatory Commission (NRC or the Commission) is considering issuance of an amendment to Facility Operating License No. NPF-30 issued to Union Electric Company (the licensee) for operation of the Callaway Plant, Unit 1, located in Callaway County, Missouri.

The license amendment request was originally noticed in the **Federal Register** on March 8, 2011 (76 FR 12766). This notice is being reissued in its entirety to include a revised description of the amendment request. The proposed amendment would add a new Surveillance Requirement (SR)

3.3.8.6 to Technical Specification (TS) 3.3.8, "Emergency Exhaust System (EES) Actuation Instrumentation." The new SR would require the performance of response time testing on the portion of the EES required to isolate the normal fuel building ventilation exhaust flow path and initiate the fuel building ventilation isolation signal (FBVIS) mode of operation. The proposed amendment also would revise TS Table 3.3.8-1 to indicate that new SR 3.3.8.6 applies to automatic actuation Function 2, "Automatic Actuation Logic and Actuation Relays (BOP ESFAS)," and Function 3, "Fuel Building Exhaust Radiation—Gaseous." In addition, the specified frequency of new SR 3.3.8.6 would be relocated and controlled in accordance with the licensee's Surveillance Frequency Control Program in accordance with guidance in Nuclear Energy Institute (NEI) 04-10, "Risk-Informed Technical Specifications Initiative 5b, Risk-Informed Method for Control of Surveillance Frequencies." Finally, there would be corresponding changes to the Final Safety Analysis Report (FSAR).

Before issuance of the proposed license amendment, the Commission will have made findings required by the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations.

The Commission has made a proposed determination that the amendment request involves no significant hazards consideration. Under the Commission's regulations in Title 10 of the *Code of Federal Regulations* (10 CFR), Section 50.92, this means that operation of the facility in accordance with the proposed amendment would not (1) involve a significant increase in the probability or consequences of an accident previously evaluated; or (2) create the possibility of a new or different kind of accident from any accident previously evaluated; or (3) involve a significant reduction in a margin of safety. As required by 10 CFR 50.91(a), the licensee has provided its analysis of the issue of no significant hazards consideration, which the Commission issued in the **Federal Register** on March 8, 2011 (76 FR 12766). The Commission is issuing a modified no significant hazards consideration to consider aspects of the SR 3.3.8.6 relocation to the Surveillance Frequency Control Program. The NRC previously approved the relocation of surveillance frequencies as part of Callaway Plant's License Amendment No. 202, as noted in the **Federal Register** on January 11, 2011 (76 FR 1649).

1. Does the proposed change involve a significant increase in the probability or consequences of an accident previously evaluated?

*Response:* No.

There are no design changes associated with the proposed change. All design, material, and construction standards that were applicable prior to this amendment request will continue to be applicable.

The proposed change will not affect accident initiators or precursors nor adversely alter the design assumptions, conditions, and configuration of the facility or the manner in which the plant is operated and maintained with respect to such initiators or precursors. There will be no change to fuel handling methods and procedures.

Therefore, there will be no changes that would serve to increase the likelihood of occurrence of a fuel handling accident.

The proposed change changes a performance requirement, but it does not physically alter safety-related systems nor affect the way in which safety-related systems perform their functions.

The proposed TS change will serve to assure that the fuel building ventilation exhaust ESF [emergency safety feature] response time is tested and confirmed to be in accordance with the system design and consistent with the assumptions of the fuel building FHA [fuel handling accident] analysis (as revised). As such, the proposed change will not alter or prevent the capability of structures, systems, and components (SSCs) to perform their intended functions for mitigating the consequences of an accident and meeting applicable acceptance limits.

The proposed change will not affect the source term used in evaluating the radiological consequences of a fuel handling accident in the fuel building. However, the Fuel Building Ventilation Exhaust ESF response time has been increased to 90 seconds in recognition of the total delay times involved in the generation of a fuel building ventilation isolation signal (FBVIS) and the times required for actuated components to change state to their required safety configurations. Consequently, the fuel handling accident radiological consequences as reported in FSAR [Final Safety Analysis Report] Table 15.7-8 have increased. However, the increases are much less than the upper limit of "minimal" as defined pursuant to 10 CFR 50.59(c)(2)(iii) and NEI [Nuclear Energy Institute] 96-07 Revision 1 ["Guidelines for 10 CFR 50.59 Implementation," November 2000]. Therefore, there is no significant increase in the calculated consequences of a postulated design basis fuel handling accident in the fuel building. The applicable radiological dose criteria of 10 CFR 100.11, 10 CFR 50 Appendix A General Design Criterion 19, and SRP [NUREG-0800, "Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plants: LWR [Light-Water-Reactor] Edition"] 15.7.4 will continue to be met. New SR 3.3.8.6 is added to ensure system performance consistent with the accident analyses and associated dose calculations (as revised).

[The licensee's request in its letter dated October 27, 2011, for relocating the specified frequency of new SR 3.3.8.6 to the licensee-controlled Surveillance Frequency Control Program is the type of SR whose relocation to the licensee's Surveillance Frequency Control Program was previously approved in Amendment No. 202, dated July 29, 2011 (ADAMS Accession No. ML111661877). That amendment was approved based on the conclusion that the change did not involve a significant increase in the probability or consequences of accidents previously evaluated.]

Therefore, the proposed change does not involve a significant increase in the probability or consequences of an accident previously evaluated.

2. Does the proposed change create the possibility of a new or different kind of accident from any accident previously evaluated?

*Response:* No.

With respect to any new or different kind of accident, there are no proposed design changes nor are there any changes in the method by which any safety-related plant SSC performs its specified safety function. The proposed change will not affect the normal method of plant operation or change any operating parameters. No new accident scenarios, transient precursors, failure mechanisms, or limiting single failures will be introduced as a result of this amendment.

The proposed amendment will not alter the design or performance of the 7300 Process Protection System, Nuclear Instrumentation System, Solid State Protection System, BOP ESFAS, MSFIS [Main Steam and Feed Isolation System], or LSELS [Load Shedding and Emergency Load Sequencing] used in the plant protection systems.

[The licensee's request in its letter dated October 27, 2011, for relocating the specified frequency of new SR 3.3.8.6 to the licensee-controlled Surveillance Frequency Control Program is the type of SR whose relocation to the licensee's Surveillance Frequency Control Program was previously approved in Amendment No. 202, dated July 29, 2011 (ADAMS Accession No. ML111661877). That amendment was approved based on the determination that the change does not involve a possibility of creating a new or different kind of accident.]

The proposed change does not, therefore, create the possibility of a new or different accident from any accident previously evaluated.

3. Does the proposed change involve a significant reduction in a margin of safety?

*Response:* No.

There will be no effect on those plant systems necessary to assure the accomplishment of protection functions associated with reactor operation or the reactor coolant system. There will be no impact on the overpower limit, departure from nucleate boiling ratio (DNBR) limits, heat flux hot channel factor ( $F_Q$ ), nuclear enthalpy rise hot channel factor (FAH), loss of coolant accident peak cladding temperature (LOCA PCT), peak local power density, or any other limit and associated margin of safety. Required shutdown margins in the COLR [Core Operating Limits Report] will not be changed.

The proposed change does not eliminate any surveillances or alter the frequency of surveillances required by the Technical Specifications. The proposed change would add a new Technical Specification Surveillance Requirement for assuring the satisfactory performance of the fuel building ventilation exhaust ESF function in response to a[n] FBVIS. The accident analysis for a fuel handling accident in the fuel building was re-performed to support the proposed Fuel Building Ventilation Exhaust ESF response time, and this reanalysis demonstrated that the acceptance criteria continue to be met with only a slight increase in radiological consequences (i.e., less than one percent).

[The licensee's request in its letter dated October 27, 2011, for relocating the specified frequency of new SR 3.3.8.6 to the licensee-controlled Surveillance Frequency Control Program is the type of SR whose relocation to the licensee's Surveillance Frequency Control Program was previously approved in Amendment No. 202, dated July 29, 2011 (ADAMS Accession No. ML111661877). That amendment was approved based on the determination that the proposed change would not result in a significant reduction of margin of safety.]

Therefore, the proposed change does not involve a significant reduction in a margin of safety.

The NRC staff has reviewed the licensee's analysis and, based on this review, it appears that the three standards of 10 CFR 50.92(c) are satisfied. Therefore, the NRC staff proposes to determine that the amendment request involves no significant hazards consideration.

The Commission is seeking public comments on this proposed determination. Any comments received within 30 days after the date of publication of this notice will be considered in making any final determination.

Normally, the Commission will not issue the amendment until the expiration of 60 days after the date of publication of this notice. The Commission may issue the license amendment before expiration of the 60-day period provided that its final determination is that the amendment involves no significant hazards consideration. In addition, the Commission may issue the amendment prior to the expiration of the 30-day comment period should circumstances change during the 30-day comment period such that failure to act in a timely way would result, for example, in derating or shutdown of the facility. Should the Commission take action prior to the expiration of either the comment period or the notice period, it will publish in the **Federal Register** a notice of issuance. Should the Commission make a final No Significant Hazards Consideration Determination,

any hearing will take place after issuance. The Commission expects that the need to take this action will occur very infrequently.

Within 60 days after the date of publication of this notice, any person(s) whose interest may be affected by this action may file a request for a hearing and a petition to intervene with respect to issuance of the amendment to the subject facility operating license. Requests for a hearing and a petition for leave to intervene shall be filed in accordance with the Commission's "Rules of Practice for Domestic Licensing Proceedings" in 10 CFR part 2. Interested person(s) should consult a current copy of 10 CFR 2.309, which is available at the Commission's PDR, located at One White Flint North, Public File Area O1F21, 11555 Rockville Pike (first floor), Rockville, Maryland. NRC regulations are accessible electronically from the NRC Library on the NRC Web site at <http://www.nrc.gov/reading-rm/doc-collections/cfr/>. If a request for a hearing or petition for leave to intervene is filed by the above date, the Commission or a presiding officer designated by the Commission or by the Chief Administrative Judge of the Atomic Safety and Licensing Board Panel will rule on the request and/or petition; and the Secretary or the Chief Administrative Judge of the Atomic Safety and Licensing Board will issue a notice of a hearing or an appropriate order.

As required by 10 CFR 2.309, a petition for leave to intervene shall set forth with particularity the interest of the petitioner in the proceeding, and how that interest may be affected by the results of the proceeding. The petition should specifically explain the reasons why intervention should be permitted with particular reference to the following general requirements: (1) The name, address and telephone number of the requestor or petitioner; (2) the nature of the requestor's/petitioner's right under the Act to be made a party to the proceeding; (3) the nature and extent of the requestor's/petitioner's property, financial, or other interest in the proceeding; and (4) the possible effect of any decision or order which may be entered in the proceeding on the requestor's/petitioner's interest. The petition must also identify the specific contentions which the requestor/petitioner seeks to have litigated at the proceeding.

Each contention must consist of a specific statement of the issue of law or fact to be raised or controverted. In addition, the requestor/petitioner shall provide a brief explanation of the bases for the contention and a concise

statement of the alleged facts or expert opinion which support the contention and on which the petitioner intends to rely in proving the contention at the hearing. The requestor/petitioner must also provide references to those specific sources and documents of which the petitioner is aware and on which the petitioner intends to rely to establish those facts or expert opinion. The petition must include sufficient information to show that a genuine dispute exists with the applicant on a material issue of law or fact. Contentions shall be limited to matters within the scope of the amendment under consideration. The contention must be one which, if proven, would entitle the petitioner to relief. A requestor/petitioner who fails to satisfy these requirements with respect to at least one contention will not be permitted to participate as a party.

Those permitted to intervene become parties to the proceeding, subject to any limitations in the order granting leave to intervene, and have the opportunity to participate fully in the conduct of the hearing.

If a hearing is requested, the Commission will make a final determination on the issue of no significant hazards consideration. The final determination will serve to decide when the hearing is held. If the final determination is that the amendment request involves no significant hazards consideration, the Commission may issue the amendment and make it immediately effective, notwithstanding the request for a hearing. Any hearing held would take place after issuance of the amendment. If the final determination is that the amendment request involves a significant hazards consideration, any hearing held would take place before the issuance of any amendment.

All documents filed in NRC adjudicatory proceedings, including a request for hearing, a petition for leave to intervene, any motion or other document filed in the proceeding prior to the submission of a request for hearing or petition to intervene, and documents filed by interested governmental entities participating under 10 CFR 2.315(c), must be filed in accordance with the NRC E-Filing rule (72 FR 49139, August 28, 2007). The E-Filing process requires participants to submit and serve all adjudicatory documents over the Internet, or in some cases to mail copies on electronic storage media. Participants may not submit paper copies of their filings unless they seek an exemption in accordance with the procedures described below.

To comply with the procedural requirements of E-Filing, at least ten (10) days prior to the filing deadline, the participant should contact the Office of the Secretary by email at [hearing.docket@nrc.gov](mailto:hearing.docket@nrc.gov), or by telephone at (301) 415-1677, to request (1) a digital ID certificate, which allows the participant (or its counsel or representative) to digitally sign documents and access the E-Submittal server for any proceeding in which it is participating; and (2) advise the Secretary that the participant will be submitting a request or petition for hearing (even in instances in which the participant, or its counsel or representative, already holds an NRC-issued digital ID certificate). Based upon this information, the Secretary will establish an electronic docket for the hearing in this proceeding if the Secretary has not already established an electronic docket.

Information about applying for a digital ID certificate is available on NRC's public Web site at <http://www.nrc.gov/site-help/e-submittals/apply-certificates.html>. System requirements for accessing the E-Submittal server are detailed in NRC's "Guidance for Electronic Submission," which is available on the agency's public Web site at <http://www.nrc.gov/site-help/e-submittals.html>. Participants may attempt to use other software not listed on the Web site, but should note that the NRC's E-Filing system does not support unlisted software, and the NRC Meta System Help Desk will not be able to offer assistance in using unlisted software.

If a participant is electronically submitting a document to the NRC in accordance with the E-Filing rule, the participant must file the document using the NRC's online, Web-based submission form. In order to serve documents through EIE, users will be required to install a Web browser plug-in from the NRC Web site. Further information on the Web-based submission form, including the installation of the Web browser plug-in, is available on the NRC's public Web site at <http://www.nrc.gov/site-help/e-submittals.html>.

Once a participant has obtained a digital ID certificate and a docket has been created, the participant can then submit a request for hearing or petition for leave to intervene. Submissions should be in Portable Document Format (PDF) in accordance with NRC guidance available on the NRC public Web site at <http://www.nrc.gov/site-help/e-submittals.html>. A filing is considered complete at the time the documents are submitted through the NRC's E-Filing

system. To be timely, an electronic filing must be submitted to the E-Filing system no later than 11:59 p.m. Eastern Time on the due date. Upon receipt of a transmission, the E-Filing system time-stamps the document and sends the submitter an email notice confirming receipt of the document. The E-Filing system also distributes an email notice that provides access to the document to the NRC Office of the General Counsel and any others who have advised the Office of the Secretary that they wish to participate in the proceeding, so that the filer need not serve the documents on those participants separately. Therefore, applicants and other participants (or their counsel or representative) must apply for and receive a digital ID certificate before a hearing request/petition to intervene is filed so that they can obtain access to the document via the E-Filing system.

A person filing electronically using the agency's adjudicatory E-Filing system may seek assistance by contacting the NRC Meta System Help Desk through the "Contact Us" link located on the NRC Web site at <http://www.nrc.gov/site-help/e-submittals.html>, by email at [MSHD.Resource@nrc.gov](mailto:MSHD.Resource@nrc.gov), or by a toll-free call at (866) 672-7640. The NRC Meta System Help Desk is available between 8 a.m. and 8 p.m., Eastern Time, Monday through Friday, excluding government holidays.

Participants who believe that they have a good cause for not submitting documents electronically must file an exemption request, in accordance with 10 CFR 2.302(g), with their initial paper filing requesting authorization to continue to submit documents in paper format. Such filings must be submitted by: (1) First class mail addressed to the Office of the Secretary of the Commission, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, Attention: Rulemaking and Adjudications Staff; or (2) courier, express mail, or expedited delivery service to the Office of the Secretary, Sixteenth Floor, One White Flint North, 11555 Rockville Pike, Rockville, Maryland, 20852, Attention: Rulemaking and Adjudications Staff. Participants filing a document in this manner are responsible for serving the document on all other participants. Filing is considered complete by first-class mail as of the time of deposit in the mail, or by courier, express mail, or expedited delivery service upon depositing the document with the provider of the service. A presiding officer, having granted an exemption request from using E-Filing, may require

a participant or party to use E-Filing if the presiding officer subsequently determines that the reason for granting the exemption from use of E-Filing no longer exists.

Documents submitted in adjudicatory proceedings will appear in NRC's electronic hearing docket which is available to the public at <http://ehd1.nrc.gov/EHD/>, unless excluded pursuant to an order of the Commission, or the presiding officer. Participants are requested not to include personal privacy information, such as social security numbers, home addresses, or home phone numbers in their filings, unless an NRC regulation or other law requires submission of such information. With respect to copyrighted works, except for limited excerpts that serve the purpose of the adjudicatory filings and would constitute a Fair Use application, participants are requested not to include copyrighted materials in their submission.

Petitions for leave to intervene must be filed no later than 60 days from the date of publication of this notice. Non-timely filings will not be entertained absent a determination by the presiding officer that the petition or request should be granted or the contentions should be admitted, based on a balancing of the factors specified in 10 CFR 2.309(c)(1)(i)-(viii).

For further details with respect to this license amendment application, see the application for amendment dated December 10, 2010, as supplemented by letters dated June 16, 2011, and October 27, 2011, which is available for public inspection at the Commission's PDR, located at One White Flint North, File Public Area O1 F21, 11555 Rockville Pike (first floor), Rockville, Maryland. Publicly available documents created or received at the NRC are accessible electronically through ADAMS in the NRC Library at <http://www.nrc.gov/reading-rm/adams.html>. Persons who do not have access to ADAMS or who encounter problems in accessing the documents located in ADAMS, should contact the NRC PDR Reference staff by telephone at 1-800-397-4209, (301) 415-4737, or by email to [pdr.resource@nrc.gov](mailto:pdr.resource@nrc.gov).

*Attorney for licensee:* John O'Neill, Esq., Pillsbury Winthrop Shaw Pittman LLP, 2300 N Street NW., Washington, DC 20037.

Dated at Rockville, Maryland, this 22nd day of November 2011.

For the Nuclear Regulatory Commission.

**Mohan C. Thadani,**

Senior Project Manager, Plant Licensing  
Branch IV, Division of Operating Reactor  
Licensing, Office of Nuclear Reactor  
Regulation.

[FR Doc. 2011-30728 Filed 11-28-11; 8:45 am]

**BILLING CODE 7590-01-P**

## NUCLEAR REGULATORY COMMISSION

[NRC-2011-0006]

### Sunshine Act Meeting

**AGENCY HOLDING THE MEETINGS:** Nuclear  
Regulatory Commission.

**DATES:** Weeks of November 28,  
December 5, 12, 19, 26, 2011, January 2,  
2012.

**PLACE:** Commissioners' Conference  
Room, 11555 Rockville Pike, Rockville,  
Maryland.

**STATUS:** Public and Closed.

### Week of November 28, 2011

*Tuesday, November 29, 2011*

9:25 a.m. Affirmation Session (Public  
Meeting) (Tentative)

a. U.S. Department of Energy (High-  
Level Waste Repository), Docket No. 63-  
001-HLW; Staff Petition for the  
Commission to Exercise its Inherent  
Supervisory Authority to Review Board  
Orders Regarding Preservation of  
Licensing Support Network (LSN)  
Documents Collection, and Staff  
Request for Stay (Tentative)

b. Final Rule: Requirements for  
Fingerprint-Based Criminal History  
Records Checks for Individuals Seeking  
Unescorted Access to Nonpower  
Reactors (Research or Test Reactors)  
(RIN 3150-A125) (Tentative)

This meeting will be webcast live at  
the Web address—<http://www.nrc.gov>.  
9:30 a.m. Meeting with the Advisory  
Committee on Reactor Safeguards  
(ACRS) (Public Meeting) (Contact:  
Tanny Santos, (301) 415-7270)

This meeting will be webcast live at  
the Web address—<http://www.nrc.gov>.

*Thursday, December 1, 2011*

9:30 a.m. Briefing on Equal  
Employment Opportunity (EEO) and  
Small Business Programs (Public  
Meeting) (Contact: Barbara Williams,  
(301) 415-7388)

This meeting will be webcast live at  
the Web address—<http://www.nrc.gov>.

### Week of December 5, 2011—Tentative

There are no meetings scheduled for  
the week of December 5, 2011.

### Week of December 12, 2011—Tentative

*Tuesday, December 13, 2011*

9 a.m. Briefing on NFPA 805 Fire  
Protection (Public Meeting)(Contact:  
Alex Klein, (301) 415-2822)

This meeting will be webcast live at  
the Web address—<http://www.nrc.gov>.

### Week of December 19, 2011—Tentative

There are no meetings scheduled for  
the week of December 19, 2011.

### Week of December 26, 2011—Tentative

There are no meetings scheduled for  
the week of December 26, 2011.

### Week of January 2, 2012—Tentative

There are no meetings scheduled for  
the week of January 2, 2012.

\* \* \* \* \*

\* The schedule for Commission  
meetings is subject to change on short  
notice. To verify the status of meetings,  
call (recording)—(301) 415-1292.  
Contact person for more information:  
Rochelle Bavol, (301) 415-1651.

\* \* \* \* \*

The NRC Commission Meeting  
Schedule can be found on the Internet  
at: [http://www.nrc.gov/public-involve/  
public-meetings/schedule.html](http://www.nrc.gov/public-involve/public-meetings/schedule.html).

\* \* \* \* \*

The NRC provides reasonable  
accommodation to individuals with  
disabilities where appropriate. If you  
need a reasonable accommodation to  
participate in these public meetings, or  
need this meeting notice or the  
transcript or other information from the  
public meetings in another format (e.g.  
braille, large print), please notify Bill  
Dosch, Chief, Work Life and Benefits  
Branch, at (301) 415-6200, TDD: (301)  
415-2100, or by email at  
[william.dosch@nrc.gov](mailto:william.dosch@nrc.gov). Determinations  
on requests for reasonable  
accommodation will be made on a case-  
by-case basis.

\* \* \* \* \*

This notice is distributed  
electronically to subscribers. If you no  
longer wish to receive it, or would like  
to be added to the distribution, please  
contact the Office of the Secretary,  
Washington, DC 20555 (301) 415-1969),  
or send an email to  
[darlene.wright@nrc.gov](mailto:darlene.wright@nrc.gov).

Dated: November 23, 2011.

**Rochelle C. Bavol,**

Policy Coordinator, Office of the Secretary.

[FR Doc. 2011-30839 Filed 11-25-11; 4:15 pm]

**BILLING CODE 7590-01-P**

## NUCLEAR REGULATORY COMMISSION

[NRC-2011-0277]

### Notice of Opportunity for Public Comment on the Proposed Model Safety Evaluation for Plant-Specific Adoption of Technical Specifications Task Force Traveler TSTF-505, Revision 1, "Provide Risk-Informed Extended Completion Times—RITSTF Initiative 4B"

**AGENCY:** Nuclear Regulatory  
Commission.

**ACTION:** Notice of opportunity for public  
comment.

**SUMMARY:** The U.S. Nuclear Regulatory  
Commission (NRC) is requesting public  
comment on the proposed model safety  
evaluation (SE) for plant-specific  
adoption of Technical Specifications  
(TS) Task Force (TSTF) Traveler TSTF-  
505, Revision 1, "Provide Risk-Informed  
Extended Completion Times—RITSTF  
Initiative 4B." TSTF-505, Revision 1, is  
available in the Agencywide Documents  
Access and Management System  
(ADAMS) under Accession Number  
ML111650552; the model application is  
available in ADAMS under Accession  
Number ML112850506. The proposed  
model SE for plant-specific adoption of  
TSTF-505, Revision 1, is available  
electronically under ADAMS Accession  
Number ML112690239.

The proposed amendment would  
modify the TS requirements related to  
Completion Times (CTs) for Required  
Actions to provide the option to  
calculate a longer, risk-informed CT. A  
new program, the Risk-Informed  
Completion Time (RICT) Program, is  
added to TS Section 5, Administrative  
Controls. The proposed change revises  
the Improved Standard Technical  
Specification (ISTS), NUREGs-1430,  
-1431, -1432, -1433, and -1434.

**DATES:** The comment period expires on  
December 30, 2011. Comments received  
after this date will be considered, if it  
is practical to do so, but the NRC is able  
to ensure consideration only for  
comments received on or before this  
date.

**ADDRESSES:** You may submit comments  
by any one of the following methods.  
Please include Docket ID NRC-2011-  
0277 in the subject line of your  
comments. Comments submitted in  
writing or in electronic form will be  
posted on the NRC Web site and on the  
Federal rulemaking Web site [http://  
www.regulations.gov](http://www.regulations.gov). Because your  
comments will not be edited to remove  
any identifying or contact information,  
the NRC cautions you against including