

Amendment Nos.: 301 and 278.

Renewed Facility Operating License Nos. DPR-53 and DPR-69: Amendments revised the License and Technical Specifications.

Date of initial notice in Federal Register: October 14, 2011 (76 FR 64390).

The Commission's related evaluation of these amendments is contained in a Safety Evaluation dated January 11, 2012.

No significant hazards consideration comments received: No.

Carolina Power and Light Company, Docket No. 50-261, H. B. Robinson Steam Electric Plant, Unit 2, Darlington County, South Carolina

Date of application for amendment: October 20, 2010.

Brief description of amendment: The amendment revises the H. B. Robinson, Unit 2, Technical Specification (TS) 4.2.1, "Fuel Assemblies," to permit the use of AREVA's M5 advanced alloy for fuel rod cladding and fuel assembly structural components in future operating cycles. Currently, as stated in TS 4.2.1, the H. B. Robinson fuel cladding is zircaloy-4. Therefore, an amendment request is needed in order to use M5 fuel cladding. The proposed amendment also revises the H. B. Robinson Unit 2 TS 5.6.5.b, "Core Operating Limits Report (COLR)," to permit referencing of analytical methodologies for M5 material and the deletion of existing analytical methodologies that are no longer planned to be used by the licensee.

Date of issuance: December 29, 2011.

Effective date: 60 days from date of issuance.

Amendment No.: 227.

Renewed Facility Operating License No. DPR-23. Amendment revises the Technical Specifications.

Date of initial notice in Federal Register: April 19, 2011 (76 FR 21921).

The Commission's related evaluation of the amendment is contained in a safety evaluation dated December 29, 2011.

No significant hazards consideration comments received: No.

Southern Nuclear Operating Company, Inc., Georgia Power Company, Oglethorpe Power Corporation, Municipal Electric Authority of Georgia, City of Dalton, Georgia, Docket Nos. 50-321 and 50-366, Edwin I. Hatch Nuclear Plant, Units 1 and 2, Appling County, Georgia

Date of application for amendments: October 29, 2010, as supplemented by letters dated February 21, May 27, and October 13, 2011.

Brief description of amendments: The amendments revised the Technical Specifications by relocating the specific surveillance frequencies to a licensee-controlled program using risk-informed justification (Technical Specification Task Force—425).

Date of issuance: January 3, 2012.

Effective date: As of the date of issuance and shall be implemented within 120 days from the date of issuance.

Amendment Nos.: Unit 1-266 and Unit 2-210.

Renewed Facility Operating License Nos. DPR-57 and NPF-5: Amendments revised the licenses and the technical specifications.

Date of initial notice in Federal Register: December 14, 2010 (75 FR 77916).

The supplements dated February 21, May 27, and October 13, 2011, provided additional information that clarified the application, did not expand the scope of the application as originally noticed, and did not change the staff's original proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated January 3, 2012.

No significant hazards consideration comments received: No.

Tennessee Valley Authority, Docket No. 50-390, Watts Bar Nuclear Plant (WBN), Unit 1, Rhea County, Tennessee

Date of application for amendment: October 5, 2011.

Brief description of amendment: The amendment revised the facility operating license to remove License Condition 2.G. This license condition described reporting requirements of other requirements in Section 2.C of the facility operating license. The change is consistent with the Nuclear Regulatory Commission approved change notice published in the **Federal Register** on November 4, 2005 (70 FR 67202), announcing the availability of this improvement through the consolidated line item improvement process.

Date of issuance: January 6, 2012.

Effective date: As of the date of issuance and shall be implemented no later than 32 days from date of issuance.

Amendment No.: 90.

Facility Operating License No. NPF-90: Amendment revised the License.

Date of initial notice in Federal Register: November 1, 2011 (76 FR 67490).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated January 6, 2012.

No significant hazards consideration comments received: No.

Union Electric Company, Docket No. 50-483, Callaway Plant, Unit 1, Callaway County, Missouri

Date of application for amendment: December 10, 2010, as supplemented by letters dated June 16, October 27, and December 13, 2011.

Brief description of amendment: The amendment added new Surveillance Requirement (SR) 3.3.8.6 to Technical Specification (TS) 3.3.8, "Emergency Exhaust System (EES) Actuation Instrumentation." The new SR requires the performance of response time testing on the portion of the EES required to isolate the normal fuel building ventilation exhaust flow path and initiate the fuel building ventilation isolation signal mode of operation. The amendment also revised TS Table 3.3.8-1, "EES Actuation Instrumentation," to indicate that new SR 3.3.8.6 applies to automatic actuation Function 2, Automatic Actuation Logic and Actuation Relays (BOP ESFAS), and Function 3, Fuel Building Exhaust

Radiation—Gaseous. In addition, the specified frequency of new SR 3.3.8.6 was relocated and controlled in accordance with the licensee's Surveillance Frequency Control Program.

Date of issuance: December 30, 2011.

Effective date: As of its date of issuance and shall be implemented within 90 days from the date of issuance.

Amendment No.: 204.

Facility Operating License No. NPF-30: The amendment revised the Operating License and Technical Specifications.

Date of initial notice in Federal Register: March 8, 2011 (76 FR 12766); revised and republished on November 29, 2011 (76 FR 73733). The supplemental letter dated June 16, 2011, provided additional information that clarified the application, did not expand the scope of the application as originally noticed, and did not change the staff's original proposed no significant hazards consideration (NSHC) determination.

The supplemental letter dated October 27, 2011, added a new request for approval to relocate the surveillance frequency of new SR 3.3.8.6 to the licensee's Surveillance Frequency Control Program. The proposed NSHC determination for this additional change was not evaluated in the initial notice (76 FR 12766; March 8, 2011); therefore, on November 29, 2011, the NRC staff revised and republished the notice of proposed NSHC incorporating the new change (76 FR 73733). The republished notice also provided an opportunity to request a hearing by January 30, 2012, but indicated that if the Commission makes a final NSHC determination, any such hearing would take place after issuance of the amendment.

The supplemental letter dated December 13, 2011, provided additional information that clarified the application, as supplemented, did not expand the scope of the application, as supplemented, and did not change the staff's revised proposed NSHC determination, as published in the **Federal Register** on November 29, 2011 (76 FR 73733).

The Commission's related evaluation of the amendment and final NSHC determination are contained in a Safety Evaluation dated December 30, 2011.

No significant hazards consideration comments received: No.

Dated at Rockville, Maryland, this 12th day of January 2012.

For the Nuclear Regulatory Commission.

Michele G. Evans,

Director, Division of Operating Reactor Licensing, Office of Nuclear Reactor Regulation.

[FR Doc. 2012-1215 Filed 1-23-12; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

[NRC-2012-0002]

Sunshine Federal Register Notice

AGENCY HOLDING THE MEETINGS: Nuclear Regulatory Commission.

DATE: Weeks of January 23, 30, February 6, 13, 20, 27, 2012.

PLACE: Commissioners' Conference Room, 11555 Rockville Pike, Rockville, Maryland.

STATUS: Public and Closed.

Week of January 23, 2012

There are no meetings scheduled for the week of January 23, 2012.

Week of January 30, 2012—Tentative

There are no meetings scheduled for the week of January 30, 2012.

Week of February 6, 2012—Tentative

Thursday, February 9, 2012

9 a.m. Briefing on Status of Outreach and Educational Efforts with External Stakeholders Related to the Safety Culture Policy Statement (Public Meeting). (Contact: Diane Sieracki, (301) 415-3297.)

This meeting will be webcast live at the Web address—www.nrc.gov.

Week of February 13, 2012—Tentative

There are no meetings scheduled for the week of February 13, 2012.

Week of February 20, 2012—Tentative

Wednesday, February 22, 2012

9 a.m. Briefing on Fort Calhoun (Public Meeting). (Contact: Jeff Clark, (817) 860-8147.)

This meeting will be webcast live at the Web address—www.nrc.gov.

Week of February 27, 2012—Tentative

Tuesday, February 28, 2012

9:30 a.m. Briefing on the Threat Environment Assessment (Closed—Ex. 1).

* The schedule for Commission meetings is subject to change on short notice. To verify the status of meetings, call (recording)—(301) 415-1292. Contact person for more information: Rochelle Baval, (301) 415-1651.

The NRC Commission Meeting Schedule can be found on the Internet at: <http://www.nrc.gov/public-involve/public-meetings/schedule.html>.

The NRC provides reasonable accommodation to individuals with disabilities where appropriate. If you need a reasonable accommodation to participate in these public meetings, or need this meeting notice or the transcript or other information from the public meetings in another format (e.g., braille, large print), please notify Bill Dosch, Chief, Work Life and Benefits Branch, at (301) 415-6200, TDD: (301) 415-2100, or by email at william.dosch@nrc.gov. Determinations on requests for reasonable

accommodation will be made on a case-by-case basis.

This notice is distributed electronically to subscribers. If you no longer wish to receive it, or would like to be added to the distribution, please contact the Office of the Secretary, Washington, DC 20555, (301) 415-1969, or send an email to darlene.wright@nrc.gov.

Dated: January 19, 2012.

Rochelle C. Baval,

Policy Coordinator, Office of the Secretary.

[FR Doc. 2012-1526 Filed 1-20-12; 4:15 pm]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

[NRC-2009-0481]

Protection Against Turbine Missiles

AGENCY: Nuclear Regulatory Commission.

ACTION: Regulatory guide; issuance.

SUMMARY: The U.S. Nuclear Regulatory Commission (NRC or Commission) is issuing a revision to Regulatory Guide 1.115, "Protection Against Turbine Missiles." This guide describes methods acceptable to the NRC staff for protecting safety-related structures, systems, and components against missiles resulting from turbine failure by the appropriate orientation and placement of the turbine-generator set, the management of the probability of turbine missile generation, and the use of missile barriers.

ADDRESSES: You can access publicly available documents related to this regulatory guide using the following methods:

- *NRC's Public Document Room (PDR):* The public may examine and have copied, for a fee, publicly available documents at the NRC's PDR, O1-F21, One White Flint North, 11555 Rockville Pike, Rockville, Maryland 20852.

- *NRC's Agencywide Documents Access and Management System (ADAMS):* Publicly available documents created or received at the NRC are available online in the NRC Library at <http://www.nrc.gov/reading-rm/adams.html>. From this page, the public can gain entry into ADAMS, which provides text and image files of the NRC's public documents. If you do not have access to ADAMS or if there are problems in accessing the documents located in ADAMS, contact the NRC's PDR reference staff at 1-(800) 397-4209, (301) 415-4737, or by email to pdr.resource@nrc.gov. The regulatory guide is available electronically under

ADAMS Accession Number ML101650675. The regulatory analysis may be found in ADAMS under Accession Number ML101670039.

- *Federal Rulemaking Web Site:* Public comments and supporting materials related to this notice can be found at <http://www.regulations.gov> by searching on Docket ID NRC-2009-0481.

Regulatory guides are not copyrighted, and NRC approval is not required to reproduce them.

FOR FURTHER INFORMATION CONTACT: R.A. Jervey, Regulatory Guide Development Branch, Division of Engineering, Office of Nuclear Regulatory Research, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, telephone: (301) 251-7404 or email: Richard.Jervej@nrc.gov.

SUPPLEMENTARY INFORMATION: The NRC is issuing a revision to an existing guide in the agency's "Regulatory Guide" series. This series was developed to describe and make available to the public information such as methods that are acceptable to the NRC staff for implementing specific parts of the agency's regulations, techniques that the staff uses in evaluating specific problems or postulated accidents, and data that the staff needs in its review of applications for permits and licenses.

Revision 2 of Regulatory Guide 1.115, "Protection Against Turbine Missiles," was issued with a temporary identification as Draft Regulatory Guide, DG-1217. DG-1217 was published in the **Federal Register** on November 2, 2009 (74 FR 56672) for a 60 day public comment period. DG-1217 was reissued for public comment on May 6, 2011 (76 FR 26320). The public comment period closed on June 3, 2011. The staff's responses to the public comments received are located in the NRC's Agencywide Documents Access and Management System (ADAMS) under the following Accession Numbers ML112090989 and ML101660585.

Dated at Rockville, Maryland, this 13th day of January 2011.

For the Nuclear Regulatory Commission.

Edward O'Donnell,

Acting Chief, Regulatory Guide Development Branch, Division of Engineering, Office of Nuclear Regulatory Research.

[FR Doc. 2012-1335 Filed 1-23-12; 8:45 am]

BILLING CODE 7590-01-P