

Site Building 235-F Safety, issued on May 9, 2012, and I accept the Recommendation.

DOE agrees with the Board that action must be taken to reduce the hazards associated with the material at risk that remains as residual contamination within Building 235-F.

The Board acknowledged in its letter that DOE has taken action to de-inventory Building 235-F of special nuclear material. DOE has also taken action to remove the transient combustible material within Building 235-F and to limit access. In developing an Implementation Plan (IP), DOE will address all sub-recommendations with the ultimate goal of reducing, to the extent feasible, the radiological hazards from residual contamination and the fire hazards due to excessive combustible materials and electrical ignition sources. Operability and safety basis related concerns on fire detection and alarm systems will be addressed in the IP. Emergency response posture predicated on a potential radiological release from Building 235-F will also be evaluated to ensure its adequacy, including improvements in conducting drills necessary to demonstrate the overall effectiveness.

DOE is committed to the safe design and operation of its nuclear facilities consistent with the principles of Integrated Safety Management, and values the Board's input on how DOE can improve its activities. We look forward to working with the Board as we work to reduce the hazards posed by Building 235-F.

I have assigned Dr. David C. Moody, Manager, Savannah River Operations Office, to be the Department's responsible manager for this Recommendation. He can be reached at (803) 952-9468.

Sincerely,

Steven Chu

[FR Doc. 2012-18176 Filed 7-24-12; 8:45 am]

BILLING CODE 6450-01-P

DEPARTMENT OF ENERGY

Federal Energy Regulatory Commission

[Project No. 13011-003]

Shelbyville Hydro LLC; Notice of Application Ready for Environmental Analysis and Soliciting Comments, Recommendations, Terms and Conditions, and Prescriptions

Take notice that the following hydroelectric application has been filed with the Commission and is available for public inspection.

- a. *Type of Application:* Major License.
- b. *Project No.:* 13011-003.
- c. *Date filed:* October 28, 2011.
- d. *Applicant:* Shelbyville Hydro LLC (Shelbyville Hydro), a wholly-owned subsidiary of Symbiotics LLC.
- e. *Name of Project:* Lake Shelbyville Dam Hydroelectric Project.
- f. *Location:* On the Kaskaskia River, in Shelby County, Illinois at an existing

dam owned and operated by the U.S. Corps of Engineers (Corps). The project would occupy 3.24 acres of federal lands managed by the Corps.

g. *Filed Pursuant to:* Federal Power Act 16 U.S.C. 791(a)-825(r).

h. *Applicant Contact:* Mr. Brent L. Smith, Chief Operating Officer, Symbiotics LLC 371 Upper Terrace, Suite 2, Bend, OR 97702; Telephone (541)-330-8779.

i. *FERC Contact:* Lesley Kordella, (202) 502-6406 or Lesley.Kordella@ferc.gov.

j. *Deadline for filing comments, terms and conditions, recommendations, and prescriptions:* 60 days from the issuance date of this notice; reply comments are due 105 days from the issuance date of this notice.

All documents may be filed electronically via the Internet. See 18 CFR 385.2001(a)(1)(iii) and the instructions on the Commission's Web site <http://www.ferc.gov/docs-filing/efiling.asp>. Commenters can submit brief comments up to 6,000 characters, without prior registration, using the eComment system at <http://www.ferc.gov/docs-filing/ecomment.asp>. You must include your name and contact information at the end of your comments. For assistance, please contact FERC Online Support at FERCOnlineSupport@ferc.gov or toll free at 1-866-208-3676, or for TTY, (202) 502-8659. Although the Commission strongly encourages electronic filing, documents may also be paper-filed. To paper-file, mail an original and seven copies to: Kimberly D. Bose, Secretary, Federal Energy Regulatory Commission, 888 First Street NE., Washington, DC 20426.

The Commission's Rules of Practice and Procedures require all intervenors filing documents with the Commission to serve a copy of that document on each person on the official service list for the project. Further, if an intervenor files comments or documents with the Commission relating to the merits of an issue that may affect the responsibilities of a particular resource agency, they must also serve a copy of the document on that resource agency.

k. This application has been accepted for filing and is ready for environmental analysis.

l. *Project Description:* The project would be located at an existing dam owned and operated by the Corps (St. Louis District). The existing Lake Shelbyville Dam was constructed in 1963 for the purposes of flood control, recreation development, water supply, navigation release, and fish and wildlife conservation. In August of 1970, the Corps closed the gates to start the initial

filling of the lake. The West Okaw and Kaskaskia rivers were inundated for 17 miles upstream of the dam.

The Lake Shelbyville Dam is an earthen embankment with an elevation of 643 feet above mean sea level (MSL). The dam is 3,025 feet long and rises 108 feet above the river bed. The concrete spillway is located at 593 feet MSL and is topped by three Tainter gates that are approximately 45 feet wide by 37 feet high. The two regulating outlet structures release water through the face of the spillway. The impoundment above the Lake Shelbyville Dam, referred to as Lake Shelbyville, varies according to flood control operations controlled by the Corps. Lake Shelbyville has a maximum storage capacity of 684,000 acre-feet. Of the 684,000 acre-feet of storage, 474,000 acre-feet have been designated for flood control. The average depth of the reservoir is 16 feet and the maximum is 67 feet.

The proposed Lake Shelbyville Project would consist of: (1) A trash rack with 4-inch spacing integrated into the Corps' existing west intake structure; (2) a steel liner installed in the Corps' existing west outlet chamber transitioning to a bifurcation; (3) a 13-foot-diameter bifurcation and a river release valve installed at the west outlet structure; (4) a 13-foot-diameter penstock at the bifurcation after which it reduces to a 12-foot-diameter, 575-foot-long steel penstock; (5) a 60-foot-long, 50-foot-wide, 68-foot-high concrete powerhouse containing a 6.8-megawatt Kaplan turbine-generator with a flow of 130 to 1,500 cubic feet per second (cfs) at a net head of 33 to 77 feet; (6) an approximately 24.5-foot-wide, 30-foot-long, 6.7-foot-tall draft tube; (7) a 25 to 105-foot-wide, 49-foot-long tailrace; (8) a 12.47-kilovolt, 407-foot-long buried transmission line connecting the project to an existing Shelby Electric Cooperative substation located 900 feet downstream of the dam; and (9) appurtenant facilities. The project boundary would include 3.24 acres of federal lands owned by the Corps. The annual average energy production is estimated to be 20.3 gigawatt-hours.

The project would operate in a run-of-release mode utilizing releases from Lake Shelbyville as they are dictated by the Corps, with no proposed change to the Corps' facility operation. Power generation would be seasonally variable as flow regimens and pool levels are set forth by the Corps. The project would generate power using flows between 130 and 1,500 cfs. When flows are below 130 cfs, all flows would be passed through the Corps' existing outlet

structure and the project would then be offline. When flows are greater than 1,500 cfs, excess flow would be passed through the existing outlet structure.

m. A copy of the application is available for review at the Commission in the Public Reference Room or may be viewed on the Commission's Web site at <http://www.ferc.gov> using the "eLibrary" link. Enter the docket number excluding the last three digits in the docket number field to access the document. For assistance, contact FERC Online Support. A copy is also available for inspection and reproduction at the address in item h above.

All filings must (1) bear in all capital letters the title "COMMENTS", "REPLY COMMENTS", "RECOMMENDATIONS," "TERMS AND CONDITIONS," or "PRESCRIPTIONS;" (2) set forth in the heading the name of the applicant and the project number of the application to which the filing responds; (3) furnish the name, address, and telephone number of the person submitting the filing; and (4) otherwise comply with the requirements of 18 CFR 385.2001 through 385.2005. All comments, recommendations, terms and conditions or prescriptions must set forth their evidentiary basis and otherwise comply with the requirements of 18 CFR 4.34(b). Agencies may obtain copies of the application directly from the applicant. Each filing must be accompanied by proof of service on all persons listed on the service list prepared by the Commission in this proceeding, in accordance with 18 CFR 4.34(b), and 385.2010.

You may also register online at <http://www.ferc.gov/docs-filing/esubscription.asp> to be notified via email of new filings and issuances related to this or other pending projects. For assistance, contact FERC Online Support.

n. Public notice of the filing of the initial development application, which has already been given, established the due date for filing competing applications or notices of intent. Under the Commission's regulations, any competing development application must be filed in response to and in compliance with public notice of the initial development application. No competing applications or notices of intent may be filed in response to this notice.

o. A license applicant must file no later than 60 days following the date of issuance of this notice: (1) A copy of the water quality certification; (2) a copy of the request for certification, including proof of the date on which the certifying agency received the request; or (3)

evidence of waiver of water quality certification.

Dated: July 18, 2012.

Kimberly D. Bose,

Secretary.

[FR Doc. 2012-18103 Filed 7-24-12; 8:45 am]

BILLING CODE 6717-01-P

DEPARTMENT OF ENERGY

Federal Energy Regulatory Commission

Combined Notice of Filings #1

Take notice that the Commission received the following exempt wholesale generator filings:

Docket Numbers: EG12-89-000.

Applicants: Mehoopany Wind Energy LLC.

Description: Notice of Self-Certification of Exempt Wholesale Generator Status of Mehoopany Wind Energy LLC.

Filed Date: 7/17/12.

Accession Number: 20120717-5064.

Comments Due: 5 p.m. ET 8/7/12.

Take notice that the Commission received the following electric securities filings:

Docket Numbers: ES12-47-000.

Applicants: ISO New England Inc.

Description: Application of ISO New England Inc. under Section 204 of the Federal Power Act for an Order Authorizing the Issuance of Securities.

Filed Date: 7/17/12.

Accession Number: 20120717-5094.

Comments Due: 5 p.m. ET 8/7/12.

Docket Numbers: ES12-48-000.

Applicants: ISO New England Inc.

Description: Application of ISO New England Inc. under Section 204 of the FPA For An Order Authorizing the Issuance of Securities.

Filed Date: 7/17/12.

Accession Number: 20120717-5095.

Comments Due: 5 p.m. ET 8/7/12.

Take notice that the Commission received the following qualifying facility filings:

Docket Numbers: QF12-447-000.

Applicants: LAFOURCHE SUGARS, LLC.

Description: Form 556—Notice of Self-Certification for Qualifying Cogeneration Facility Status of LAFOURCHE SUGARS, LLC.

Filed Date: 7/17/12.

Accession Number: 20120717-5137.

Comments Due: None Applicable.

The filings are accessible in the Commission's eLibrary system by clicking on the links or querying the docket number.

Any person desiring to intervene or protest in any of the above proceedings

must file in accordance with Rules 211 and 214 of the Commission's Regulations (18 CFR 385.211 and 385.214) on or before 5:00 p.m. Eastern time on the specified comment date. Protests may be considered, but intervention is necessary to become a party to the proceeding.

eFiling is encouraged. More detailed information relating to filing requirements, interventions, protests, service, and qualifying facilities filings can be found at: <http://www.ferc.gov/docs-filing/efiling/filing-req.pdf>. For other information, call (866) 208-3676 (toll free). For TTY, call (202) 502-8659.

Dated: July 18, 2012.

Nathaniel J. Davis, Sr.,

Deputy Secretary.

[FR Doc. 2012-18116 Filed 7-24-12; 8:45 am]

BILLING CODE 6717-01-P

DEPARTMENT OF ENERGY

Federal Energy Regulatory Commission

[Docket No. EL12-85-000]

Notice of Complaint; Keryn Newman v. Potomac-Appalachian Transmission Highline, LLC

Take notice that on July 18, 2012 pursuant to Rules 206 and 218 of the Federal Energy Regulatory Commission's (Commission) Rules of Practice and Procedure, 18 CFR 385.206 and 385.218 and section 206 of the Federal Power Act, 16 U.S.C. 824(e) and 825(e), Keryn Newman (Complainant) filed a formal complaint against Potomac-Appalachian Transmission Highline, LLC (Respondent) alleging that Respondent violated its Formula Rate Implementation Protocols by refusing to provide information properly requested by an Interested Party in accordance with Section VI of the Protocols.

Any person desiring to intervene or to protest this filing must file in accordance with Rules 211 and 214 of the Commission's Rules of Practice and Procedure (18 CFR 385.211, 385.214). Protests will be considered by the Commission in determining the appropriate action to be taken, but will not serve to make protestants parties to the proceeding. Any person wishing to become a party must file a notice of intervention or motion to intervene, as appropriate. The Respondent's answer and all interventions or protests must be filed on or before the comment date. The Respondent's answer, motions to intervene, and protests must be served on the Complainants.