

individual(s) listed in the **FOR FURTHER INFORMATION CONTACT** section of this document.

- NRC's Agencywide Documents Access and Management System (ADAMS): You may access publicly available documents online in the NRC Library at <http://www.nrc.gov/reading-rm/adams.html>. To begin the search, select "ADAMS Public Documents" and then select "Begin Web-based ADAMS Search." For problems with ADAMS, please contact the NRC's Public Document Room (PDR) reference staff at 1-800-397-4209, 301-415-4737, or by email to [pdr.resource@nrc.gov](mailto:pdr.resource@nrc.gov). The ADAMS accession number for each document referenced in this document (if that document is available in ADAMS) is provided the first time that a document is referenced. The NRC published Revision 2 of the SRP-LR and the GALL Report in December 2010, and they are available in ADAMS under Accession Nos. ML103490041 and ML103490036, respectively.

- NRC's PDR: You may examine and purchase copies of public documents at the NRC's PDR, Room O1-F21, One White Flint North, 11555 Rockville Pike, Rockville, Maryland 20852.

- NRC's Interim Staff Guidance Web site: LR-ISG documents are also available online under the "License Renewal" heading at <http://www.nrc.gov/reading-rm/doc-collections/isg/>.

**FOR FURTHER INFORMATION CONTACT:** Mr. William Holston, Division of License Renewal, Office of Nuclear Reactor Regulation, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001; telephone: 301-415-8573; email: [William.Holston@nrc.gov](mailto:William.Holston@nrc.gov).

#### SUPPLEMENTARY INFORMATION:

##### Background

The NRC issues LR-ISGs to communicate insights and lessons learned and to address emergent issues not covered in license renewal guidance documents, such as the GALL Report and SRP-LR. In this way, the NRC staff and stakeholders may use the guidance in an LR-ISG document before it is incorporated into a formal license renewal guidance document revision. The NRC staff issues LR-ISGs in accordance with the LR-ISG Process, Revision 2 (ADAMS Accession No. ML100920158), for which a notice of availability was published in the **Federal Register** on June 22, 2010 (75 FR 35510).

The NRC staff has developed LR-ISG-2012-02 to address: (a) Recurring internal corrosion, (b) a representative minimum sample size for periodic

inspections in the GALL Report AMP XI.M38, "Inspection of Internal Surfaces in Miscellaneous Piping and Ducting Components," (c) flow blockage of water-based fire protection system piping, (d) revisions to the scope and inspection recommendations of the GALL Report AMP XI.M29, "Aboveground Metallic Tanks," (e) corrosion under insulation, (f) external volumetric examination of internal piping surfaces of underground piping, (g) specific guidance for use of the pressurization option for inspecting elastomers in the GALL Report AMP XI.M38, and (h) key miscellaneous changes to the GALL Report and SRP-LR.

On April 12, 2013, (78 FR 21980) the NRC requested public comments on draft LR-ISG-2012-02 (ADAMS Accession No. ML12291A920). On May 23, 2013, the NRC conducted a public meeting to discuss draft LR-ISG-2012-02. A meeting summary was published on June 20, 2013 (ADAMS Accession No. ML13149A401).

The NRC received comments from the Nuclear Energy Institute by letter dated June 14, 2013 (ADAMS Accession No. ML13168A397). No other comments were submitted. The NRC considered these comments in developing the final LR-ISG. Detailed responses to the comments can be found in Appendix I of the final LR-ISG.

The final LR-ISG-2012-02 is approved for NRC staff and stakeholder use and will be incorporated into NRC's next formal license renewal guidance document revision.

##### Backfitting and Issue Finality

Issuance of this final LR-ISG does not constitute backfitting as defined in 10 CFR 50.109 (the Backfit Rule) and is not otherwise inconsistent with the issue finality provisions in 10 CFR part 52, "Licenses, Certifications, and Approvals for Nuclear Power Plants." As discussed in the "Backfitting Discussion" section of the final LR-ISG-2012-02, the LR-ISG is directed to holders of operating licenses or combined licenses who are currently in the license renewal process. The LR-ISG is not directed to holders of operating licenses or combined licenses until they apply for license renewal. The LR-ISG is also not directed to licensees who already hold renewed operating or combined licenses.

Dated at Rockville, Maryland, this 14th day of November, 2013.

For the Nuclear Regulatory Commission.

**Melanie A. Galloway,**

*Deputy Director, Division of License Renewal, Office of Nuclear Reactor Regulation.*

[FR Doc. 2013-28069 Filed 11-21-13; 8:45 am]

BILLING CODE 7590-01-P

## NUCLEAR REGULATORY COMMISSION

[Docket No. 40-09083; NRC-2009-0352]

### Issuance of Materials License for U.S. Army Installation Management Command

**AGENCY:** Nuclear Regulatory Commission.

**ACTION:** Notice of issuance of materials license.

**SUMMARY:** The U.S. Nuclear Regulatory Commission (NRC) has issued a license to the U.S. Army, Installation Management Command, for possession of depleted uranium (DU) from the Davy Crockett weapon spotting round at the U.S. Army's Schofield Barracks and Pohakuloa Training Area installations in Hawaii. The Army informed the NRC in November 2006 that it had discovered DU fragments at the Schofield Barracks. Following that discovery, the Army determined that the Davy Crockett system had been used at other Army installations. The Army has a significant amount of DU that, under the Atomic Energy Act and NRC regulations, it is required to have a radioactive materials license. The Army submitted a license application in November 2008 for the DU at the Hawaiian sites. In the future, the Army will request amendments to the license to address Davy Crockett DU at the other sites.

**ADDRESSES:** Please refer to Docket ID NRC-2009-0352 when contacting the NRC about the availability of information regarding this document. You may access publicly-available information related to this document using any of the following methods:

- *Federal Rulemaking Web site:* Go to <http://www.regulations.gov> and search for Docket ID NRC-2009-0352. Address questions about NRC dockets to Carol Gallagher; telephone: 301-287-3422; email: [Carol.Gallagher@nrc.gov](mailto:Carol.Gallagher@nrc.gov). For technical questions, contact the individual(s) listed in the **FOR FURTHER INFORMATION CONTACT** section of this document.

- *NRC's Agencywide Documents Access and Management System (ADAMS):* You may access publicly available documents online in the NRC Library at <http://www.nrc.gov/reading-rm/adams.html>. To begin the search, select "ADAMS Public Documents" and

then select “*Begin Web-based ADAMS Search.*” For problems with ADAMS, please contact the NRC’s Public Document Room (PDR) reference staff at 1–800–397–4209, 301–415–4737, or by email to [pdr.resource@nrc.gov](mailto:pdr.resource@nrc.gov). The ADAMS accession number for each document referenced in this document (if that document is available in ADAMS) is provided the first time that a document is referenced. In addition, for the convenience of the reader, the ADAMS accession numbers are provided in the section of this document entitled, **SUPPLEMENTARY INFORMATION.**

- *NRC’s PDR:* You may examine and purchase copies of public documents at the NRC’s PDR, Room O1–F21, One White Flint North, 11555 Rockville Pike, Rockville, Maryland 20852.

**FOR FURTHER INFORMATION CONTACT:** Dominick Orlando, Office of Federal and State Materials and Environmental Management Programs, U.S. Nuclear Regulatory Commission, Washington DC 20555–0001, telephone: 301–415–6749, email: [Dominick.Orlando@nrc.gov](mailto:Dominick.Orlando@nrc.gov).

**SUPPLEMENTARY INFORMATION:** The NRC has issued a license to the U.S. Army, Installation Management Command for possession of depleted uranium from the Davy Crockett weapon spotting round at the U.S. Army’s Schofield Barracks and Pohakuloa Training Area installations in Hawaii. Materials License SUC–1593 authorizes possession only of existing depleted uranium from the Davy Crockett weapon and does not allow the U.S. Army to use the depleted uranium for other purposes or add to the existing depleted uranium inventory on the installations. The Army will also be required to conduct its operations in accordance with the conditions listed in Materials License SUC–1593.

This notice also serves as the record of decision for the NRC’s decision to approve the U.S. Army, Installation Management Command’s license application for the Schofield Barracks and Pohakuloa Training Area and issue Materials License SUC–1593.

The NRC considers the entire publicly available record for a license application to constitute the agency’s record of decision. Documents related to the application carry NRC docket ID NRC–2009–0352. These documents for the U.S. Army, Installation Management Command license include the license application (ML090070095), the Safety Evaluation Report (SER) (ML13259A081), and the license (ML13259A062). Note that a complete listing of documents associated with the

NRC staff’s review of the Army’s license application is included in the SER.

The U.S. Army, Installation Management Command’s request for a materials license was previously noticed in the **Federal Register** on August 13, 2009 (74 FR 40855), with a notice of an opportunity to request a hearing. On October 26, 2009, NRC staff received both comments on the license application and a request for a hearing. On November 24, 2009, an Atomic Safety and Licensing and Board (ASLBP) was established to preside over the proceeding (74 FR 62830). On January 13, 2010, the ASLBP held oral arguments on standing and contention admissibility in Rockville, Maryland, with the petitioners participating by videoconference from the Hilo Campus of the University of Hawaii on the island of Hawaii. On February 24, 2010, the ASLB denied the request (ML100550704), and the ASLB’s decision was appealed by one of the individuals to the Commission (ML100640665). On August 12, 2010, the Commission affirmed the ALSB’s decision (ML102240165).

In accordance with 10 CFR 2.390 of the NRC’s “Rules of Practice and Procedure,” the details with respect to this action, including the SER and accompanying documentation and license, are available electronically at the NRC’s Electronic Reading Room at <http://www.nrc.gov/reading-rm/adams.html>. From this site, you can access ADAMS, which provides text and image files of the NRC’s public documents.

Dated at Rockville, Maryland, this 12th day of November, 2013.

For the Nuclear Regulatory Commission.

**Andrew Persinko,**

*Deputy Director, Decommissioning and Uranium Licensing Directorate, Division of Waste Management and Environmental Protection, Office of Federal and State Materials and Environmental Management Programs.*

[FR Doc. 2013–28058 Filed 11–21–13; 8:45 am]

**BILLING CODE 7590–01–P**

## **NUCLEAR REGULATORY COMMISSION**

### **Advisory Committee on Reactor Safeguards; Notice of Meeting**

In accordance with the purposes of Sections 29 and 182b of the Atomic Energy Act (42 U.S.C. 2039, 2232b), the Advisory Committee on Reactor Safeguards (ACRS) will hold a meeting on December 4–7, 2013, 11545 Rockville Pike, Rockville, Maryland.

**Wednesday, December 4, 2013,  
Conference Room T2–B1, 11545  
Rockville Pike, Rockville, Maryland**

*1:30 p.m.–1:35 p.m.: Opening Remarks by the ACRS Chairman* (Open)—The ACRS Chairman will make opening remarks regarding the conduct of the meeting.

*1:35 p.m.–3:30 p.m.: Japan Lessons Learned Tier 3 Issue: Expedited Transfer of Spent Fuel to Dry Cask Storage* (Open)—The Committee will hear presentations by and hold discussions with representatives of the NRC staff regarding the Japan Lessons Learned Tier 3 issue of expedited transfer of spent fuel to dry cask storage.

*3:45 p.m.–4:45 p.m.: Draft Report on the Biennial ACRS Review of the NRC Safety Research Program* (Open)—The Committee will continue its discussion of the draft report on the biennial ACRS review of the NRC Safety Research Program.

*4:45 p.m.–6:00 p.m.: Preparation of ACRS Reports* (Open)—The Committee will discuss proposed ACRS reports on matters discussed during this meeting.

**Thursday, December 5, 2013,  
Conference Room T–2B1, 11545  
Rockville Pike, Rockville, Maryland**

*8:30 a.m.–8:35 a.m.: Opening Remarks by the ACRS Chairman* (Open)—The ACRS Chairman will make opening remarks regarding the conduct of the meeting.

*8:35 a.m.–10:30 a.m.: Selected Chapters of the Safety Evaluation Report (SER) With Open Items Associated With the Calvert Cliffs, Unit 3, Combined License Application (COLA) Referencing the U.S. Evolutionary Power Reactor (EPR)* (Open/Closed)—The Committee will hear presentations by and hold discussions with representatives of the NRC staff and UniStar regarding portions of Chapters 2, 3, 9, 13, and 14 of the SER with Open Items for the Calvert Cliffs, Units 3, COLA referencing the U.S. EPR design. [**Note:** A portion of this meeting may be closed in order to discuss and protect information designated as proprietary, pursuant to 5 U.S.C. 552b(c)(4).]

*10:45 a.m.–12:45 p.m.: Topical Report and Selected Chapters of the Safety Evaluation Reports (SERs) With Open Items Associated with the US Advanced Pressurized Water Reactor (US–APWR) Design Certification and the Comanche Peak Combined License Application (COLA)* (Open/Closed)—The Committee will hear presentations by and hold discussions with representatives of the NRC staff, Mitsubishi Heavy Industries, and Luminant Generation Company