

Dated: November 25, 2015.

**Michel Smyth,**

*Departmental Clearance Officer.*

[FR Doc. 2015-30529 Filed 12-1-15; 8:45 am]

BILLING CODE 4510-04-P

## DEPARTMENT OF LABOR

### Occupational Safety and Health Administration

[Docket No. OSHA-2014-0022]

#### **Nucor Steel Connecticut Incorporated; Application for Permanent Variance and Interim Order; Grant of Interim Order; Request for Comments**

**AGENCY:** Occupational Safety and Health Administration (OSHA), Labor.

**ACTION:** Notice.

**SUMMARY:** In this notice, OSHA announces the application of Nucor Steel Connecticut Incorporated for a permanent variance and interim order from the provisions of OSHA standards that regulate the control of hazardous energy (lockout/tagout) and presents the Agency's preliminary finding to grant the permanent variance. OSHA invites the public to submit comments on the variance application to assist the Agency in determining whether to grant the applicant a permanent variance based on the conditions specified in this notice of the application.

**DATES:** Submit comments, information, documents in response to this notice, and requests for a hearing on or before January 4, 2016. The interim order described in this notice became effective on December 2, 2015, and shall remain in effect until December 2, 2016 or until it is modified or revoked, whichever occurs first.

**ADDRESSES:** Submit comments by any of the following methods:

1. *Electronically:* Submit comments and attachments electronically at <http://www.regulations.gov>, which is the Federal eRulemaking Portal. Follow the instructions online for making electronic submissions.

2. *Facsimile:* If submissions, including attachments, are not longer than 10 pages, commenters may fax them to the OSHA Docket Office at (202) 693-1648.

3. *Regular or express mail, hand delivery, or messenger (courier) service:* Submit comments, requests, and any attachments to the OSHA Docket Office, Docket No. OSHA-2014-0022, Technical Data Center, U.S. Department of Labor, 200 Constitution Avenue NW., Room N-2625, Washington, DC 20210; telephone: (202) 693-2350 (TTY

number: (877) 889-5627). Note that security procedures may result in significant delays in receiving comments and other written materials by regular mail. Contact the OSHA Docket Office for information about security procedures concerning delivery of materials by express mail, hand delivery, or messenger service. The hours of operation for the OSHA Docket Office are 8:15 a.m.-4:45 p.m., e.t.

4. *Instructions:* All submissions must include the Agency name and the OSHA docket number (OSHA-2014-0022). OSHA places comments and other materials, including any personal information, in the public docket without revision, and these materials will be available online at <http://www.regulations.gov>. Therefore, the Agency cautions commenters about submitting statements they do not want made available to the public, or submitting comments that contain personal information (either about themselves or others) such as Social Security numbers, birth dates, and medical data.

5. *Docket:* To read or download submissions or other material in the docket, go to <http://www.regulations.gov> or the OSHA Docket Office at the address above. All documents in the docket are listed in the <http://www.regulations.gov> index; however, some information (e.g., copyrighted material) is not publicly available to read or download through the Web site. All submissions, including copyrighted material, are available for inspection and copying at the OSHA Docket Office. Contact the OSHA Docket Office for assistance in locating docket submissions.

6. *Extension of comment period:* Submit requests for an extension of the comment period on or before January 4, 2016 to the Office of Technical Programs and Coordination Activities, Directorate of Technical Support and Emergency Management, Occupational Safety and Health Administration, U.S. Department of Labor, 200 Constitution Avenue NW., Room N-3655, Washington, DC 20210, or by fax to (202) 693-1644.

**FOR FURTHER INFORMATION CONTACT:** Information regarding this notice is available from the following sources:

*Press inquiries:* Contact Mr. Frank Meilinger, Director, OSHA Office of Communications, U.S. Department of Labor, 200 Constitution Avenue NW., Room N-3647, Washington, DC 20210; telephone: (202) 693-1999; email: [Meilinger.francois2@dol.gov](mailto:Meilinger.francois2@dol.gov).

*General and technical information:* Contact Mr. Kevin Robinson, Director,

Office of Technical Programs and Coordination Activities, Directorate of Technical Support and Emergency Management, Occupational Safety and Health Administration, U.S. Department of Labor, 200 Constitution Avenue NW., Room N-3655, Washington, DC 20210; phone: (202) 693-2110 or email: [Robinson.kevin@dol.gov](mailto:Robinson.kevin@dol.gov).

#### **SUPPLEMENTARY INFORMATION:**

*Copies of this Federal Register notice.* Electronic copies of this **Federal Register** notice are available at <http://www.regulations.gov>. This **Federal Register** notice, as well as news releases and other relevant information, also are available at OSHA's Web page at <http://www.osha.gov>.

*Hearing Requests.* According to 29 CFR 1905.15, hearing requests must include: (1) A short and plain statement detailing how the proposed variance would affect the requesting party; (2) a specification of any statement or representation in the variance application that the commenter denies, and a concise summary of the evidence adduced in support of each denial; and (3) any views or arguments on any issue of fact or law presented in the variance application.

#### **I. Notice of Application**

On September 22, 2014, Nucor Steel Connecticut Incorporated (hereafter, "NSCI" or "the applicant") 35 Toelles Road, Wallingford, CT 06492, submitted under Section 6(d) of the Occupational Safety and Health Act of 1970 ("OSH Act"; 29 U.S.C. 655) and 29 CFR 1905.11 ("Variances and other relief under section 6(d)") an application for a permanent variance from several provisions of the OSHA standard that regulates the control of hazardous energy ("lockout/tagout" or "LOTO"), as well as a request for an interim order pending OSHA's decision on the application for variance (Ex. OSHA-2014-0022-0003) at its Wallingford, Connecticut facility. Specifically, NSCI seeks a variance from the provisions of the standard that require: (1) Lockout or tagout devices be affixed to each energy isolating device by authorized employees (29 CFR 1910.147(d)(4)(i)); and (2) lockout devices, where used, be affixed in a manner to that will hold the energy isolating devices in a "safe" or "off" position (29 CFR 1910.147(d)(4)(ii)). NSCI also requested an interim order pending OSHA's decision on the application for variance.

According to its application, NSCI manufactures steel wire rod and coiled rebar from billets of steel by using rolling and forming processes. Further, NSCI's description of its operation indicates that the hot steel billets are

shaped and formed into steel wire rod and coiled rebar by running them through a series of rolls. The rolls shape and form the steel as it moves from one stand to the next. Each roll has several passes (or grooves), only one of which is used at a time. The pass is designed to shape the bar to a certain size as it goes through the mill by compressing, squeezing, and stretching the bar. Rolls are designed with passes to bring a bar down through roughing, intermediate and finish mills to a finished size.

As with any shaping tool, the passes wear during use and from time to time need to be changed. As the pass wears, the shape of the bar and the appearance of the bar are affected. When new rolls are brought into production, every pass is prepared with a spray that provides friction which allows the rolls to bite the bar between the rolls. Once rolls are in operation, roll grinding is regularly required, because during the operation of the mill stands water is used to cool the rolls to prevent fracturing and damage to the rolls. The water protects the pass while in use, but it also creates rust in the other passes. The rust can affect the final quality of the bar being processed, so steps are taken to remove the rust prior to restarting the operations. Rust is removed from the passes using a common 4-inch hand grinder. Since January 2012, the rolls have been ground with the rolls stopped and locked out.

NSCI asserts that grinding the rolls requires access to the Motor Control Room (MCR), in order to operate the energy isolation disconnects for the roll mills. Employees who perform the particular task of grinding the passes would be exposed to potentially serious arc flash hazards if they accessed the MCR in order to perform energy isolation functions. To control exposure to the arc flash hazards, NSCI instituted safe work rules that: (1) Designate the MCR as a restricted entry work area; (2) restrict MCR access to qualified electricians only; and (3) prohibit employees who perform pass grinding from entering the MCR because they are not qualified electrical employees trained in recognition and mitigation of electrical hazards. Further, NSCI asserts that as a consequence of following these safe work rules the employees performing pass grinding cannot lockout the energy isolation disconnects located in the MCR or personally verify that a lockout has been performed.

OSHA initiated a preliminary technical review of NSCI's variance application and developed a set of follow-up questions regarding the assertions of equivalent worker protection included in the application.

On November 26, 2014, OSHA sent NSCI a letter containing a set of follow-up questions (Ex. OSHA-2014-0022-0006). On December 19, 2014, NSCI provided its responses to the follow-up questions (Ex. OSHA-2014-0022-0007). Based on these responses to the follow-up questions and the alternate safety measures proposed in NSCI's application, on May 22, 2015, the Agency sent NSCI a letter (Ex. OSHA-2014-0022-0009) describing its preliminary findings on the technical merits of the application. OSHA's letter also included a set of proposed conditions for the grant of an interim order and permanent variance and a request for NSCI's comments on these proposed conditions. On July 10, 2015, NSCI provided its response (Ex. OSHA-2014-0022-0010) indicating acceptance of the proposed conditions and including a few recommended changes. OSHA carefully reviewed NSCI's recommended changes and incorporated the majority of the changes into this notice.

Following this review, OSHA determined that the applicant proposed an alternative that will provide a workplace as safe and healthful as that provided by the standard. OSHA is granting NSCI an interim order in order to permit it to continue work while OSHA continues to consider its application for a permanent variance.

## II. The Variance Application

### A. Background

NSCI's variance application and the responses to OSHA's follow-up questions include the following: Detailed descriptions of the manufacturing process; the equipment used; the proposed alternative to lockout/tagout (LOTO) devices and procedures implemented during servicing and maintenance of specific equipment (e.g., grinding of roll mill stands) located in the roll mill stands; and technical evidence supporting NSCI's assertions of equivalency of worker protection.

According to the information included in its application, performing lockout on the roll mill stands requires access to the MCR, an area restricted to qualified electricians. Because NSCI employees who perform the particular task of grinding the passes are not qualified electrical employees trained in recognition and mitigation of electrical hazards, they may not access the MCR. Therefore, they cannot use the EID in that location to isolate the hazardous electrical energy or personally verify that energy isolation has been achieved

if the EID is operated by a qualified employee.

To address these issues, NSCI has developed an alternative method of preventing the unexpected startup or energization of the roll mill passes located in the roll mill stands. NSCI proposes to use a comprehensive engineered system and appropriate administrative procedures to meet the energy isolation requirements. The engineered system uses a "trapped key" concept and monitored safety-rated power relays in combination with administrative procedures the trapped key system described above to replace a locked out energy isolating device. The trapped key functions similar to a lockout device, in that only the employee in possession of the key can restart the machine undergoing maintenance. The single key is controlled through administrative group lockout procedures that NSCI believes match the requirements of 29 CFR 1910.147.

Further, NSCI asserts that its proposed trapped key energy control system has been evaluated<sup>1</sup> for three scenarios that could result in unexpected energization of the rolls including: (1) Intentional de-energization; (2) intentional re-energization; and (3) potential faults. The system prevents unexpected startup or energization in all three scenarios.

The applicant contends that the alternative safety measures included in its application provide its workers with a place of employment that is at least as safe and healthful as they would obtain under the existing provisions of OSHA's control of hazardous energy (lockout/tagout) standard. The applicant certifies that it provided employee representatives with a copy of the variance application. The applicant also certifies that it notified its workers of the variance application by posting, at prominent locations where it normally posts workplace notices, a summary of the application and information specifying where the workers can examine a copy of the application. In addition, the applicant informed its

<sup>1</sup> NSCI provided documentation that TÜV Rheinland, an independent third-party testing laboratory reviewed and certified that the trapped key interlock system is a suitable component for use in safety category 2, 3, and 4 safety systems as specified in International Electrotechnical Commission (IEC) and International Organization for Standardization (ISO) machinery standards. Further, NSCI asserted that several independent experts (including Dr. James Barrett, Mr. Ed Grund, Mr. Bruce Main, and Mr. Alan Metelsky) skilled in the evaluation of electrical circuitry, guarding, and the control of hazardous energy evaluated the circuitry of the trapped key system and found that it was appropriately designed and installed for this application.

workers of their rights to petition the Assistant Secretary of Labor for Occupational Safety and Health for a hearing on the variance application.

*B. Variance From Paragraph (d)(4)(i) and (d)(4)(ii) of 29 CFR 1910.147*

As an alternative means of compliance to the requirements of 1910.147(d)(4)(i) and (ii), NSCI is proposing to use a comprehensive engineered system and appropriate administrative procedures to meet these requirements. The engineered system uses a “trapped key” concept and monitored safety-rated power relays in combination with administrative procedures the trapped key system described above to replace a locked out energy isolating device. The trapped key functions similar to a lockout device, in that only the employee in possession of the key can restart the machine undergoing maintenance. The single key is controlled through administrative group lockout procedures identical to those required by 29 CFR 1910.147. Although the trapped key prevents normal intended startup of the equipment being serviced, it is not being used on an EID, as required by OSHA’s standards. To meet this requirement, NSCI proposes to use a monitored safety-relay system that uses approved components, redundant systems, and control-reliable circuitry. Use of the proposed trapped key system in combination with detailed administrative energy control policies and procedures, as well as providing effective training would allow NSCI’s authorized and affected employees to complete the required grinding of its stationary rolls in a manner that provides equivalency in energy isolation to compliance with the applicable provisions of the LOTO standard. The proposed trapped key system is based on use of an Allen Bradley *GuardMaster* safety-rated relay, which is specifically designed for safety applications. However, the use of the proposed Allen Bradley *GuardMaster* safety-rated relay does not meet the LOTO standard’s definition of EID because this relay is a form of control circuitry.

The applicant maintains that use of the proposed trapped key system provides equivalent safety with what can be achieved by strict compliance with the 1910.147(d)(4)(i) and (ii) requirements. According to NSCI’s variance application, equivalent safety is achieved by prohibiting roll movement during de-energization while grinding is being performed, as well as prohibiting mistaken intentional re-energization and re-energization due to fault conditions, without exposing

employees to hazards within the MCR. To protect against system faults causing re-energization, the proposed trapped key system meets the requirements for control reliability as stated in ANSI B11.19 (2010) *Performance of Safeguarding*, in that no single fault will result in the loss of the safety function. In addition, the system includes system fault monitoring, tamper resistance, and exclusive employee control over lockout devices.

Further, the applicant asserts that the trapped key system uses well tried components, which is a key factor in the reliability of a control system. The system is based on an Allen Bradley *GuardMaster* safety rated relay which is specifically designed for safety applications. The trapped key is a specially manufactured unique key that is only available from the manufacturer at a significant cost, and cannot be otherwise duplicated.

*C. Technical Review*

OSHA conducted a review of NSCI’s application and the supporting technical documentation. After completing the review of the application and supporting documentation, OSHA concludes that NSCI:

1. Modified the electrical controls at the pulpit (central control station located on the roll mill floor for the 15 roll mill stands), to prevent employee exposure to hazards associated with movement of the roll mill while performing the task of grinding roll mill passes located in the roll mill stands;

2. Installed a trapped key control system and implemented administrative energy control procedures that prevent employee exposure to hazards associated with energy while grinding on the roll mill passes;

3. Utilizing qualified engineering safety experts, performed a job hazard analysis for roll grinding associated tasks, conducted and documented an electrical isolation analysis, system and functional safety reviews, and control reliability analysis to verify that the use of the trapped key system and administrative energy control procedures prevent the movement of roll mill passes; prevent mistaken or intentional re-energization; and maintain immobility in the event of fault conditions;

4. Developed a two-tiered system of securing the trapped key as follows:

- a. Stopping the operation and energization of the roll mill passes by removing the trapped key from the system, and securing the key within a lockbox inside the pulpit area (central control station located on the roll mill floor for the 15 roll mill stands); and

- b. Locking the key to the lockbox in the pulpit area inside a secondary group lock box installed on the roll mill floor, with each employee performing roll mill grinding applying their personal lock to the lockbox;

5. Developed detailed administrative energy control procedures for use of the trapped key system;

6. Implemented detailed administrative energy control procedures designed to ensure that each authorized employee applies a personal lock to the secondary group lock box;

7. Procured and provided appropriate equipment and supplies;

8. Made the administrative energy control policies and procedures available in English and Spanish;

9. Trained authorized and affected employees on the application of the trapped key system and associated administrative energy control policies and procedures;

10. Ensured that grinding on the passes is conducted only while using the administrative energy control procedures based on the trapped key system;

11. Installed guarding on the entry/infeed and exit/outfeed sides of each roll mill stand to prevent employees from standing between turning mills and being exposed to the crushing hazards of in-running nip points;

12. Developed additional administrative controls and procedures to minimize the potential for authorized and affected employees to enter between the mill stands when harm could occur; and

13. Designated and posted the areas as “No Entry” unless the procedures (1–12 above) are followed.

**III. Description of the Conditions Specified by the Interim Order and the Application for a Permanent Variance**

This section describes the conditions that comprise the alternative means of compliance with 29 CFR 1910.147(d)(4)(i) and (d)(4)(ii). These conditions form the basis of the interim order and NSCI’s application for a permanent variance.<sup>2</sup>

*Proposed Condition A: Scope*

The scope of the interim order/proposed permanent variance limits/would limit coverage of the conditions of the interim order/proposed permanent variance to the work situations specified under this proposed

<sup>2</sup>In these conditions, the present tense form of the verb (e.g., “must”) pertains to the interim order, while the future conditional form of the verb (e.g., “would”) pertains to the application for a permanent variance (designated as “permanent variance”).

condition. Clearly defining the scope of the interim order/proposed permanent variance provides/would provide NSCI, NSCI's employees, other stakeholders, the public, and OSHA with necessary information regarding the work situations in which the proposed permanent variance does/would apply and does not/would not apply. For example, condition A limits/would limit coverage of the interim order/proposed permanent variance only to the task of grinding roll mill passes located in the roll mill stands. The condition clarifies/would clarify that no other maintenance work, including electrical maintenance, may be/would be performed on the roll mill passes, the roll mill motors, other residual or stored energy sources, or electric circuits connected to the trapped key system or roll mill stands using the trapped key system to control hazardous energy.

According to 29 CFR 1905.11, an employer or class or group of employers<sup>3</sup> may request a permanent variance for a specific workplace or workplaces. If granted, the variance would apply to the specific employer(s) that submitted the application. In this instance, if OSHA were to grant a permanent variance, it would apply to the applicant, NSCI at the Wallingford, CT plant only. As a result, it is important to understand that the interim order and proposed variance would not apply to any other employers or NSCI plant locations.

#### *Proposed Condition B: Definitions*

Proposed condition B defines/would define a series of terms, mostly technical terms, used in the interim order and proposed permanent variance to standardize and clarify their meaning. Defining these terms serves to enhance the applicant's and its employees' understanding of the conditions specified by interim order and the proposed permanent variance.

#### *Proposed Condition C: Safety and Health Practices*

Proposed condition C requires/would require the applicant to: (1) Modify certain controls at the pulpit by installing and operating a trapped key system designed to replace an energy isolating device; (2) develop and implement certain trapped key system-related alternate energy control policies and procedures; and (3) develop and implement a series of trapped key

system-related hazard prevention and control requirements and methods designed to ensure the continued effective functioning of the alternate energy control equipment, policies, and procedures. Examples of such hazard control measures include, but are not limited to: (1) Conducting grinding on the passes only after using the steps required to properly de-energize the system; (2) under the direction of a qualified person,<sup>4</sup> ensuring that the trapped key system is installed, inspected, serviced, maintained, used, and when appropriate modified in accordance with good engineering practices, and/or in strict accordance with the manufacturers' specifications and instructions, where available; and (3) no other maintenance is/would be performed on the roll mill stands while grinding is taking place.

#### *Proposed Condition D: Steps Required To De-Energize the System*

Proposed condition D requires/would require the applicant to develop and implement a detailed procedure for de-energizing the roll mill passes located in the roll mill stands in order to perform the grinding task. The procedure for de-energizing the roll mill passes includes/would include a series of steps to ensure that all authorized and effected employees are/would be notified that: The roll mill passes are/would be effectively de-energized; the task of grinding the roll mill passes is ready to begin; and no other servicing or maintenance is/would be performed on the roll mill stands while grinding is taking place.

#### *Proposed Condition E: Steps Required To Start Motion Intentionally*

Proposed condition E requires/would require the applicant to develop and implement a detailed procedure for re-energizing and intentionally starting motion in the roll mill passes located in the roll mill stands in order to resume normal operations at the conclusion of the grinding task. The procedure for re-energizing the roll mill passes includes/would include a series of steps to ensure that all authorized and effected employees are/would be notified that the task of grinding the roll mill passes is complete and that the roll mill passes are/would be ready for use.

#### *Proposed Condition F: Training and Methods of Operation*

Proposed condition F requires/would require the applicant to develop and implement an effective hazardous energy control qualification and training

program for authorized employees involved in using the trapped key system while grinding roll mill passes. The condition specifies/would specify the factors that an employee must know following completion of the training program. Elements to be/would be included in the training program encompass, among others: The program to be/would be presented in language that the employees can understand; the instruction be/would be reviewed periodically to accommodate changes in the energy control program; the contents and conditions included in the interim order/proposed variance; and a job hazard analysis (JHA) in the use of the trapped key system, the identification of associated hazards, and safe application of the associated energy control procedures be/would be prepared and instructed. Additionally, proposed condition F also requires/would require the applicant to train each affected employee in the purpose and use of the alternative energy control procedures using the trapped key system.

#### *Proposed Condition G: Inspections, Tests, and Accident Prevention*

Proposed condition G requires/would require the applicant to develop, implement and operate an effective program for completing inspections, tests, program evaluations, and accident prevention for the use of the trapped key system and safe application of the hazardous energy control procedures in the roll mill stands and associated work areas. This condition will/would help to ensure the safe operation and physical integrity of the equipment and work area necessary for use of the trapped key system while conducting roll mill grinding operations, thereby enhancing worker safety by reducing the risk of unexpected energization of the equipment.

This condition also requires/would require the applicant to document tests, inspections, corrective actions and repairs involving the use of the trapped key system, and maintain these documents. Further, this requirement will/would provide the applicant with information needed to schedule tests and inspections to ensure the continued safe operation of the equipment and systems, and to determine that the actions taken to correct defects were/would be appropriate.

#### *Proposed Condition H: Recordkeeping*

Proposed condition H requires/would require the applicant to maintain records of specific factors associated with use of the trapped key system to prevent the unexpected energization of the equipment while grinding roll mill

<sup>3</sup> A class or group of employers (such as members of a trade alliance or association) may apply jointly for a variance provided an authorized representative for each employer signs the application and the application identifies each employer's affected facilities.

<sup>4</sup> See footnote 9.

passes. The information gathered and recorded under this provision, in concert with the information provided under proposed condition I (Notifications, for using the OSHA 301 Incident Report form to investigate and record energy isolation failure-related injuries as defined by 29 CFR 1904.4, 1904.7, 1904.8 through 1904.12), enables/would enable the applicant and OSHA to determine the effectiveness of the permanent variance in preventing recordable injuries.<sup>5</sup>

#### *Proposed Condition I: Notifications*

Proposed condition I requires/would require the applicant, within specified periods to: (1) Notify OSHA (*i.e.*, Office of Technical Programs and Coordination Activities (OTPCA), and the Bridgeport, CT, Area Office) of any recordable injuries, illnesses, fatalities, work-related in-patient hospitalizations, amputations and all losses of an eye (as defined by 29 CFR 1904.4, and 1904.7 through 1904.12) that occur/would occur as a result of complying with the alternative energy control conditions of the variance (*e.g.*, as a result of performing roll mill pass grinding operations) within 8 hours of the incident (or becoming aware of the incident); (2) provide OSHA (*i.e.*, OTPCA and the Bridgeport, CT, Area Office) with a copy of the preliminary incident investigation report (using OSHA 301 form) within 24 hours of the incident (or becoming aware of the incident); (3) provide OSHA (*i.e.*, OTPCA and the Bridgeport, CT, Area Office) with a copy of the full incident investigation within 7 calendar days of the incident (or becoming aware of the incident); (4) include on the 301 form information on the energy isolation procedures and conditions associated with the recordable injury or illness, the root-cause determination, and preventive and corrective actions identified and implemented; (5) provide its certification that it informed affected workers of the incident and the results of the incident investigation; (6) notify OTPCA and the Bridgeport, CT, Area Office within 15 working days should the applicant need to revise its energy isolation procedures to accommodate changes in the application of its trapped key system that affect/would affect its ability to comply with the conditions of

the proposed permanent variance; and (7) provide/would provide OTPCA and the Bridgeport, CT, Area Office, by January 31st at the beginning of each calendar year, with a report covering the year just ended, evaluating the effectiveness of the alternate energy isolation program.

The proposed requirement of this condition for completing and submitting the variance conditions-related (recordable) preliminary incident investigation report (OSHA 301 form) is/would be more restrictive than the current recordkeeping requirement of completing the OSHA 301 form within 7 calendar days of the incident (1904.29(b)(3)). Submittal of the preliminary incident investigation report will/would be followed by submittal of the full incident investigation report within 7 calendar days. This modified and more stringent incident investigation and reporting requirement is/would be restricted to variance conditions-related (recordable) incidents only. Providing this notification is/would be essential because time is/would be a critical element in OSHA's ability to determine the continued effectiveness of the variance conditions in preventing recordable incidents, and the employer's identification of appropriate hazard control measures and implementation of corrective and preventive actions. Further, these notification requirements enable/would enable the applicant, its employees, and OSHA to determine the effectiveness of the permanent variance in providing the requisite level of safety to the employer's workers and, based on this determination, whether to revise or revoke the conditions of the proposed permanent variance. Timely notification permits/would permit OSHA to take whatever action is necessary and appropriate to prevent further variance conditions-related recordable injuries and illnesses. Providing notification to employees informs/would inform them of the precautions taken by the employer to prevent similar incidents in the future. Additionally, these notification requirements allow/would allow OSHA to: communicate effectively, expedite administration, and enforce the conditions of the interim order/proposed permanent variance.

This proposed condition also requires/would require the applicant to notify OSHA if it ceases to do business, has a new address or location for its main office, or transfers the operations covered by the interim order/proposed permanent variance to a successor company. In addition, the condition specifies/would specify that OSHA

must approve the transfer of the interim order/permanent variance to a successor company. These requirements allow/would allow OSHA to communicate effectively with the applicant regarding the status of the interim order/proposed permanent variance, and expedite the Agency's administration and enforcement of the interim order/permanent variance. Stipulating that an applicant is/would be required to have OSHA's approval to transfer an interim order/permanent variance to a successor company provides/would provide assurance that the successor company has/would have knowledge of, and will/would comply with, the conditions specified by the interim order/proposed permanent variance, thereby ensuring the safety of workers involved in performing the operations covered by the interim order/proposed permanent variance.

#### **IV. Grant of Interim Order**

As noted earlier, on September 22, 2014, NSCI requested an interim order that will/would remain in effect until: December 2, 2016, or the Agency makes a decision on its application for a permanent variance, or it is modified or revoked, whichever occurs first. During the period starting with the publication of this notice and until the interim order expires, or the Agency modifies or revokes the interim order, or makes a decision on its application for a permanent variance, the applicant is required to comply fully with the conditions of the interim order (as an alternative to complying with the requirements of 29 CFR 1910.147(d)(4)(i) and 1910.147(d)(4)(ii) (hereafter, "the standard") that requires:

A. Lockout or tagout devices be affixed to each energy isolating device by authorized employees (1910.147(d)(4)(i)); and

B. Lockout devices, where used, be affixed in a manner to that will hold the energy isolating devices in a "safe" or "off" position (29 CFR 1910.147(d)(4)(ii)).

As described earlier in this notice (section II(C) Technical Review), after reviewing the proposed alternatives OSHA preliminarily determined that NSCI developed, and proposed to implement, effective alternative means of protection that protect its employees as effectively as paragraphs 1910.147(d)(4)(i) and (ii) of OSHA's LOTO standard during the servicing and maintenance task of grinding roll mill passes located in the roll mill stands.

Based on a review of available evidence and the information provided in the applicant's variance application, OSHA is issuing an interim order.

<sup>5</sup> See 29 CFR 1904 Recording and Reporting Occupational Injuries and Illnesses ([http://www.osha.gov/pls/oshaweb/owadisp.show\\_document?p\\_table=STANDARDS&p\\_id=9631](http://www.osha.gov/pls/oshaweb/owadisp.show_document?p_table=STANDARDS&p_id=9631)); recordkeeping forms and instructions (<http://www.osha.gov/recordkeeping/RKform300pkg-fillable-enabled.pdf>); and Updates to OSHA's Recordkeeping Rule (<http://www.osha.gov/recordkeeping2014/index.html>).

Under the interim order and variance application, instead of complying with the requirements of 29 CFR 1910.147(d)(4)(i) and (ii) of OSHA's LOTO standard, NSCI will: (1) Comply with the conditions listed below under "Specific Conditions of the Interim Order and the Application for a Permanent Variance" for as long as the Interim Order remains in effect; (2) comply fully with all other applicable provisions of 29 CFR part 1910; and (3) provide a copy of this **Federal Register** notice to all employees affected by the conditions using the same means it used to inform these employees of its application for a permanent variance. Additionally, this interim order will remain in effect until December 2, 2016; OSHA publishes its final decision on the variance application in the **Federal Register**; or OSHA modifies or revokes the interim order in accordance with 29 CFR 1905.13, whichever occurs first.

#### V. Specific Conditions of the Interim Order and the Application for a Permanent Variance

The following conditions apply to the interim order OSHA is granting to NSCI. In addition, these conditions specify the alternative means of compliance with the requirements of paragraphs 29 CFR 1910.147(d)(4)(i) and (ii) that NSCI is proposing for its permanent variance. The conditions apply to all NSCI employees located at the 35 Toelles Road, Wallingford, CT 06492 establishment during the servicing and maintenance task of grinding roll mill passes located in the roll mill stands. These conditions are:<sup>6</sup>

##### A. Scope

1. This interim order/permanent variance applies/would apply only to the task of grinding roll mill passes located in the roll mill stands of NSCI's Wallingford, CT establishment. This work is to be/would be performed by authorized employees under alternative energy control procedures using a trapped key system and lockboxes.

2. No other maintenance work, including electrical maintenance (such as troubleshooting or maintenance covered under 29 CFR 1910.333), may be/would be performed on the roll mill passes, the roll mill motors, or electric circuits connected to the trapped key system or roll mill stands using the trapped key system to control hazardous energy.

3. If any other maintenance or servicing work is/would be performed, even if that work is performed at the same time as grinding roll mill passes,

all of the maintenance work at that time must be/would be performed under full lockout as required by 29 CFR 1910.147.

4. Except for the requirements specified by 29 CFR 1910.147(d)(4)(i) and (ii), NSCI must comply/would comply fully with all other applicable provisions of 29 CFR part 1910.147 during servicing and maintenance of roll mills during the task of grinding roll mill passes.

5. The interim order will remain in effect until December 2, 2016; OSHA modifies or revokes it; or OSHA publishes the **Federal Register** notice granting the permanent variance in accordance with 29 CFR 1905.13, whichever occurs first.

##### B. Definitions

The following definitions apply/would apply to this interim order/proposed permanent variance:

1. *Affected employee*—an employee whose job requires him/her to work in an area in which grinding of roll mill passes located in the roll mill stands is being performed.

2. *Authorized employee*—an employee who uses the trapped key system in order to perform grinding of roll mill passes located in the roll mill stands. An affected employee becomes an authorized employee when that employee's duties include performing grinding of roll mill passes located in the roll mill stands covered under this section.

3. *Competent person*—an employee who is capable of identifying existing and predictable hazards in the surroundings associated with grinding of roll mill passes located in the roll mill stands or working conditions that are unsanitary, hazardous, or dangerous to employees, and who has authorization to take prompt corrective measures to eliminate them.<sup>7</sup>

4. *Equipment lock box*—a part of the trapped key system consisting of any group lock box designated for and mounted on or near equipment used for securing the equipment lock box key by use of a personal lockout device.

5. *Equipment lock box lock and key*—a part of the trapped key system consisting of a uniquely identified equipment specific lock (red) and key used to secure the pulpit designated lock box containing and securing the trapped key.

6. *Group lock box*—a purchased lock box labeled as "TRAPPED KEY SYSTEM" that is used to enable more than one lock to be applied to the box. There are two types of lock boxes used in association with the trapped key

system (see definitions for pulpit designated lock box and secondary group lock box).

7. *Job Hazard Analysis/Job Safety Analysis*—an evaluation of tasks or operations to identify potential hazards and to determine the necessary controls.

8. *Personal lock and key*—a durable, standardized substantial and uniquely identified device (a lock) that is maintained and controlled by a single authorized employee whose name is attached to the device. The key is unique to this device and is equally maintained and controlled by the authorized employee<sup>8</sup> whose name is attached to the device. The personal lock and key is used to secure the equipment lock box key in the secondary group lock box.

9. *Pulpit designated lock box*—a group lock box mounted inside the pulpit designated for use with the "TRAPPED KEY SYSTEM" and including the: (a) Trapped key; (b) equipment lock box lock and key; and (c) pulpit operator personal lock and key placed on the pulpit designated lock box to secure the trapped key.

10. *Pulpit operator*—an authorized employee who: (a) Is designated to work on a roll mill crew; (b) is authorized to use the trapped key system during the grinding of roll mill passes; and (c) is trained to operate the pulpit panel. The pulpit panel has the ability to control the following equipment systems: Reheat furnace, discharge roll line, turntable, roll mill stands A & B; roll mill stands 1–15; water system; finishing mill; laying head; and stelmore conveyor.

11. *Pulpit operator trapped key system personal lock and key*—a part of the trapped key system consisting of a uniquely identified lock (green) and key used by the pulpit operator to secure the pulpit designated lock box containing and securing the trapped key.

12. *Qualified person*—an employee who, by possession of a recognized degree, certificate, or professional standing, or who, by extensive knowledge, training, and experience, successfully demonstrates an ability to solve or resolve problems relating to the subject matter, the work, or the project.<sup>9</sup>

13. *Roll mill operator and/or lead*—an authorized employee who is designated and trained to operate specific and multiple equipment systems or perform a specific job task that is part of the rolling process, including application of

<sup>8</sup> See 29 CFR part 1910 [Docket No. S–012A], RIN 1218–AA53. Control of Hazardous Energy Sources (Lockout/Tagout), regarding "one person, one lock, one key."

<sup>9</sup> Adapted from 29 CFR 1926.32(m).

<sup>6</sup> See footnote 2.

<sup>7</sup> Adapted from 29 CFR 1926.32(f).

the trapped key system for the grinding of roll mill passes.

14. *Secondary group lock box*—a group lock box located on the mill floor just below the pulpit where authorized employees apply personal locks and follow trapped key system alternative energy isolation procedures to secure the equipment lock box key.

15. *Safety-rated relay*—a device specifically designed for safety applications that meets the requirements for control reliability as stated in ANSI B11.19 (2010) Performance of Safeguarding. The term “control reliable” means that no single fault will result in the loss of the safety function. In addition, the relay must include monitoring and tamper resistance.

16. *Team member*—an employee who is trained and authorized to use the trapped key system in order to perform grinding of roll mill passes located in the roll mill stands.

17. *Trapped key*—a specially manufactured unique key only available from its manufacturer that is inserted into the trapped key system’s rotary switch. The rotary switch trapped key is mechanically attached by a chain to the pulpit designated lock box.

18. *Trapped key system*—the alternative method of preventing the unexpected startup or energization during grinding of roll mill passes located in the roll mill stands. NSCI presented the trapped key system to OSHA in its variance application of September 22, 2014, as supplemented by its responses to OSHA’s questions during the Agency’s application review. The system is based on an Allen Bradley *GuardMaster* safety-rated relay which is specifically designed for safety applications and use of a trapped key that is a specially manufactured unique key only available from its manufacturer, and the administrative controls described in this variance.

#### C. Safety and Health Practices

1. NSCI shall/would modify the electrical controls at the pulpit (central control station located on the roll mill floor for the 15 roll mill stands), to prevent employee exposure to hazards associated with movement of the roll mill during the task of grinding roll mill passes;

2. NSCI shall/would install a trapped key system;

3. NSCI shall/would install a pulpit designated lock box for the trapped key in the pulpit area;

4. NSCI shall/would install a secondary group lock box in the roll mills floor area for securing the pulpit designated lock box key;

5. NSCI shall/would develop administrative energy control procedures for use of the trapped key system as described below;

6. NSCI shall/would implement detailed energy control procedures designed to ensure that each authorized employee applies a personal lock to the secondary group lock box, and has the ability to personally verify de-energization of the system, as described below;

7. NSCI shall/would make the energy control policies and procedures available to authorized and affected employees in English and Spanish;

8. NSCI shall/would ensure that grinding on the passes is conducted only while using the administrative energy control procedures based on the trapped key system, or using full lockout procedures that comply with 29 CFR 1910.147 when the roll stands must be de-energized so that other maintenance operations can be performed simultaneously with roll grinding;

9. NSCI shall/would install guarding on the entry/infeed and exit/outfeed sides of each roll mill stand to prevent employees from standing between turning mills and being exposed to the crushing hazards of in-running nip points;

10. NSCI shall/would develop additional administrative controls and procedures to minimize the potential for authorized and affected employees to enter between the mill stands when harm could occur; and

11. NSCI shall/would designate and post the areas as “No Entry” unless the procedures (1–10) are followed.

12. NSCI shall/would ensure that the trapped key system and its components are properly installed, inspected, maintained, and used so that it works as designed. NSCI shall strictly follow, where applicable, manufacturers’ recommendations for the installation, inspection, maintenance, and use of the system and its components.

13. NSCI shall/would ensure that the trapped key system is only altered or modified for uses specified and approved by a qualified person by following good engineering practices. Where available, such alterations and modifications shall strictly follow the manufacturers’ specifications, instructions, and written authorization. No changes or modifications may be made to the trapped key system or its components that diminish the protection provided to affected employees.

14. NSCI shall/would ensure that alteration or modification of the trapped key system is fully justified and

documented when the manufacturers’ specifications, instructions, and written authorization are lacking.

15. NSCI shall/would implement a procedure to ensure that no other maintenance will be performed on the roll mill stands while grinding is taking place, unless full lockout is used for all maintenance tasks being performed at that time.

#### D. Steps Required To De-Energize the System

NSCI shall/would develop and implement a detailed procedure for de-energizing the roll mill passes located in the roll mill stands in order to perform the grinding task. The procedure for de-energizing the roll mill passes shall/would include the following steps:

1. The authorized employee de-energizing the roll mill passes shall/would notify all affected employees that the equipment will be/would be shut down and locked out to perform grinding of the passes;

2. The pulpit operator shall/would turn off the control lever on the control panel;

3. The pulpit operator shall/would activate the E-stop;

4. The pulpit operator verifies/would verify that the red “system functional” indicator is illuminated, then turns/would turn the trapped lockout key 90° to OFF position, and removes/would remove the trapped key from the panel. The operator verifies/would verify that the green “safe to work indicator” illuminates, and that the red “system functional” indicator goes out;

5. The pulpit operator:

a. Places/would place the trapped key in the pulpit designated lock box and applies/would apply his or her personal lock to the pulpit designated lock box; and

b. Applies/would apply the equipment lock box lock designated for this energy control procedure;

6. The pulpit operator hands/would hand the equipment lock box lock key to the roll mill operator and/or lead;

7. The roll mill operator and/or lead takes/would take the equipment lock box lock key to the secondary group lock box;

8. The roll mill operator and/or lead places/would place the equipment lock box lock key in the secondary group lock box and attaches his or her personal lock;

9. Authorized employees (team members) place/would place their personal locks on the secondary group lock box;

10. The roll mill operator and/or lead verifies/would verify that the equipment is de-energized and locked out by trying

to operate the equipment (using the start button);

11. The roll mill operator and/or lead ensures/would ensure that there are no additional sources of energy that could lead to the unexpected energization of the roll mill passes;

12. Authorized employees who placed/would place their personal trapped key system locks on the secondary group lockout box shall/would also confirm that the equipment is fully de-energized;

13. Authorized employees who placed/would place their personal locks on the secondary group lock box shall/would maintain their personal key in their possession while performing grinding of the roll mill passes; and

14. Authorized employees shall/would perform the task of grinding the passes only while these procedures are/would be used.

#### *E. Steps Required To Start Motion Intentionally*

NSCI shall/would develop and implement a detailed procedure for re-energizing and intentionally starting motion in the roll mill passes located in the roll mill stands in order to resume normal operations at the conclusion of the grinding task. The procedure for re-energizing the roll mill passes shall/would include the following steps:

1. The roll mill operator and/or lead shall/would check the equipment and the immediate area around the equipment to ensure that necessary items have been removed and that the equipment components are operationally intact;

2. The roll mill operator and/or lead shall/would check the work area to ensure that all affected employees have been safely positioned or removed from the area;

3. The roll mill operator and/or lead shall/would check that all controls are in the neutral or off position;

4. Authorized employees shall/would remove their personal trapped key system locks from the secondary group lock box;

5. The roll mill operator and/or lead shall/would remove the equipment lock box lock key from the secondary group lock box and take it to the pulpit;

6. The roll mill operator and/or lead shall/would hand the equipment lock box lock key to the pulpit operator;

7. The pulpit operator shall/would verify that all personnel are clear of the equipment before starting to re-energize the roll mill passes;

8. The pulpit operator shall/would remove his or her trapped key system personal lock from the pulpit designated lock box;

9. Using the equipment lock box lock key, the pulpit operator shall/would remove the equipment lock box lock;

10. The pulpit operator shall/would remove the trapped key from the pulpit designated lock box and shall/would insert the key into the rotary switch and turn it 90° to the ON position;

11. The pulpit operator shall/would press the reset button to re-energize the roll mill passes;

12. The pulpit operator shall/would confirm that the green light clears and the red light activates indicating that the system is powered and that the trapped key system will no longer prevent roll mill motion; and

13. The pulpit operator shall/would notify affected employees that the task of grinding the roll mill passes is complete and that the roll mill passes are ready for use.

#### *F. Training and Methods of Operation*

NSCI shall/would develop and implement a detailed worker qualifications and training program. NSCI must/would:

1. Develop an energy control training program and train each authorized employee, pulpit operator, roll mill designated person, and their supervisors on the trapped key system, and the procedures each must perform under it. The training program will be provided in a language that the employees can understand;

2. Develop a training program and train each affected employee in the purpose and use of the alternative energy control procedures using the trapped key system before commencing operations under this interim order/proposed variance, and document this instruction. The training program will be provided in a language that the employees can understand;

3. Repeat the instruction specified in paragraph (1) of this condition periodically and as necessary (e.g., after making changes, in accordance with condition I-5, to the use of the trapped key system that affect its component configuration or operation and associated energy control procedures);

4. Ensure that each authorized and affected employee, designated pulpit operator, roll mill designated person, and each of their supervisors have effective and documented training in the contents and conditions covered by this proposed variance;

5. Ensure that only trained and authorized employees, designated pulpit operators, and roll mill designated persons, perform energy control procedures for the task of grinding roll mill passes;

6. Prepare a JHA for the safe application of energy control procedures; and

7. Review periodically and as necessary (e.g., after making changes, in accordance with conditions C-13 and I-5, to the component configuration or operation of the trapped key system and energy control procedures that affect the grinding of roll mill passes located in the roll mill stands), the contents of the JHA with affected personnel.

#### *G. Inspections, Tests and Incident Prevention*

NSCI shall/would develop and implement a detailed program for completing inspections, tests, program evaluations and incident prevention. NSCI must/would:

1. Initiate and maintain a program of frequent and regular inspections of the trapped key system and associated work areas by:

a. Ensuring that a competent person (authorized employee) conducts daily visual checks and quarterly inspections and functionality tests of the trapped key system components and configuration or operation and energy control procedures that affect the grinding of roll mill passes located in the roll mill stands to ensure that the procedure and the conditions of this variance are being followed;

b. Ensuring that a competent person conducts weekly inspections of the work areas associated with the grinding of roll mill passes located in the roll mill stands; and

c. Developing a set of checklists to be used by a competent person in conducting the weekly inspections of the work areas associated with the grinding of roll mill passes located in the roll mill stands and the quarterly inspections and functionality tests of the trapped key system components and configuration or operation and energy control procedures that affect the grinding of roll mill passes.

2. Remove the equipment from service if the competent person determines that the equipment constitutes a safety hazard. NSCI must not return the equipment to service until the hazardous condition is corrected and the correction has been approved by a qualified person.

3. All maintenance, servicing, and installation of replacement parts must be performed in strict accordance with good engineering practices. Where available, the maintenance, servicing and installation of replacement parts must strictly follow the manufacturers' specifications, instructions, and limitations.



### H. Recordkeeping

1. NSCI must/would maintain a record of any recordable injury, illness, in-patient hospitalizations, amputations, loss of an eye or fatality (using the OSHA 301 Incident Report form to investigate and record energy control-related recordable injuries as defined by 29 CFR 1904.4, 1904.7, 1904.8 through 1904.12<sup>10</sup>), resulting from the task of grinding roll mill passes located in the roll mill stands by completing the OSHA 301 Incident Report form and OSHA 300 Log of Work-Related Injuries and Illnesses.

2. NSCI must/would maintain records of all tests and inspections of the component configuration or operation, and energy control procedures, as well as associated hazardous condition corrective actions and repairs.

### I. Notifications

To assist OSHA in administering the conditions specified herein, NSCI shall/would:

1. Notify the OTPCA and the Bridgeport, CT, Area Office of any recordable injuries, illnesses, in-patient hospitalizations, amputations, loss of an eye or fatality (by submitting the completed OSHA 301 Incident Report form) resulting from implementing the alternative energy control procedures of the proposed variance conditions while completing the task of grinding roll mill passes located in the roll mill stands. The notification must be made within 8 hours of the incident or 8 hours after becoming aware of a recordable injury, illness, in-patient hospitalizations, amputations, loss of an eye, or fatality.

2. Submit a copy of the preliminary incident investigation (OSHA form 301) to the OTPCA and the Bridgeport, CT, Area Office within 24 hours of the incident or 24 hours after becoming aware of a recordable case and submit a copy of the full incident investigation within 7 calendar days of the incident or 7 calendar days after becoming aware of the case. In addition to the information required by the OSHA form 301, the incident-investigation report must include a root-cause determination, and the preventive and corrective actions identified and implemented.

3. Provide certification within 15 working days of the incident that NSCI informed affected workers of the incident and the results of the incident investigation (including the root-cause determination and preventive and corrective actions identified and implemented).

4. Notify the OTPCA and the Bridgeport, CT, Area Office in writing and 15 working days prior to any proposed change in the energy control operations (including changes addressed by condition C-13) that affects NSCI's ability to comply with the conditions specified herein.

5. Obtain OSHA's approval prior to implementing the proposed change in the energy control operations that affects NSCI's ability to comply with the conditions specified herein.

6. Provide a written evaluation report, by January 31st at the beginning of each calendar year, with a report covering the year just ended, to the OTPCA and the Bridgeport, CT, Area Office summarizing the quarterly inspections and functionality tests of the trapped key system components and configuration or operation and energy control procedures that affect the grinding of roll mill passes located in the roll mill stands, to ensure that the energy control procedure and the conditions of this variance are being followed.

Note: The evaluation report is to contain summaries of: (1) The number of variance-related incidents (as recorded on OSHA 301 forms); and (2) root causes of any incidents, and preventive and corrective actions identified and implemented.

7. Inform the OTPCA and the Bridgeport, CT, Area Office as soon as possible after it has knowledge that it will:

- a. Cease to do business;
- b. change the location and address of the main office for managing the alternative energy control procedures specified herein; or
- c. transfer the operations specified herein to a successor company.

8. Notify all affected employees of this interim order/proposed permanent variance by the same means required to inform them of its application for a variance.

9. Request approval from OSHA for the transfer of the interim order/proposed permanent variance to a successor company.

### Authority and Signature

David Michaels, Ph.D., MPH, Assistant Secretary of Labor for Occupational Safety and Health, 200 Constitution Avenue NW., Washington, DC 20210, authorized the preparation of this notice. Accordingly, the Agency is issuing this notice pursuant to Section 29 U.S.C. 655(6)(d), Secretary of Labor's Order No. 1-2012 (77 FR 3912, Jan. 25, 2012), and 29 CFR 1905.11.

Signed at Washington, DC, on November 25, 2015.

**David Michaels,**

*Assistant Secretary of Labor for Occupational Safety and Health.*

[FR Doc. 2015-30483 Filed 12-1-15; 8:45 am]

**BILLING CODE 4510-26-P**

## NUCLEAR REGULATORY COMMISSION

[Docket No. 52-016; NRC-2008-0066]

### Dominion Virginia Power Combined License Application for North Anna, Unit 3

**AGENCY:** Nuclear Regulatory Commission.

**ACTION:** Exemption; issuance.

**SUMMARY:** The U.S. Nuclear Regulatory Commission (NRC) is issuing an exemption in a response to a September 23, 2015, letter from Dominion Virginia Power (Dominion or applicant), which requested an exemption from the requirement to submit an annual update of the Final Safety Analysis Report (FSAR) included in Dominion's Combined License (COL) application for calendar year 2015. The NRC staff reviewed this request and determined that it is appropriate to grant the exemption based on the schedule for completion of the applicant's seismic closure plan (SCP) submitted on October 22, 2014, which outlined a revised approach to performing certain aspects of the seismic analysis for the North Anna 3 COL application (COLA) as well as use of the most current NRC-approved ground motion model.

**DATES:** The effective date of the Dominion FSAR exemption issuance is December 2, 2015.

**ADDRESSES:** Please refer to Docket ID NRC-2008-0066 when contacting the NRC about the availability of information regarding this document. You may obtain publicly-available information related to this document using any of the following methods:

- Federal Rulemaking Web site: Go to <http://www.regulations.gov> and search for Docket ID NRC-2008-0066. Address questions about NRC dockets to Carol Gallagher; telephone: 301-415-3463; email: [Carol.Gallagher@nrc.gov](mailto:Carol.Gallagher@nrc.gov). For technical questions, contact the individual listed in the **FOR FURTHER INFORMATION CONTACT** section of this document.

- NRC's Agencywide Documents Access and Management System (ADAMS): You may obtain publicly available documents online in the ADAMS Public Documents collection at

<sup>10</sup> See footnote 5.