

addendum updates the OSA's plan of action and milestones for HIOSH to work towards regaining section 18(e) final approval status. OSHA will continue to work with, and provide assistance to, HIOSH.

Authority and Signature

David Michaels, Ph.D., MPH, Assistant Secretary of Labor for Occupational Safety and Health, U.S. Department of Labor, 200 Constitution Ave. NW., Washington, DC, authorized the preparation of this notice. OSHA is issuing this notice under the authority specified by section 18 of the Occupational Safety and Health Act of 1970 (29 U.S.C. 667), Secretary of Labor's Order No. 1–2012 (76 FR 3912), and 29 CFR part 1902.

Signed in Washington, DC, on May 25, 2016.

David Michaels,

Assistant Secretary of Labor for Occupational Safety and Health.

[FR Doc. 2016–12821 Filed 5–31–16; 8:45 am]

BILLING CODE 4510–26–P

NATIONAL SCIENCE FOUNDATION

Astronomy and Astrophysics Advisory Committee; Notice of Meeting

In accordance with the Federal Advisory Committee Act (Pub. L. 92–463, as amended), the National Science Foundation announces the following meeting:

Name: Astronomy and Astrophysics Advisory Committee (#13883).

Date and time: June 6, 2016; 12:00 p.m.–4:00 p.m. EDT (via Teleconference).

Place: National Science Foundation, Room 1060, Stafford I Building, 4201 Wilson Blvd., Arlington, VA 22230.

Dial-in Information (June 2016 Meeting Only)

To join via Browser: <https://bluejeans.com/996692403/browser>.

To join via phone:
(1) Dial: +1.408.740.7256; +1.888.240.2560; or +1.408.317.9253 (see all numbers—<http://bluejeans.com/numbers?l=en>).

(2) Enter Conference ID: 996692403.

Type of meeting: Open.

Contact person: Dr. James Ulvestad, Division Director, Division of Astronomical Sciences, Suite 1045, National Science Foundation, 4201 Wilson Blvd., Arlington, VA 22230. Telephone: 703–292–7165.

Purpose of meeting: To provide advice and recommendations to the National Science Foundation (NSF), the National Aeronautics and Space

Administration (NASA) and the U.S. Department of Energy (DOE) on issues within the field of astronomy and astrophysics that are of mutual interest and concern to the agencies.

Agenda: To hear presentations of current programming by representatives from NSF, NASA, DOE and other agencies relevant to astronomy and astrophysics; to discuss current and potential areas of cooperation between the agencies; to formulate recommendations for continued and new areas of cooperation and mechanisms for achieving them.

Reason for late notice: Due to unforeseen scheduling complications and the necessity to proceed with the meeting.

Dated: May 25, 2016.

Crystal Robinson,

Committee Management Officer.

[FR Doc. 2016–12736 Filed 5–31–16; 8:45 am]

BILLING CODE 7555–01–P

NUCLEAR REGULATORY COMMISSION

[Docket Nos. 52–027 and 52–028; NRC–2008–0441]

Virgil C. Summer Nuclear Station, Units 2 and 3; South Carolina Electric & Gas Company, South Carolina Public Service Authority; Compressed and Instrument Air System High Pressure Air Subsystem Changes

AGENCY: Nuclear Regulatory Commission.

ACTION: Exemption and combined license amendment; issuance.

SUMMARY: The U.S. Nuclear Regulatory Commission (NRC) is granting an exemption to allow a change to the certification information of Tier 1 of the generic design control document (DCD) and issuing License Amendment No. 44 to Combined Licenses (COL), NPF–93 and NPF–94. The COLs were issued to South Carolina Electric & Gas Company (SCE&G), and South Carolina Public Service Authority (together called the licensee) in March 2012, for the construction and operation of the Virgil C. Summer Nuclear Station (VCSNS), Units 2 and 3, located in Fairfield County, South Carolina.

DATES: June 1, 2016.

ADDRESSES: Please refer to Docket ID NRC–2008–0441 when contacting the NRC about the availability of information regarding this document. You may obtain publicly-available information related to this document using any of the following methods:

- *Federal Rulemaking Web site:* Go to <http://www.regulations.gov> and search for Docket ID NRC–2008–0441. Address questions about NRC dockets to Carol Gallagher; telephone: 301–415–3463; email: carol.gallagher@nrc.gov. For technical questions, contact the individual listed in the **FOR FURTHER INFORMATION CONTACT** section of this document.

- *NRC's Agencywide Documents Access and Management System (ADAMS):* You may obtain publicly-available documents online in the ADAMS Public Documents collection at <http://www.nrc.gov/reading-rm/adams.html>. To begin the search, select “ADAMS Public Documents” and then select “Begin Web-based ADAMS Search.” For problems with ADAMS, please contact the NRC's Public Document Room (PDR) reference staff at 1–800–397–4209, 301–415–4737, or by email to pdr.resource@nrc.gov. The ADAMS accession number for each document referenced (if it is available in ADAMS) is provided the first time that it is mentioned in this document. The request for the amendment and exemption was submitted by the letter dated October 30, 2014 (ADAMS Accession No. ML14303A635). The licensee supplemented this request by letter dated July 13, 2015 (ADAMS Accession No. ML15194A314), and April 21, 2016, (ADAMS Accession No. ML16112A272).

- *NRC's PDR:* You may examine and purchase copies of public documents at the NRC's PDR, One White Flint North, 11555 Rockville Pike, Rockville, Maryland 20852. Specific information on NRC's PDR is available at <http://www.nrc.gov/reading-rm/pdr.html>.

FOR FURTHER INFORMATION CONTACT: William (Billy) Gleaves, Office of New Reactors, U.S. Nuclear Regulatory Commission, Washington, DC 20555–0001; telephone: 301–415–5848; email: Bill.Gleaves@nrc.gov.

SUPPLEMENTARY INFORMATION:

I. Introduction

The NRC is granting an exemption from Tier 1 information in the certified DCD incorporated by reference in part 52 of title 10 of the *Code of Federal Regulations* (10 CFR), appendix D, “Design Certification Rule for the AP1000 Design,” and issuing License Amendment No. 44 to COLs, NPF–93 and NPF–94, to the licensee. The exemption is required by Paragraph A.4 of Section VIII, “Processes for Changes and Departures,” appendix D to 10 CFR part 52 to allow the licensee to change Tier 1 information. With the requested amendment, the licensee sought

proposed changes related to the plant-specific Tier 1 information. The Tier 1 information for which a plant-specific exemption is being requested includes changes to remove a supply line from the Compressed and Instrument Air System (CAS) to the generator breaker package. The proposed license amendment describes changes to plant-specific Tier 1 text, COL Appendix C, and UFSAR Tier 2 text and a figure related to the removal of a supply line from the CAS to the main generator breaker package.

The granting of the exemption allows the changes to Tier 1 information requested in the license amendment request. Because the acceptability of the exemption was determined in part by the acceptability of the amendment, the exemption and amendment are being issued concurrently.

Part of the justification for granting the exemption was provided by the review of the amendment. Because the exemption is necessary in order to issue the requested license amendment, the NRC granted the exemption and issued the amendment concurrently, rather than in sequence. This included issuing a combined safety evaluation containing the NRC staff's review of both the exemption request and the license amendment. The exemption met all applicable regulatory criteria set forth in 10 CFR 50.12, 10 CFR 52.7, and 10 CFR 52.63(b)(1). The license amendment was found to be acceptable as well. The combined safety evaluation is available in ADAMS under Accession No. ML16076A430.

Identical exemption documents (except for referenced unit numbers and license numbers) were issued to the licensee for VCSNS Units 2 and 3 (COLs NPF-93 and NPF-94). These documents can be found in ADAMS under Accession Nos. ML16076A420 and ML16076A427, respectively. The exemption is reproduced (with the exception of abbreviated titles and additional citations) in Section II of this document. The amendment documents for COLs NPF-93 and NPF-94 are available in ADAMS under Accession Nos. ML16076A411 and ML16076A418, respectively. A summary of the amendment documents is provided in Section III of this document.

II. Exemption

Reproduced below is the exemption document issued to VCSNS, Units 2 and 3. It makes reference to the combined safety evaluation that provides the reasoning for the findings made by the NRC (and listed under Item 1) in order to grant the exemption:

1. In a letter dated October 30, 2014, supplemented July 13, 2015, and April 21, 2016, the South Carolina Electric & Gas Company (SC&G/licensee) requested from the Nuclear Regulatory Commission (NRC/Commission) an exemption to allow departures from Tier 1 information in the certified Design Control Document (DCD) incorporated by reference in title 10 of the *Code of Federal Regulations* (10 CFR) part 52, appendix D, "Design Certification Rule for the AP1000 Design," as part of license amendment request (LAR) 15-14, "Compressed and Instrument Air System High Pressure Air Subsystem Changes."

For the reasons set forth in Section 3.1 of the NRC staff's Safety Evaluation that supports this license amendment, which can be found at Agencywide Documents Access and Management System (ADAMS) Accession No. ML16076A430, the Commission finds that:

- A. The exemption is authorized by law;
- B. the exemption presents no undue risk to public health and safety;
- C. the exemption is consistent with the common defense and security;
- D. special circumstances are present in that the application of the rule in this circumstance is not necessary to serve the underlying purpose of the rule;
- E. the special circumstances outweigh any decrease in safety that may result from the reduction in standardization caused by the exemption, and
- F. the exemption will not result in a significant decrease in the level of safety otherwise provided by the design.

2. Accordingly, the licensee is granted an exemption from the certified AP1000 DCD Tier 1 information, as described in the licensee's request dated October 30, 2014, supplemented July 13, 2015. This exemption is related to, and necessary for, the granting of License Amendment No. 44, which is being issued concurrently with this exemption.

3. As explained in Section 5 of the NRC staff's Safety Evaluation that supports this license amendment (ADAMS Accession No. ML16076A430), this exemption meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Therefore, pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment needs to be prepared in connection with the issuance of the exemption.

4. This exemption is effective as of the date of its issuance.

III. License Amendment Request

The request for the amendment and exemption was submitted by the letter dated October 30, 2014. The licensee

supplemented this request by the letter dated July 13, 2015, and April 21, 2016. The proposed amendment is described in Section I, above.

The Commission has determined for these amendments that the application complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR chapter I, which are set forth in the license amendment.

A notice of consideration of issuance of amendment to facility operating license or combined license, as applicable, proposed no significant hazards consideration determination, and opportunity for a hearing in connection with these actions, was published in the **Federal Register** on February 17, 2015 (80 FR 8355). No comments were received during the 30-day comment period.

The NRC staff has found that the amendment involves no significant hazards consideration. The Commission has determined that these amendments satisfy the criteria for categorical exclusion in accordance with 10 CFR 51.22(c)(9). Therefore, pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared for these amendments. The supplement dated July 13, 2015, and April 21, 2016, provided additional information that clarified the application, did not expand the scope of the application as originally noticed, and did not change the staff's original proposed no significant hazards consideration determination as published in the **Federal Register**.

IV. Conclusion

Using the reasons set forth in the combined safety evaluation, the staff granted the exemption and issued the amendment that the licensee requested on October 30, 2014, and supplemented by letters dated July 13, 2015, and April 21, 2016. The exemption and amendment were issued on April 27, 2016, as part of a combined package to the licensee (ADAMS Accession No. ML16076A396).

Dated at Rockville, Maryland, this 24th day of May 2016.

For the Nuclear Regulatory Commission.

John McKirgan,

Acting Chief, Licensing Branch 4, Division of New Reactor Licensing, Office of New Reactors.

[FR Doc. 2016-12916 Filed 5-31-16; 8:45 am]

BILLING CODE 7590-01-P