

protected under Title 13 U.S.C. Section 9. The Census Bureau issued a **Federal Register** notice (FRN) and submitted an emergency clearance request to OMB for revised confidentiality pledge language, with the new line to address the new cybersecurity screening requirements bolded for reference:

*“The U.S. Census Bureau is required by law to protect your information. The Census Bureau is not permitted to publicly release your responses in a way that could identify you. Per the Federal Cybersecurity Enhancement Act of 2015, your data are protected from cybersecurity risks through screening of the systems that transmit your data.”*

OMB Control No.	Information collection title
1121-0111 ...	National Crime Victimization Survey (NCVS).
1121-0184 ...	School Crime Supplement to the NCVS.
1121-0317 ...	Identity Theft Supplement to the NCVS.
1121-0260 ...	Police Public Contact Supplement to the NCVS.
1121-0302 ...	Supplemental Victimization Survey to the NCVS.

The FRN submitted by the Census Bureau can be accessed at <https://www.federalregister.gov/documents/2016/12/14/2016-30014/confidentiality-pledge-revision-notice>, and the Census Bureau's PRA clearance request can be accessed at [https://www.reginfo.gov/public/do/PRAViewICR?ref\\_nbr=201612-0607-001](https://www.reginfo.gov/public/do/PRAViewICR?ref_nbr=201612-0607-001).

If additional information is required contact: Melody Braswell, Department Clearance Officer, United States Department of Justice, Justice Management Division, Policy and Planning Staff, Two Constitution Square, 145 N Street NE., 3E.405B, Washington, DC 20530.

Dated: December 27, 2016.

**Melody Braswell,**

Department Clearance Officer, U.S. Department of Justice.

[FR Doc. 2016-31705 Filed 12-29-16; 8:45 am]

BILLING CODE 4410-18-P

## NUCLEAR REGULATORY COMMISSION

[Docket Nos. 52-025 and 52-026; NRC-2008-0252]

### Southern Nuclear Operating Company, Inc., Vogtle Electric Generating Plant, Units 3 and 4; Tier 1 Editorial and Consistency Changes

AGENCY: Nuclear Regulatory Commission.

**ACTION:** Exemption and combined license amendment; issuance.

**SUMMARY:** The U.S. Nuclear Regulatory Commission (NRC) is granting an exemption to allow a departure from the certification information of Tier 1 of the generic design control document (DCD) and is issuing License Amendment No. 56 to Combined Licenses (COL) NPF-91 and NPF-92. The COLs were issued to Southern Nuclear Operating Company, Inc., and Georgia Power Company, Oglethorpe Power Corporation, MEAG Power SPVM, LLC, MEAG Power SPVJ, LLC, MEAG Power SPVP, LLC, Authority of Georgia, and the City of Dalton, Georgia (the licensee); for construction and operation of the Vogtle Electric Generating Plant (VEGP) Units 3 and 4, located in Burke County, Georgia. The granting of the exemption allows the changes to Tier 1 information asked for in the amendment. Because the acceptability of the exemption was determined in part by the acceptability of the amendment, the exemption and amendment are being issued concurrently.

**ADDRESSES:** Please refer to Docket ID NRC-2008-0252 when contacting the NRC about the availability of information regarding this document. You may access information related to this document, which the NRC possesses and is publicly available, using any of the following methods:

- *Federal Rulemaking Web site:* Go to <http://www.regulations.gov> and search for Docket ID NRC-2008-0252. Address questions about NRC dockets to Carol Gallagher; telephone: 301-415-3463; email: [Carol.Gallagher@nrc.gov](mailto:Carol.Gallagher@nrc.gov). For technical questions, contact the individual listed in the **FOR FURTHER INFORMATION CONTACT** section of this document.

- *NRC's Agencywide Documents Access and Management System (ADAMS):* You may obtain publicly-available documents online in the ADAMS Public Documents collection at <http://www.nrc.gov/reading-rm/adams.html>. To begin the search, select "ADAMS Public Documents" and then select "*Begin Web-based ADAMS Search.*" For problems with ADAMS, please contact the NRC's Public Document Room (PDR) reference staff at 1-800-397-4209, 301-415-4737, or by email to [pdr.resource@nrc.gov](mailto:pdr.resource@nrc.gov). The ADAMS accession number for each document referenced (if it is available in ADAMS) is provided the first time that it is mentioned in this document. The request for the amendment and exemption was submitted by letter dated June 3, 2016, and available in

ADAMS under Accession No. ML16155A366.

- *NRC's PDR:* You may examine and purchase copies of public documents at the NRC's PDR, Room O1-F21, One White Flint North, 11555 Rockville Pike, Rockville, Maryland 20852.

**FOR FURTHER INFORMATION CONTACT:** Chandu Patel, Office of New Reactors, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001; telephone: 301-415-3025; email: [Chandu.Patel@nrc.gov](mailto:Chandu.Patel@nrc.gov).

## SUPPLEMENTARY INFORMATION:

### I. Introduction

The NRC is granting an exemption from Paragraph B of section III, "Scope and Contents," of appendix D, "Design Certification Rule for the AP1000," to part 52 of title 10 of the *Code of Federal Regulations* (10 CFR), and issuing License Amendment No. 56 to COLs, NPF-91 and NPF-92, to the licensee. The exemption is required by Paragraph A.4 of Section VIII, "Processes for Changes and Departures," appendix D, to 10 CFR part 52 to allow the licensee to depart from Tier 1 information. With the requested amendment, the licensee sought proposed changes that would correct editorial errors in plant-specific Tier 1 information, with corresponding changes to the associated COL Appendix C information, to promote consistency with the Updated Final Safety Analysis Report Tier 2 information. One of the proposed changes to plant-specific Tier 1 information also involves a change to Updated Final Safety Analysis Report Tier 2 information. The proposed amendment also involves a proposed editorial correction to COL Paragraph 2.D.(12)(g)1. Part of the justification for granting the exemption was provided by the review of the amendment. Because the exemption is necessary in order to issue the requested license amendment, the NRC granted the exemption and issued the amendment concurrently, rather than in sequence. This included issuing a combined safety evaluation containing the NRC's review of both the exemption request and the license amendment. The exemption met all applicable regulatory criteria set forth in 10 CFR 50.12, 10 CFR 52.7, and Section VIII.A.4 of appendix D to 10 CFR part 52. The license amendment was found to be acceptable as well. The combined safety evaluation is available in ADAMS under Accession No. ML16244A345.

Identical exemption documents (except for referenced unit numbers and license numbers) were issued to the licensee for VEGP Units 3 and 4 (COLs NPF-91 and NPF-92). The exemption

documents for VEGP Units 3 and 4 can be found in ADAMS under Accession Nos. ML16244A301 and ML16244A324, respectively. The exemption is reproduced (with the exception of abbreviated titles and additional citations) in Section II of this document. The amendment documents for COLs NPF-91 and NPF-92 are available in ADAMS under Accession Nos. ML16244A270 and ML16244A283, respectively. A summary of the amendment documents is provided in Section III of this document.

## II. Exemption

Reproduced below is the exemption document issued to VEGP Units 3 and Unit 4. It makes reference to the combined safety evaluation that provides the reasoning for the findings made by the NRC (and listed under Item 1) in order to grant the exemption:

1. In an application dated June 3, 2016, the licensee requested from the Commission an exemption to allow departures from Tier 1 information in the certified DCD incorporated by reference in 10 CFR part 52, appendix D, as part of license amendment request 16-008, "Tier 1 Editorial and Consistency Changes."

For the reasons set forth in Section 3 of the NRC's Safety Evaluation, which can be found at ADAMS Accession No. ML16244A345, the Commission finds that:

A. The exemption is authorized by law;

B. the exemption presents no undue risk to public health and safety;

C. the exemption is consistent with the common defense and security;

D. special circumstances are present in that the application of the rule in this circumstance is not necessary to serve the underlying purpose of the rule;

E. the special circumstances outweigh any decrease in safety that may result from the reduction in standardization caused by the exemption; and

F. the exemption will not result in a significant decrease in the level of safety otherwise provided by the design.

2. Accordingly, the licensee is granted an exemption from the certified DCD Tier 1 information, with corresponding information in COL Appendix C of the Facility Combined License as described in the licensee's request dated June 3, 2016. This exemption is related to, and necessary for the granting of License Amendment No. 56, which is being issued concurrently with this exemption.

3. As explained in Section 5.0 of the NRC's Safety Evaluation (ADAMS Accession No. ML16244A345), this exemption meets the eligibility criteria

for categorical exclusion set forth in 10 CFR 51.22(c)(9). Therefore, pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment needs to be prepared in connection with the issuance of the exemption.

4. This exemption is effective as of the date of its issuance.

## III. License Amendment Request

By letter dated June 3, 2016, the licensee requested that the NRC amend the COLs for VEGP, Units 3 and 4, COLs NPF-91 and NPF-92. The proposed amendment is described in Section I of this **Federal Register** notice.

The Commission has determined for these amendments that the application complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment.

A notice of consideration of issuance of amendment to facility operating license or COL, as applicable, proposed no significant hazards consideration determination, and opportunity for a hearing in connection with these actions, was published in the **Federal Register** on August 2, 2016 (81 FR 50729). No comments were received during the 30-day comment period.

The Commission has determined that these amendments satisfy the criteria for categorical exclusion in accordance with 10 CFR 51.22. Therefore, pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared for these amendments.

## IV. Conclusion

Using the reasons set forth in the combined safety evaluation, the NRC granted the exemption and issued the amendment that the licensee requested on June 3, 2016. The exemption and amendment were issued on October 12, 2016 as part of a combined package to the licensee (ADAMS Accession No. ML16308A174).

Dated at Rockville, Maryland, this 19th day of December 2016.

For the Nuclear Regulatory Commission.

**Jennifer Dixon-Herrity,**

*Chief, Licensing Branch 4, Division of New Reactor Licensing, Office of New Reactors.*

[FR Doc. 2016-31720 Filed 12-29-16; 8:45 am]

**BILLING CODE 7590-01-P**

## NUCLEAR REGULATORY COMMISSION

[Docket Nos. 52-025 and 52-026; NRC-2008-0252]

### Southern Nuclear Operating Company, Inc.; Vogtle Electric Generating Plant, Units 3 and 4; Consolidation of Uninterruptible Power Supply System Spare Battery Terminal Boxes

**AGENCY:** Nuclear Regulatory Commission.

**ACTION:** Exemption and combined license amendment; issuance.

**SUMMARY:** The U.S. Nuclear Regulatory Commission (NRC) is granting an exemption to allow a departure from the certification information of Tier 1 of the generic design control document (DCD) and is issuing License Amendment No. 54 to Combined Licenses (COL), NPF-91 and NPF-92. The COLs were issued to Southern Nuclear Operating Company, Inc., and Georgia Power Company, Oglethorpe Power Corporation, MEAG Power SPVM, LLC, MEAG Power SPVJ, LLC, MEAG Power SPVP, LLC, Authority of Georgia, and the City of Dalton, Georgia (the licensee); for construction and operation of the Vogtle Electric Generating Plant (VEGP) Units 3 and 4, located in Burke County, Georgia.

The granting of the exemption allows the changes to Tier 1 information asked for in the amendment. Because the acceptability of the exemption was determined in part by the acceptability of the amendment, the exemption and amendment are being issued concurrently.

**ADDRESSES:** Please refer to Docket ID NRC-2008-0252 when contacting the NRC about the availability of information regarding this document. You may obtain publicly-available information related to this document using any of the following methods:

- *Federal Rulemaking Web site:* Go to <http://www.regulations.gov> and search for Docket ID NRC-2008-0252. Address questions about NRC dockets to Carol Gallagher; telephone: 301-415-3463; email: [Carol.Gallagher@nrc.gov](mailto:Carol.Gallagher@nrc.gov). For technical questions, contact the individual listed in the **FOR FURTHER INFORMATION CONTACT** section of this document.

- *NRC's Agencywide Documents Access and Management System (ADAMS):* You may obtain publicly-available documents online in the ADAMS Public Documents collection at <http://www.nrc.gov/reading-rm/adams.html>. To begin the search, select "ADAMS Public Documents" and then