

CFR 51.22(c)(9). Therefore, pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment needs to be prepared in connection with the issuance of the exemption.

4. This exemption is effective as of the date of its issuance.

III. License Amendment Request

By letter dated October 26, 2016 (ADAMS Accession No. ML16300A325), the licensee requested that the NRC amend the COLs for VEGP, Units 3 and 4, COLs NPF-91 and NPF-92. The proposed amendment is described in Section I of this **Federal Register** Notice.

The Commission has determined for these amendments that the application complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR chapter I, which are set forth in the license amendment.

A notice of consideration of issuance of amendment to facility operating license or combined license, as applicable, proposed no significant hazards consideration determination, and opportunity for a hearing in connection with these actions, was published in the **Federal Register** on December 20, 2016 (81 FR 92872). No comments were received during the 30-day comment period.

The Commission has determined that these amendments satisfy the criteria for categorical exclusion in accordance with 10 CFR 51.22. Therefore, pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared for these amendments.

IV. Conclusion

Using the reasons set forth in the combined safety evaluation, the staff granted the exemption and issued the amendment that the licensee requested on October 26, 2016. The exemption and amendment were issued on May 25, 2017, as part of a combined package to the licensee (ADAMS Accession No. ML17072A312).

Dated at Rockville, Maryland, this 5th day of June 2017.

For the Nuclear Regulatory Commission.

Jennifer Dixon-Herrity,

Chief, Licensing Branch 4, Division of New Reactor Licensing, Office of New Reactors.

[FR Doc. 2017-12335 Filed 6-13-17; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

[Docket Nos. 52-027 and 52-028; NRC-2008-0441]

South Carolina Electric & Gas Company, South Carolina Public Service Authority; Virgil C. Summer Nuclear Station, Units 2 and 3; Boric Acid Storage Tank Changes

AGENCY: Nuclear Regulatory Commission.

ACTION: Exemption and combined license amendment; issuance.

SUMMARY: The U.S. Nuclear Regulatory Commission (NRC) is granting an exemption to allow a departure from the certification information of Tier 1 of the generic design control document (DCD) and is issuing License Amendment No. 73 to Combined Licenses (COLs), NPF-93 and NPF-94. The COLs were issued to South Carolina Electric & Gas Company, (SCE&G); for construction and operation of the Virgil C. Summer Nuclear Station (VCSNS) Units 2 and 3, located in Fairfield County, South Carolina.

The granting of the exemption allows the changes to Tier 1 information asked for in the amendment. Because the acceptability of the exemption was determined in part by the acceptability of the amendment, the exemption and amendment are being issued concurrently.

DATES: The exemption and amendment were issued on May 24, 2017.

ADDRESSES: Please refer to Docket ID NRC-2008-0441 when contacting the NRC about the availability of information regarding this document. You may obtain publicly-available information related to this document using any of the following methods:

- *Federal Rulemaking Web site:* Go to <http://www.regulations.gov> and search for Docket ID NRC-2008-0441. Address questions about NRC dockets to Carol Gallagher; telephone: 301-415-3463; email: Carol.Gallagher@nrc.gov. For technical questions, contact the individual listed in the **FOR FURTHER INFORMATION CONTACT** section of this document.

- *NRC's Agencywide Documents Access and Management System (ADAMS):* You may obtain publicly-available documents online in the ADAMS Public Documents collection at <http://www.nrc.gov/reading-rm/adams.html>. To begin the search, select "ADAMS Public Documents" and then select "Begin Web-based ADAMS Search." For problems with ADAMS, please contact the NRC's Public

Document Room (PDR) reference staff at 1-800-397-4209, 301-415-4737, or by email to pdr.resource@nrc.gov. The ADAMS accession number for each document referenced (if it is available in ADAMS) is provided the first time that it is mentioned in this document. The request for the amendment and exemption was submitted by letter dated September 29, 2016, and is available in ADAMS under Accession No. ML16273A557.

- *NRC's PDR:* You may examine and purchase copies of public documents at the NRC's PDR, Room O1-F21, One White Flint North, 11555 Rockville Pike, Rockville, Maryland 20852.

FOR FURTHER INFORMATION CONTACT: Billy Gleaves, Office of New Reactors, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001; telephone: 301-415-5848; email: Bill.Gleaves@nrc.gov.

SUPPLEMENTARY INFORMATION:

I. Introduction

The NRC is granting an exemption from Paragraph B of Section III, "Scope and Contents," of appendix D, "Design Certification Rule for the AP1000," to part 52 of title 10 of the *Code of Federal Regulations* (10 CFR), and issuing License Amendment No. 73 to COLs, NPF-93 and NPF-94, to SCE&G. The exemption is required by Paragraph A.4 of Section VIII, "Processes for Changes and Departures," appendix D, to 10 CFR part 52 to allow SCE&G to depart from Tier 1 information. With the requested amendment, SCE&G sought proposed changes that would revise the Updated Final Safety Analysis Report (UFSAR) in the form of departures from the incorporated plant-specific DCD Tier 2 information. The proposed amendment also involves related changes to plant-specific Tier 1 information, with corresponding changes to the associated COL Appendix C information. Specifically, the license amendment request revises the inspections, tests, analyses, and acceptance criteria (ITAAC) in COL Appendix C Table 2.3.2-4, ITAAC No. 2.3.02.8a.ii to state that the volume in the BAST is at least 70,000 gallons between the tank suction point and the tank overflow; and COL Appendix C Table 2.3.2-4, ITAAC No. 2.3.02.8a.iii to state that the total CVS makeup flow to the RCS is less than or equal to 175 gpm.

Part of the justification for granting the exemption was provided by the review of the amendment. Because the exemption is necessary in order to issue the requested license amendment, the NRC granted the exemption and issued the amendment concurrently, rather

than in sequence. This included issuing a combined safety evaluation containing the NRC staff's review of both the exemption request and the license amendment. The exemption met all applicable regulatory criteria set forth in §§ 50.12, 52.7, and Section VIII.A.4 of appendix D to 10 CFR part 52. The license amendment was found to be acceptable as well. The combined safety evaluation is available in ADAMS under Accession No. ML17072A125.

Identical exemption documents (except for referenced unit numbers and license numbers) were issued to SCE&G for VCSNS Units 2 and 3 (COLs NPF-93 and NPF-94). The exemption documents for VCSNS Units 2 and 3 can be found in ADAMS under Accession Nos. ML17072A117 and ML17072A118, respectively. The exemption is reproduced (with the exception of abbreviated titles and additional citations) in Section II of this document. The amendment documents for COLs NPF-93 and NPF-94 are available in ADAMS under Accession Nos. ML17072A111 and ML17072A114, respectively. A summary of the amendment documents is provided in Section III of this document.

II. Exemption

Reproduced below is the exemption document issued to VCSNS Units 2 and Unit 3. It makes reference to the combined safety evaluation that provides the reasoning for the findings made by the NRC (and listed under Item 1) in order to grant the exemption:

1. In an application dated September 29, 2016, SCE&G requested from the Commission an exemption to allow departures from Tier 1 information in the certified DCD incorporated by reference in 10 CFR part 52, appendix D, as part of license amendment request 15-11, "Boric Acid Storage Tank Suction Point ITAAC Changes."

For the reasons set forth in Section 3.1 of the NRC staff's Safety Evaluation, which can be found in ADAMS under Accession No. ML17072A125, the Commission finds that:

A. The exemption is authorized by law;

B. the exemption presents no undue risk to public health and safety;

C. the exemption is consistent with the common defense and security;

D. special circumstances are present in that the application of the rule in this circumstance is not necessary to serve the underlying purpose of the rule;

E. the special circumstances outweigh any decrease in safety that may result from the reduction in standardization caused by the exemption; and

F. the exemption will not result in a significant decrease in the level of safety otherwise provided by the design.

2. Accordingly, SCE&G is granted an exemption from the certified DCD Tier 1 information related to the boric acid storage tank (BAST) available volume at the suction point, chemical and volume control system (CVS) makeup flow rate, and BAST installation, as described in SCE&G's request dated September 29, 2016. This exemption is related to, and necessary for the granting of License Amendment No. 73, which is being issued concurrently with this exemption.

3. As explained in Section 5.0 of the NRC staff's Safety Evaluation (ADAMS Accession No. ML17072A125), this exemption meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Therefore, pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment needs to be prepared in connection with the issuance of the exemption.

4. This exemption is effective as of the date of its issuance.

III. License Amendment Request

By letter dated September 29, 2016 (ADAMS Accession No. ML16273A557), SCE&G requested that the NRC amend the COLs for VCSNS, Units 2 and 3, COLs NPF-93 and NPF-94. The proposed amendment is described in Section I of this **Federal Register** Notice.

The Commission has determined for these amendments that the application complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment.

A notice of consideration of issuance of amendment to facility operating license or combined license, as applicable, proposed no significant hazards consideration determination, and opportunity for a hearing in connection with these actions, was published in the **Federal Register** on December 20, 2016 (81 FR 92872). No comments were received during the 30-day comment period.

The Commission has determined that these amendments satisfy the criteria for categorical exclusion in accordance with 10 CFR 51.22. Therefore, pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared for these amendments.

IV. Conclusion

Using the reasons set forth in the combined safety evaluation, the staff granted the exemption and issued the amendment that SCE&G requested on September 29, 2016.

The exemption and amendment were issued on May 24, 2017, as part of a combined package to SCE&G (ADAMS Accession No. ML17072A069).

Dated at Rockville, Maryland, this 5th day of June 2017.

For the Nuclear Regulatory Commission.

Jennifer Dixon-Herrity,

Chief, Licensing Branch 4, Division of New Reactor Licensing, Office of New Reactors.

[FR Doc. 2017-12337 Filed 6-13-17; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

Advisory Committee on Reactor Safeguards (ACRS); Meeting of the ACRS Subcommittee on APR1400; Notice of Meeting

The ACRS Subcommittee on APR1400 will hold a meeting on June 20-21, 2017, at 11545 Rockville Pike, Room T-2B1, Rockville, Maryland 20852.

The meeting will be open to public attendance with the exception of portions that may be closed to protect information that is proprietary pursuant to 5 U.S.C. 552(b)(4). The agenda for the subject meeting shall be as follows:

Tuesday, June 20, 2017, 8:30 a.m. Until 5:00 p.m. and Wednesday, June 21, 2017, 8:30 a.m. Until 12:00 p.m.

The Subcommittee will review the APR1400 design control document review, Chapter 7, "Instrumentation and Controls" and Chapter 18, "Human Factors Engineering." The Subcommittee will hear presentations by and hold discussions with the NRC staff and Korea Hydro & Nuclear Power Company regarding this matter. The Subcommittee will gather information, analyze relevant issues and facts, and formulate proposed positions and actions, as appropriate, for deliberation by the Full Committee.

Members of the public desiring to provide oral statements and/or written comments should notify the Designated Federal Official (DFO), Christopher Brown (Telephone 301-415-7111 or Email: Christopher.Brown@nrc.gov) five days prior to the meeting, if possible, so that appropriate arrangements can be made. Thirty-five hard copies of each presentation or handout should be provided to the DFO thirty minutes before the meeting. In addition, one electronic copy of each presentation