

information that clarified the application, did not expand the scope of the application as originally noticed, and did not change the staff's original proposed no significant hazards consideration determination as published in the **Federal Register**.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated January 28, 2019.

No significant hazards consideration comments received: No.

PSEG Nuclear LLC and Exelon Generation Company, LLC, Docket Nos. 50-272 and 50-311, Salem Nuclear Generating Station, Unit Nos. 1 and 2, Salem County, New Jersey

Date of amendment request: May 16, 2018, as supplemented by letters dated June 14, 2018; October 18, 2018; October 20, 2018; and October 30, 2018.

Brief description of amendments: The amendments revised Technical Specification 3.8.2.1, "A.C. [Alternating Current] Distribution—Operating," to increase the vital instrument bus inverters allowed outage time from 24 hours for the A, B, and C inverters to 7 days, and from 72 hours for the D inverter to 7 days. The extended allowed outage time is based on application of the Salem Nuclear Generating Station probabilistic risk assessment in support of a risk-informed extension, and on additional considerations and compensatory actions.

Date of issuance: January 25, 2019.

Effective date: As of the date of issuance and shall be implemented within 60 days from the date of issuance.

Amendment Nos.: 326 (Unit No. 1) and 307 (Unit No. 2). A publicly-available version is in ADAMS under Accession No. ML19009A477; documents related to these amendments are listed in the Safety Evaluation enclosed with the amendments.

Renewed Facility Operating License Nos. DPR-70 and DPR-75: The amendments revised the Renewed Facility Operating Licenses and Technical Specifications.

Date of initial notice in Federal Register: July 3, 2018 (83 FR 31186). The supplemental letters dated June 14, October 18, October 20, and October 30, 2018, provided additional information that clarified the application, did not expand the scope of the application as originally noticed, and did not change the NRC staff's original proposed no significant hazards consideration determination as published in the **Federal Register**.

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated January 25, 2019.

No significant hazards consideration comments received: No.

Southern Nuclear Operating Company, Inc., Georgia Power Company, Oglethorpe Power Corporation, Municipal Electric Authority of Georgia, City of Dalton, Georgia, Docket Nos. 50-321 and 50-366, Edwin I. Hatch Nuclear Plant, Unit Nos. 1 and 2, Appling County, Georgia

Date of amendment request: March 9, 2018. A publicly-available version is in ADAMS under Accession No. ML18071A363.

Brief description of amendments: The amendments revised the Unit No. 1 and Unit No. 2 Technical Specifications (TS) requirements of TS 3.3.8.1, "Loss of Power (LOP) Instrumentation," by modifying the instrument allowable values for the 4.16 kilovolt (kV) emergency bus degraded voltage instrumentation and by deleting the annunciation requirements for the 4.16 kV emergency bus undervoltage instrumentation for Unit No. 2. The amendment for Unit No. 2 also revises License Condition 2.C(3)(i) to clarify its intent.

Date of issuance: January 28, 2019.

Effective date: As of the date of issuance and shall be implemented within 60 days from the date of issuance.

Amendment Nos.: Unit 1—293, Unit 2—238. A publicly-available version is in ADAMS under Accession No. ML19010A009; documents related to these amendments are listed in the Safety Evaluation enclosed with the amendments.

Renewed Facility Operating License Nos. DPR-57 and NPF-5: Amendments revised the Renewed Facility Operating Licenses and Technical Specifications.

Date of initial notice in Federal Register: September 11, 2018 (83 FR 45987).

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated January 28, 2019.

No significant hazards consideration comments received: No.

Southern Nuclear Operating Company, Inc., Docket Nos. 50-424 and 50-425, Vogtle Electric Generating Plant (Vogtle), Units 1 and 2, Burke County, Georgia

Date of amendment request: October 11, 2017, as supplemented by letters dated July 26 and September 14, 2018.

Brief description of amendments: The amendments revised the Renewed Facility Operating Licenses to authorize revision of the Vogtle Units 1 and 2 Updated Final Safety Analysis Report to incorporate the process based on the Tornado Missile Risk Evaluator Methodology described in its application, as supplemented. This methodology will only be applied to discovered conditions where tornado missile protection is not currently provided, and cannot be used to avoid providing tornado missile protection in the plant modification process.

Date of issuance: January 11, 2019.

Effective date: As of the date of issuance and shall be implemented within 90 days of issuance.

Amendment Nos.: Vogtle Unit 1—198; Unit 2—181. A publicly-available version is in ADAMS under Accession No. ML18304A394; documents related to these amendments are listed in the Safety Evaluation enclosed with the amendments.

Renewed Facility Operating License Nos. NPF-68 and NPF-81: Amendments revised the Renewed Facility Operating Licenses.

Date of initial notice in Federal Register: March 27, 2018 (83 FR 13150). The supplemental letters dated July 26 and September 14, 2018, provided additional information that clarified the application, and taken together, did not expand the scope of the application as originally noticed and did not change the staff's original proposed no significant hazards consideration determination as published in the **Federal Register**.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated January 11, 2019.

No significant hazards consideration comments received: No.

Dated at Rockville, Maryland, this 1st day of February, 2019.

For the Nuclear Regulatory Commission.

Kathryn M. Brock,
Deputy Director, Division of Operating Reactor Licensing, Office of Nuclear Reactor Regulation.

[FR Doc. 2019-01215 Filed 2-11-19; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

[NRC-2019-0001]

Sunshine Act Meetings

TIME AND DATE: Weeks of February 11, 18, 25, March 4, 11, 18, 2019.

PLACE: Commissioners' Conference Room, 11555 Rockville Pike, Rockville, Maryland.

STATUS: Public and Closed.

MATTERS TO BE CONSIDERED:

Week of February 11, 2019

There are no meetings scheduled for the week of February 11, 2019.

Week of February 18, 2019—Tentative

There are no meetings scheduled for the week of February 18, 2019.

Week of February 25, 2019—Tentative

There are no meetings scheduled for the week of February 25, 2019.

Week of March 4, 2019—Tentative

Tuesday, March 5, 2019

10:00 a.m. Briefing on NRC International Activities (Closed—Ex. 1 & 9)

Week of March 11, 2019—Tentative

There are no meetings scheduled for the week of March 11, 2019.

Week of March 18, 2019—Tentative

There are no meetings scheduled for the week of March 18, 2019.

CONTACT PERSON FOR MORE INFORMATION:

For more information or to verify the status of meetings, contact Denise McGovern at 301-415-0681 or via email at Denise.McGovern@nrc.gov. The schedule for Commission meetings is subject to change on short notice.

The NRC Commission Meeting Schedule can be found on the internet at: <http://www.nrc.gov/public-involve/public-meetings/schedule.html>.

The NRC provides reasonable accommodation to individuals with disabilities where appropriate. If you need a reasonable accommodation to participate in these public meetings, or need this meeting notice or the transcript or other information from the public meetings in another format (e.g., braille, large print), please notify Kimberly Meyer-Chambers, NRC Disability Program Manager, at 301-287-0739, by videophone at 240-428-3217, or by email at Kimberly.Meyer-Chambers@nrc.gov. Determinations on requests for reasonable accommodation will be made on a case-by-case basis.

Members of the public may request to receive this information electronically. If you would like to be added to the distribution, please contact the Nuclear Regulatory Commission, Office of the Secretary, Washington, DC 20555 (301-415-1969), or by email at Wendy.Moore@nrc.gov or Diane.Garvin@nrc.gov.

Dated at Rockville, Maryland, this 7th day of February, 2019.

For the Nuclear Regulatory Commission.

Denise L. McGovern,

Policy Coordinator, Office of the Secretary.

[FR Doc. 2019-02112 Filed 2-8-19; 11:15 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

[NRC-2018-0190]

Protective Order Templates for Hearings on Conformance With the Acceptance Criteria in Combined Licenses

AGENCY: Nuclear Regulatory Commission.

ACTION: Final protective order templates.

SUMMARY: The U.S. Nuclear Regulatory Commission (NRC) staff is announcing the availability of final protective order templates to be used in hearings associated with closure of inspections, tests, analyses, and acceptance criteria (ITAAC). The templates have the purpose of facilitating quick development of case-specific protective orders to support the accelerated ITAAC hearing schedule. Participants in ITAAC hearings may, but are not required to, use the templates as the basis for proposed protective orders.

DATES: The final templates are available on February 12, 2019.

ADDRESSES: Please refer to Docket ID NRC-2018-0190 when contacting the NRC about the availability of information regarding this document. You may obtain publicly-available information related to this document using any of the following methods:

- *Federal Rulemaking Website:* Go to <http://www.regulations.gov> and search for Docket ID NRC-2018-0190. Address questions about NRC Docket IDs in *Regulations.gov* to Krupskaya Castellon; telephone: 301-287-9221; email: Krupskaya.Castellon@nrc.gov. For other questions, contact the individual listed in the **FOR FURTHER INFORMATION CONTACT** section of this document.

- *NRC's Agencywide Documents Access and Management System (ADAMS):* You may obtain publicly-available documents online in the ADAMS Public Documents collection at <http://www.nrc.gov/reading-rm/adams.html>. To begin the search, select "Begin Web-based ADAMS Search." For problems with ADAMS, please contact the NRC's Public Document Room (PDR) reference staff at 1-800-397-4209, 301-415-4737, or by email to pdr.resource@nrc.gov. For the convenience of the reader, instructions about obtaining materials referenced in this document

are provided in the "Availability of Documents" section.

- *NRC's PDR:* You may examine and purchase copies of public documents at the NRC's PDR, Room O1-F21, One White Flint North, 11555 Rockville Pike, Rockville, Maryland 20852.

FOR FURTHER INFORMATION CONTACT:

Michael A. Spencer, Office of the General Counsel, U.S. Nuclear Regulatory Commission; telephone: 301-287-9115, email:

Michael.Spencer@nrc.gov.

SUPPLEMENTARY INFORMATION:

I. Background

On July 1, 2016 (81 FR 43266), the NRC published final procedures for hearings on conformance with the acceptance criteria in combined licenses (COLs) issued under part 52 of title 10 of the *Code of Federal Regulations* (10 CFR) (ITAAC Hearing Procedures). The acceptance criteria are part of the ITAAC included in the COL. In accordance with 10 CFR 52.103(g), the NRC must find that the acceptance criteria are met before facility operation may begin. Section 189a.(1)(B) of the Atomic Energy Act of 1954, as amended (AEA), provides members of the public an opportunity to request a hearing on the facility's compliance with the acceptance criteria. The ITAAC Hearing Procedures describe the requirements for such hearing requests and the procedures to be used throughout the hearing process. The procedures for a particular ITAAC proceeding will be imposed by case-specific orders, and the ITAAC Hearing Procedures reference templates to be used for such orders.

Some NRC proceedings involve sensitive information. For ITAAC proceedings in particular, the NRC determined that a potential party may deem it necessary to obtain access to Sensitive Unclassified Non-Safeguards Information (SUNSI) or Safeguards Information (SGI) for the purpose of meeting Commission requirements for intervention. Therefore, the ITAAC Hearing Procedures include templates for orders governing requests for access to SUNSI and SGI. If a hearing participant qualifies for access to sensitive information, then a protective order and non-disclosure declaration would be needed to ensure that the information is protected appropriately. The presiding officer for a proceeding would issue the protective order, and recipients of the sensitive information would sign a non-disclosure declaration agreeing to protect the information in accordance with the protective order. Typically, the presiding officer issues a protective order in response to a motion