

ADAMS Accession No.	ML20178A668.
Brief Description of Amendment	Due to the COVID-19 public health emergency, the proposed one-time amendment would revise Technical Specification 5.5.9, "Steam Generator (SG) Program," to defer the SG tube inspection currently scheduled during Refueling Outage (RFO) 24, in the fall of 2020, to RFO 25, scheduled for the spring of 2022.
Date & Cite of Federal Register Individual Notice	July 24, 2020 (85 FR 44936).
Expiration Dates for Public Comments & Hearing Requests	August 24, 2020 (public comments); September 22, 2020 (hearing requests).
Docket No.	50-483.

Dated: August 13, 2020.

For the Nuclear Regulatory Commission.

Gregory F. Suber,

Deputy Director, Division of Operating Reactor Licensing, Office of Nuclear Reactor Regulation.

[FR Doc. 2020-18120 Filed 8-24-20; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

[NRC-2019-0234]

Information Collection: NRC Form 536, "Operator Licensing Examination Data"

AGENCY: Nuclear Regulatory Commission.

ACTION: Notice of submission to the Office of Management and Budget; request for comment.

SUMMARY: The U.S. Nuclear Regulatory Commission (NRC) has recently submitted a request for renewal of an existing collection of information to the Office of Management and Budget (OMB) for review. The information collection is entitled, NRC Form 536, "Operator Licensing Examination Data."

DATES: Submit comments by September 24, 2020. Comments received after this date will be considered if it is practical to do so, but the Commission is able to ensure consideration only for comments received on or before this date.

ADDRESSES: Written comments and recommendations for the proposed information collection should be sent within 30 days of publication of this notice to <https://www.reginfo.gov/public/do/PRAMain>. Find this particular information collection by selecting "Currently under Review—Open for Public Comments" or by using the search function.

FOR FURTHER INFORMATION CONTACT: David Cullison, NRC Clearance Officer, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001; telephone: 301-415-2084; email: Infocollects.Resource@nrc.gov.

SUPPLEMENTARY INFORMATION:

I. Obtaining Information and Submitting Comments

A. Obtaining Information

Please refer to Docket ID NRC-2019-0234 when contacting the NRC about the availability of information for this action. You may obtain publicly-available information related to this action by any of the following methods:

- **Federal Rulemaking Website:** Go to <https://www.regulations.gov> and search for Docket ID NRC-2019-0234. A copy of the collection of information and related instructions may be obtained without charge by accessing Docket ID NRC-2019-0234 on this website.
- **NRC's Agencywide Documents Access and Management System (ADAMS):** You may obtain publicly-available documents online in the ADAMS Public Documents collection at <https://www.nrc.gov/reading-rm/adams.html>. To begin the search, select "Begin Web-based ADAMS Search." For problems with ADAMS, please contact the NRC's Public Document Room reference staff at 1-800-397-4209, 301-415-4737, or by email to pdr.resource@nrc.gov. The supporting statement and NRC Form 536, "Operator Licensing Examination Data," are available in ADAMS under Accession Nos. ML20140A316 and ML20008D415, respectively.

- **NRC's Clearance Officer:** A copy of the collection of information and related instructions may be obtained without charge by contacting the NRC's Clearance Officer, David Cullison, Office of the Chief Information Officer, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001; telephone: 301-415-2084; email: Infocollects.Resource@nrc.gov.

B. Submitting Comments

The NRC cautions you not to include identifying or contact information in comment submissions that you do not want to be publicly disclosed in your comment submission. All comment submissions are posted at <https://www.regulations.gov> and entered into ADAMS. Comment submissions are not routinely edited to remove identifying or contact information.

If you are requesting or aggregating comments from other persons for submission to the OMB, then you should inform those persons not to include identifying or contact information that they do not want to be publicly disclosed in their comment submission. Your request should state that comment submissions are not routinely edited to remove such information before making the comment submissions available to the public or entering the comment into ADAMS.

II. Background

Under the provisions of the Paperwork Reduction Act of 1995 (44 U.S.C. Chapter 35), the NRC recently submitted a request for renewal of an existing collection of information to OMB for review entitled, NRC Form 536, "Operator Licensing Examination Data." The NRC hereby informs potential respondents that an agency may not conduct or sponsor, and that a person is not required to respond to, a collection of information unless it displays a currently valid OMB control number.

The NRC published a **Federal Register** notice with a 60-day comment period on this information collection on April 9, 2020 (85 FR 19965).

1. *The title of the information collection:* NRC Form 536, "Operator Licensing Examination Data."
2. *OMB approval number:* 3150-0131.
3. *Type of submission:* Extension.
4. *The form number if applicable:* 536.
5. *How often the collection is required or requested:* Annually.

6. *Who will be required or asked to respond:* (a) All holders of operating licenses for nuclear power reactors under the provision of title 10 of the Code of Federal Regulations (10 CFR) part 50, "Domestic Licensing of Production and Utilization Facilities," except those that have permanently ceased operations and have certified that fuel has been permanently removed from the reactor vessel, (b) All holders of, or applicants for, a limited work authorization, early site permit, or combined licenses issued under 10 CFR part 52, "Licenses, Certifications and Approval for Nuclear Power Plants."

7. *The estimated number of annual responses:* 60.

8. *The estimated number of annual respondents:* 60.

9. *An estimate of the total number of hours needed annually to comply with the information collection requirement or request:* 45.

10. *Abstract:* The NRC is requesting renewal of its clearance to annually request all commercial power reactor licensees and applicants for an operating license to voluntarily send to the NRC: (1) Their projected number of candidates for initial operator licensing examinations; (2) the estimated dates of the examinations, and (3) if the examinations will be facility developed or NRC developed. This information is used to plan budgets and resources in regard to operator examination scheduling in order to meet the needs of the nuclear power industry.

Dated: August 19, 2020.

For the Nuclear Regulatory Commission.

David C. Cullison,

NRC Clearance Officer, Office of the Chief Information Officer.

[FR Doc. 2020-18569 Filed 8-24-20; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

[Docket No. 50-266; NRC-2020-0191]

NextEra Energy Point Beach, LLC, Point Beach Nuclear Plant, Unit 1

AGENCY: Nuclear Regulatory Commission.

ACTION: License amendment application; opportunity to comment, request a hearing, and petition for leave to intervene.

SUMMARY: The U.S. Nuclear Regulatory Commission (NRC) is considering issuance of an amendment to Renewed Facility Operating License No. DPR-24, issued to NextEra Energy Point Beach, LLC, for operation of the Point Beach Nuclear Plant, Unit 1. The proposed amendment would modify renewed facility operating license condition 4.I, "Containment Building Construction Truss," by extending elements of the license condition on a one-time basis for another 18 months to the spring of 2022. The one-time extension is requested due to unforeseen issues as a result of the Coronavirus Disease 2019 public health emergency.

DATES: Submit comments by September 24, 2020. Requests for a hearing or petition for leave to intervene must be filed by October 26, 2020.

ADDRESSES: You may submit comments by any of the following methods:

- *Federal Rulemaking Website:* Go to <https://www.regulations.gov> and search for Docket ID NRC-2020-0191. Address questions about NRC docket IDs in *Regulations.gov* to Jennifer Borges; telephone: 301-287-9127; email: Jennifer.Borges@nrc.gov. For technical questions, contact the individual listed in the **FOR FURTHER INFORMATION CONTACT** section of this document.

- *Mail comments to:* Office of Administration, Mail Stop: TWFN-7-A60M, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, ATTN: Program Management, Announcements and Editing Staff.

For additional direction on obtaining information and submitting comments, see "Obtaining Information and Submitting Comments" in the **SUPPLEMENTARY INFORMATION** section of this document.

FOR FURTHER INFORMATION CONTACT:

Booma Venkataraman, Office of Nuclear Reactor Regulation, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001; telephone: 301-415-2934, email: Booma.Venkataraman@nrc.gov.

SUPPLEMENTARY INFORMATION:

I. Obtaining Information and Submitting Comments

A. Obtaining Information

Please refer to Docket ID NRC-2020-0191 when contacting the NRC about the availability of information for this action. You may obtain publicly-available information related to this action by any of the following methods:

- *Federal Rulemaking Website:* Go to <https://www.regulations.gov> and search for Docket ID NRC-2020-0191.
- *NRC's Agencywide Documents Access and Management System (ADAMS):* You may obtain publicly-available documents online in the ADAMS Public Documents collection at <https://www.nrc.gov/reading-rm/adams.html>. To begin the search, select "Begin Web-based ADAMS Search." For problems with ADAMS, please contact the NRC's Public Document Room reference staff at 1-800-397-4209, 301-415-4737, or by email to pdr.resource@nrc.gov. The "License Amendment Request (LAR) 293, One-Time Extension of Renewed Facility Operating License Condition 4.I, Containment Building Construction Truss," dated August 13, 2020, is available in ADAMS under Accession No. ML20226A313.

B. Submitting Comments

Please include Docket ID NRC-2020-0191 in your comment submission.

The NRC cautions you not to include identifying or contact information that you do not want to be publicly disclosed in your comment submission. The NRC will post all comment submissions at <https://www.regulations.gov> as well as enter the comment submissions into ADAMS. The NRC does not routinely edit comment submissions to remove identifying or contact information.

If you are requesting or aggregating comments from other persons for submission to the NRC, then you should inform those persons not to include identifying or contact information that they do not want to be publicly disclosed in their comment submission. Your request should state that the NRC does not routinely edit comment submissions to remove such information before making the comment submissions available to the public or entering the comment into ADAMS.

II. Introduction

The NRC is considering issuance of an amendment to Renewed Facility Operating License No. DPR-24, issued to NextEra Energy Point Beach, LLC, for operation of the Point Beach Nuclear Plant, Unit 1, located in Manitowoc County, Wisconsin.

The proposed amendment would modify renewed facility operating license condition 4.I, "Containment Building Construction Truss," by extending elements of the license condition on a one-time basis for another 18 months to the spring of 2022. The one-time extension is requested due to unforeseen issues as a result of the Coronavirus Disease 2019 public health emergency.

Before any issuance of the proposed license amendment, the NRC will need to make the findings required by the Atomic Energy Act of 1954, as amended (the Act), and NRC's regulations.

The NRC has made a proposed determination that the license amendment request involves no significant hazards consideration. Under the NRC's regulations in § 50.92 of title 10 of the *Code of Federal Regulations* (10 CFR), this means that operation of the facility in accordance with the proposed amendment would not (1) involve a significant increase in the probability or consequences of an accident previously evaluated; or (2) create the possibility of a new or different kind of accident from any accident previously evaluated; or (3) involve a significant reduction in a margin of safety. As required by 10 CFR 50.91(a), the licensee has provided its analysis of the issue of no significant