

**DEPARTMENT OF ENERGY****Federal Energy Regulatory Commission**

[Docket No. EL21–78–000]

**PJM Interconnection, L.L.C.; Notice of Institution of Section 206 Proceeding and Refund Effective Date**

On June 17, 2021, the Commission issued an order in Docket No. EL21–78–000, pursuant to section 206 of the Federal Power Act (FPA), 16 U.S.C. 824e, instituting an investigation into whether PJM Interconnection, L.L.C.'s Open Access Transmission Tariff and the Amended and Restated Operating Agreement are unjust, unreasonable, unduly discriminatory, or preferential, or otherwise unlawful. *PJM Interconnection, L.L.C.*, 175 FERC ¶ 61,231 (2021).

The refund effective date in Docket No. EL21–78–000, established pursuant to section 206(b) of the FPA, will be the date of publication of this notice in the **Federal Register**.

Any interested person desiring to be heard in Docket No. EL21–78–000 must file a notice of intervention or motion to intervene, as appropriate, with the Federal Energy Regulatory Commission, in accordance with Rule 214 of the Commission's Rules of Practice and Procedure, 18 CFR 385.214 (2020), within 21 days of the date of issuance of the order.

In addition to publishing the full text of this document in the **Federal Register**, the Commission provides all interested persons an opportunity to view and/or print the contents of this document via the internet through the Commission's Home Page (<http://www.ferc.gov>) using the "eLibrary" link. Enter the docket number excluding the last three digits in the docket number field to access the document. At this time, the Commission has suspended access to the Commission's Public Reference Room, due to the proclamation declaring a National Emergency concerning the Novel Coronavirus Disease (COVID–19), issued by the President on March 13, 2020. For assistance, contact FERC at [FERCOnlineSupport@ferc.gov](mailto:FERCOnlineSupport@ferc.gov) or call toll-free, (866) 208–3676 or TTY, (202) 502–8659.

The Commission strongly encourages electronic filings of comments, protests and interventions in lieu of paper using the "eFile" link at <http://www.ferc.gov>. In lieu of electronic filing, you may submit a paper copy. Submissions sent via the U.S. Postal Service must be addressed to: Kimberly D. Bose, Secretary, Federal Energy Regulatory

Commission, 888 First Street NE, Room 1A, Washington, DC 20426. Submissions sent via any other carrier must be addressed to: Kimberly D. Bose, Secretary, Federal Energy Regulatory Commission, 12225 Wilkins Avenue, Rockville, Maryland 20852.

Dated: June 21, 2021.

**Debbie-Anne A. Reese,**  
*Deputy Secretary.*

[FR Doc. 2021–13601 Filed 6–24–21; 8:45 am]

BILLING CODE 6717–01–P

**DEPARTMENT OF ENERGY****Federal Energy Regulatory Commission**

[Project No. 4334–017]

**EONY Generation Limited; Notice of Application Accepted for Filing and Soliciting Motions To Intervene and Protests**

Take notice that the following hydroelectric application has been filed with the Commission and is available for public inspection.

a. *Type of Application:* New Major License.

b. *Project No.:* 4334–017.

c. *Date filed:* January 28, 2021.

d. *Applicant:* EONY Generation Limited (EONY).

e. *Name of Project:* Philadelphia Hydroelectric Project.

f. *Location:* On the Indian River, in the Village of Philadelphia in Jefferson County, New York. The project does not occupy any federal land.

g. *Filed Pursuant to:* Federal Power Act 16 U.S.C. 791(a)–825(r).

h. *Applicant Contact:* Franz Kropp, Director, Generation, EONY, 7659 Lyonsdale Road, Lyons Falls, NY 13368; (613) 225–0418, ext. 7498. Murray Hall, Manager, Generation, EONY, 7659 Lyonsdale Road, Lyons Falls, NY 13368; (613) 382–7312.

i. *FERC Contact:* Emily Carter at (202) 502–6512, or [Emily.Carter@ferc.gov](mailto:Emily.Carter@ferc.gov).

j. *Deadline for filing motions to intervene and protests:* 60 days from the issuance date of this notice.

The Commission strongly encourages electronic filing. Please file motions to intervene and protests using the Commission's eFiling system at <http://www.ferc.gov/docs-filing/efiling.asp>. For assistance, please contact FERC Online Support at [FERCOnlineSupport@ferc.gov](mailto:FERCOnlineSupport@ferc.gov), (866) 208–3676 (toll free), or (202) 502–8659 (TTY). In lieu of electronic filing, you may send a paper copy. Submissions sent via the U.S. Postal Service must be addressed to: Kimberly D. Bose, Secretary, Federal

Energy Regulatory Commission, 888 First Street NE, Room 1A, Washington, DC 20426. Submissions sent via any other carrier must be addressed to: Kimberly D. Bose, Secretary, Federal Energy Regulatory Commission, 12225 Wilkins Avenue, Rockville, Maryland 20852. The first page of any filing should include docket number P–4334–017.

The Commission's Rules of Practice require all intervenors filing documents with the Commission to serve a copy of that document on each person on the official service list for the project. Further, if an intervenor files comments or documents with the Commission relating to the merits of an issue that may affect the responsibilities of a particular resource agency, they must also serve a copy of the document on that resource agency.

k. This application has been accepted but is not ready for environmental analysis at this time.

l. *Project Description:* The existing Philadelphia Hydroelectric Project consists of (1) a 65-acre reservoir at a normal maximum water surface elevation of 475.4 feet;<sup>1</sup> (2) two concrete dams joined by an island and designated as the east diversion dam, which is 60 feet long and 2 to 3 feet high with a crest elevation of 474.4 feet, and topped with 1.2-foot-high flashboards, and the west diversion dam, which has two sections totaling approximately 30 feet long and 10.4 feet high with a crest elevation of 475.4 feet; (3) a 45-foot-long non-overflow section that includes a reinforced concrete intake structure; (4) a 377-foot-long, 9.5-foot-diameter concrete penstock; (5) a 54.5-foot-long by 30-foot-wide reinforced concrete powerhouse; (6) one 3.645-megawatt horizontal Kaplan-type turbine-generator unit; (7) trashracks with 2.5-inch clear spacing; (8) a 4,160-volt, approximately 50-foot-long buried transmission line; (9) a switchyard; and (10) appurtenant facilities. The average annual generation was 10,092,492 kilowatt-hours for the period from 2016 to 2020.

EONY currently operates the project in run-of-river mode and discharges a minimum flow of 20 cubic feet per second (cfs) into the project's 1,250-foot-long bypassed reach to project aquatic resources.

As part of the license application, EONY filed a settlement agreement on behalf of itself, the U.S. Fish and Wildlife Service, and the New York State Department of Environmental Conservation. As part of the settlement

<sup>1</sup> All elevations are in National Geodetic Vertical Datum of 1929.