

[site-help/e-submittals/apply-certificates.html](https://www.nrc.gov/site-help/e-submittals/apply-certificates.html).

Once a requestor has obtained a digital ID certificate and downloaded the EIE viewer, and a docket has been created, the requestor can then submit a request for a hearing through the EIE. Submissions should be in Portable Document Format (PDF) in accordance with NRC guidance available on the NRC public website at <https://www.nrc.gov/site-help/e-submittals.html>. A filing is considered complete at the time the filer submits its document through the EIE.

To be timely, electronic filings must be submitted to the E-Filing system no later than 11:59 p.m. ET on the due date. Upon receipt of a transmission, the E-Filing system time-stamps the document and sends the submitter an email notice confirming receipt of the document. The E-Filing system also distributes an email notice that provides access to the document to the NRC Office of the General Counsel and any others who have advised the Office of the Secretary that they wish to participate in the proceeding, so that the filer need not serve the document on those participants separately. Therefore, any others who wish to participate in the proceeding (or their counsel or representative) must apply for and receive a digital ID certificate before a hearing request is filed so that they can obtain access to the document via the E-Filing system.

A person filing electronically using the agency's adjudicatory E-Filing system may seek assistance through the "Contact Us" link located on the NRC website at <https://www.nrc.gov/site-help/e-submittals.html> or by calling the NRC Electronic Filing Help Desk, which is available between 8 a.m. and 8 p.m., ET, Monday through Friday, excluding government holidays. The toll-free help line number is (866) 672-7640. A person filing electronically may also seek assistance by sending an email to the NRC Electronic Filing Help Desk at [MSHD.Resource@nrc.gov](mailto:MSHD.Resource@nrc.gov).

Participants who believe that they have good cause for not submitting documents electronically must file an exemption request, in accordance with 10 CFR 2.302(g), with their initial paper filing requesting authorization to continue to submit documents in paper format. Such filings must be submitted by (1) first class mail addressed to the Office of the Secretary of the Commission, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, ATTN: Rulemaking and Adjudications Staff; or (2) courier, express mail, or expedited delivery service to the Office of the Secretary,

Sixteenth Floor, One White Flint North, 11555 Rockville Pike, Rockville, MD 20852, ATTN: Rulemaking and Adjudications Staff. Participants filing a document in this manner are responsible for serving the document on all other participants. Filing is considered complete by first-class mail as of the time of deposit in the mail, or by courier, express mail, or expedited delivery service upon depositing the document with the provider of the service.

Documents submitted in adjudicatory proceedings will appear in NRC's electronic hearing docket, which is available to the public at <https://adams.nrc.gov/ehd>, unless excluded pursuant to an order of the Commission, an Atomic Safety and Licensing Board, or a Presiding Officer. Participants are requested not to include personal privacy information, such as social security numbers, home addresses, or home phone numbers in their filings, unless an NRC regulation or other law requires submission of such information. With respect to copyrighted works, except for limited excerpts that serve the purpose of the adjudicatory filings and would constitute a Fair Use application, participants are requested not to include copyrighted materials in their submissions.

## VI

In the absence of a request for hearing, or written approval of an extension of time in which to request a hearing, License No. 47-35507-01 shall be revoked and all other provisions in Part III of this Order shall be final within 30 days of the date of this Order without further order or proceedings. If an extension of time for requesting a hearing has been approved, the provisions in Part V shall be final when the extension expires if a hearing request has not been received.

## VII

Pursuant to 10 CFR 15.29, the Commission may not consider an application for a new license unless all of the applicant's delinquent debts to the NRC have been paid in full.

Failure to meet the requirements of this Order may subject the Licensee and its agents to civil penalties and criminal sanctions.

For the Nuclear Regulatory Commission.  
/RA/  
David L. Pelton,  
Director, Office of Enforcement.

Dated at Rockville, Maryland, This 11th day of May, 2023.

[FR Doc. 2023-12988 Filed 6-15-23; 8:45 am]

BILLING CODE 7590-01-P

## NUCLEAR REGULATORY COMMISSION

[NRC-2023-0001]

### Sunshine Act Meetings

**TIME AND DATE:** Weeks of June 19, 26, July 3, 10, 17, 24, 2023. The schedule for Commission meetings is subject to change on short notice. The NRC Commission Meeting Schedule can be found on the internet at: <https://www.nrc.gov/public-involve/public-meetings/schedule.html>.

**PLACE:** The NRC provides reasonable accommodation to individuals with disabilities where appropriate. If you need a reasonable accommodation to participate in these public meetings or need this meeting notice or the transcript or other information from the public meetings in another format (e.g., braille, large print), please notify Anne Silk, NRC Disability Program Specialist, at 301-287-0745, by videophone at 240-428-3217, or by email at [Anne.Silk@nrc.gov](mailto:Anne.Silk@nrc.gov). Determinations on requests for reasonable accommodation will be made on a case-by-case basis.

**STATUS:** Public.

Members of the public may request to receive the information in these notices electronically. If you would like to be added to the distribution, please contact the Nuclear Regulatory Commission, Office of the Secretary, Washington, DC 20555, at 301-415-1969, or by email at [Wendy.Moore@nrc.gov](mailto:Wendy.Moore@nrc.gov).

### MATTERS TO BE CONSIDERED:

#### Week of June 19, 2023

*Tuesday, June 20, 2023*

9:00 a.m. Briefing on Results of the Agency Action Review Meeting (Public Meeting) (Contact: Nicole Fields: 630-829-9570)

*Additional Information:* The meeting will be held in the Auditorium, 11545 Rockville Pike, Rockville, Maryland. The public is invited to attend the Commission's meeting in person or watch live via webcast at the Web address—<https://video.nrc.gov/>.

#### Week of June 26, 2023—Tentative

There are no meetings scheduled for the week of June 26, 2023.

#### Week of July 3, 2023—Tentative

There are no meetings scheduled for the week of July 3, 2023.

**Week of July 10, 2023—Tentative**

There are no meetings scheduled for the week of July 10, 2023.

**Week of July 17, 2023—Tentative**

There are no meetings scheduled for the week of July 17, 2023.

**Week of July 24, 2023—Tentative**

There are no meetings scheduled for the week of July 24, 2023.

**CONTACT PERSON FOR MORE INFORMATION:**

For more information or to verify the status of meetings, contact Wesley Held at 301–287–3591 or via email at [Wesley.Held@nrc.gov](mailto:Wesley.Held@nrc.gov).

The NRC is holding the meetings under the authority of the Government in the Sunshine Act, 5 U.S.C. 552b.

Dated: June 14, 2023.

For the Nuclear Regulatory Commission.

**Wesley W. Held,**

*Policy Coordinator, Office of the Secretary.*

[FR Doc. 2023–13066 Filed 6–14–23; 4:15 pm]

**BILLING CODE 7590–01–P**

**NUCLEAR REGULATORY COMMISSION**

[Docket Nos. 50–456 and 50–457; NRC–2023–0105]

**Constellation Energy Generation, LLC; Braidwood Station, Units 1 and 2**

**AGENCY:** Nuclear Regulatory Commission.

**ACTION:** Environmental assessment and finding of no significant impact; issuance.

**SUMMARY:** The U.S. Nuclear Regulatory Commission (NRC) is considering issuance of amendments to Renewed Facility Operating License Nos. NPF–72 and NPF–77, which authorize Constellation Energy Generation, LLC, (Constellation, licensee) to operate Braidwood Station (Braidwood), Units 1 and 2. The proposed amendments would change Technical Specification (TS) Surveillance Requirement (SR) 3.7.9.2 to allow an ultimate heat sink (UHS) temperature of less than or equal to 102.8 degrees Fahrenheit (°F) from the date of issuance of the amendments through September 30, 2023.

**DATES:** The environmental assessment (EA) and finding of no significant impact (FONSI) referenced in this document are available on June 16, 2023.

**ADDRESSES:** Please refer to Docket ID NRC–2023–0105 when contacting the NRC about the availability of information regarding this document. You may obtain publicly available

information related to this document using any of the following methods:

- *Federal Rulemaking Website:* Go to <https://www.regulations.gov> and search for Docket ID NRC–2023–0105. Address questions about Docket IDs in *Regulations.gov* to Stacy Schumann; telephone: 301–415–0624; email: [Stacy.Schumann@nrc.gov](mailto:Stacy.Schumann@nrc.gov). For technical questions, contact the individual listed in the **FOR FURTHER INFORMATION CONTACT** section of this document.

- *NRC's Agencywide Documents Access and Management System (ADAMS):* You may obtain publicly available documents online in the ADAMS Public Documents collection at <https://www.nrc.gov/reading-rm/adams.html>. To begin the search, select “Begin Web-based ADAMS Search.” For problems with ADAMS, please contact the NRC's Public Document Room (PDR) reference staff at 1–800–397–4209, 301–415–4737, or by email to [PDR.Resource@nrc.gov](mailto:PDR.Resource@nrc.gov). For the convenience of the reader, instructions about obtaining materials referenced in this document are provided in the “Availability of Documents” section.

- *NRC's PDR:* You may examine and purchase copies of public documents, by appointment, at the NRC's PDR, Room P1 B35, One White Flint North, 11555 Rockville Pike, Rockville, Maryland 20852. To make an appointment to visit the PDR, please send an email to [PDR.Resource@nrc.gov](mailto:PDR.Resource@nrc.gov) or call 1–800–397–4209 or 301–415–4737, between 8 a.m. and 4 p.m. eastern time (ET), Monday through Friday, except Federal holidays.

**FOR FURTHER INFORMATION CONTACT:** Joel S. Wiebe, Office of Nuclear Reactor Regulation, U.S. Nuclear Regulatory Commission, Washington, DC 20555–0001, telephone: 301–415–6606; email: [Joel.Wiebe@nrc.gov](mailto:Joel.Wiebe@nrc.gov).

**SUPPLEMENTARY INFORMATION:****I. Introduction**

The NRC is considering issuance of amendments to Renewed Facility Operating License Nos. NPF–72 and NPF–77, which authorize Constellation Energy Generation, LLC, to operate Braidwood Station, Units 1 and 2, located in Will County, Illinois. Constellation submitted its license amendment request in accordance with section 50.90 of title 10 of the *Code of Federal Regulation* (10 CFR), by letter dated March 24, 2023. If approved, the license amendments would revise TS SR 3.7.9.2 to allow a temporary increase in the allowable UHS average temperature of less than or equal to ( $\leq$ ) 102.8 °F (39.3 degrees Celsius (°C)) from the date of issuance of the amendments

through September 30, 2023. Therefore, as required by 10 CFR 51.21, the NRC performed an environmental assessment (EA). Based on the results of the EA that follows, the NRC has determined not to prepare an environmental impact statement for the proposed amendments and is issuing a FONSI.

**II. Environmental Assessment***Description of the Proposed Action*

The proposed action would revise the Braidwood TS to allow a temporary increase in the allowable average temperature of water withdrawn from the UHS and supplied to the plant for cooling from  $\leq 102$  °F (38.9 °C) to  $\leq 102.8$  °F (39.3 °C) from the date of issuance of the amendments through September 30, 2023. Specifically, the proposed action would revise TS SR 3.7.9.2, which currently states, “Verify average water temperature of UHS is  $\leq 102.8$  °F until September 30, 2022. After September 30, 2022, verify average water temperature of UHS is  $\leq 102$  °F” to state “Verify average water temperature of UHS is  $\leq 102.8$  °F until September 30, 2023. After September 30, 2023, verify average water temperature of UHS is  $\leq 102$  °F.” Under the current TS, if the average UHS temperature as measured at the discharge of the operating essential service water system pumps is greater than 102 °F (38.9 °C), TS 3.7.9, Required Actions A.1 and A.2, would be entered concurrently and would require the licensee to place Braidwood in hot standby (Mode 3) within 12 hours and cold shutdown (Mode 5) within 36 hours. The proposed action would allow Braidwood to continue to operate during times when the UHS indicated average water temperature exceeds 102 °F (38.9 °C) but is less than or equal to 102.8 °F (39.3 °C) from the date of issuance of the amendments through September 30, 2023. The current TS's UHS average water temperature limit of 102 °F (38.9 °C) would remain applicable to all other time periods beyond September 30, 2023. The proposed action is nearly identical to previously approved license amendments that allowed for the average water temperature of the UHS to be  $\leq 102.8$  °F for specified periods until September 30, 2020, September 30, 2021, and September 30, 2022. The NRC issued EAs for the 2020, 2021, and 2022, UHS amendments in the **Federal Register** on September 10, 2020 (85 FR 55863), July 7, 2021 (86 FR 35831), and July 20, 2022 (87 FR 43301), respectively. The NRC issued the amendments on September 24, 2020, July 13, 2021, and August 10, 2022, respectively. The only difference